



**ADDIS ABABA UNIVERSITY
ADDIS ABABA INSTITUTE OF TECHNOLOGY
SCHOOL OF ELECTRICAL AND COMPUTER ENGINEERING**

**STUDIES ON APPLICATIONS OF FACTS DEVICES TO IMPROVE
OVERLOADING AND UNBALANCED POWER SYSTEM OPERATING
CONDITONS ON ETHIOPIAN GRID**

BY: ABIY ATAKURE TEKELEHIMANOT

ADVISOR: PROF.N.P. SINGH

A Thesis Submitted to Addis Ababa Institute of Technology, School of
Graduate Studies Addis Ababa University in Partial Fulfillment of the
Requirement for the Degree of Masters of Science in Electrical
Engineering (Electrical Power Engineering)

April, 2019

Addis Ababa, Ethiopia



**ADDIS ABABA UNIVERSITY
ADDIS ABABA INSTITUTE TECHNOLOGY
SCHOOL OF ELECTRICAL AND COMPUTER ENGINEERING**

BY: ABIY ATA KURE TEKELEHIMANOT

Chairman, Department of Electrical
And Computer Engineering

Signature

Prof. N.P. Singh
Advisor

Signature

Internal Examiner

Signature

External Examiner

Signature

Declaration

I, the undersigned declare that this thesis is my original work, has not been presented for Degree in this or other universities, all sources of materials for this thesis have been fully acknowledged

Abiy Atakure
GSE/1058/07

Place: Addis Ababa Institute of Technology, Addis Ababa University, Addis Ababa

Date of Submission: _____

This is certifying that the above statement made by the student is correct and true to the best of my knowledge and belief.

Prof.N.P. Singh

Advisor's Name

signature: _____

Acknowledgment

First of all, I would like to thank God, for His provision of strength that helped me to overcome any difficulties during the entire work. Without His help I couldn't be able to finish it.

Secondly, I would like to express my gratitude to my advisor Prof.N.P. Singh, for his valuable comment, timely response and great commitment. I'm also grateful to his motivation and his dynamic suggestions for solutions to any of the challenges faced during the thesis work.

Then I would like to appreciate my workmates and friends, Ethiopian Electric Power corporation staffs for their hospitality and willingness to provide me the PSS/E dongle to use it for simulation for the entire transmission grid. I have received a very keen support from the office during the overall period of the study.

And I want to thank all my family for their continuous and tireless support. Finally, I want to say thank you to all my friends who took part in this work directly or indirectly.

Table of Contents

| | |
|----------------------------------------|------|
| Declaration | II |
| Acknowledgment | III |
| Table of Contents | IV |
| List of Figures | VII |
| List of Tables..... | VIII |
| Acronyms | IX |
| Abstract | XI |
| CHAPTER 1..... | 1 |
| INTRODUCTION..... | 1 |
| 1.1 Background..... | 1 |
| 1.2 Statement of the Problem | 3 |
| 1.3 Objectives of the Thesis | 4 |
| 1.4 Methodology..... | 5 |
| 1.5 Literature Review | 6 |
| 1.6 Organization of the Thesis..... | 11 |
| CHAPTER 2..... | 13 |
| FUNDAMENTALS OF FACTS CONTROLLERS..... | 13 |
| 2.1 Introduction | 13 |

| | | |
|---------------------------------------------------------------------------------------------|-----------------------------------------------------------------------|----|
| 2.2 | Types of FACTS Controllers | 14 |
| 2.3 | Distributed Series Reactance..... | 18 |
| 2.4 | DSR for Power Flow Controller | 23 |
| CHAPTER 3..... | | 26 |
| ETHIOPIAN GRID TRANSMISSION SYSTEM AND DISTRIBUTED SERIES REACTANCE PLACEMENT..... | | 26 |
| 3.1 | Introduction | 26 |
| 3.2 | Ethiopian Grid System Modeling Using PSS/E..... | 30 |
| 3.3 | Model in PSS/E | 36 |
| 3.4 | Investigation of Partial Blackout of the System as of 2017..... | 38 |
| 3.5 | DSRs Placement to Improve the Performance of Transmission System..... | 42 |
| CHAPTER 4..... | | 48 |
| PERFORMANCE EVALUATION OF THE TRANSMISSION SYSTEM WITH DSRs AND COST BENEFIT ANALYSIS | | 48 |
| 4.1 | Introduction | 48 |
| 4.2 | Simulation Studies of the Transmission System without DSR..... | 49 |
| 4.3 | Simulation Studies of the Transmission System with DSRs | 51 |
| 4.4 | Analysis of Simulation Results | 55 |
| 4.5 | Cost Benefit Analysis of Using DSRs..... | 58 |
| CHAPTER 5..... | | 61 |

| | |
|----------------------------------------------------|-----|
| CONCLUSIONS, RECOMMENDATIONS AND FUTURE WORK | 61 |
| 5.1 INTRODUCTION..... | 61 |
| 5.2 CONCLUSIONS..... | 61 |
| 5.3 RECOMNDATIONS | 62 |
| 5.4 SUGGESTIONS OF FUTURE WORK | 62 |
| REFERNCES | 64 |
| APPENDIX A: Summary of Contingency Analysis | 68 |
| APPENDIX B: Peak Load 2017 Data’s..... | 83 |
| APPENDIX C: Load Flow Analysis..... | 116 |
| APPENDIX D: General Network Diagram of EEP..... | 121 |

List of Figures

| | |
|---------------------------------------------------------------------------------------------------------------------------------|----|
| FIGURE 2-1 TYPES OF FACTS CONTROLLERS | 14 |
| FIGURE 2-2 TWO BUS SYSTEM | 15 |
| FIGURE 2 -3 SCHEMATIC CIRCUIT OF DSR [9] | 19 |
| FIGURE 2- 4 DSR CONNECTED TO A TRANSMISSION LINE [10] | 19 |
| FIGURE 2- 5 D-FACTS DEPLOYED ON POWER LINE | 20 |
| FIGURE 2-6 DSR COMMUNICATIONS | 22 |
| FIGURE 2 -7KEY ELEMENTS OF THE INTERFACE TREE VIEW, MAIN MENU, TOOLBARS, SPREADSHEET, VIEW OUTPUT BAR DIAGRAM, VIEW STATUS BAR. | 32 |
| FIGURE 2- 8 OVERVIEW OF THE SPREADSHEET VIEW | 33 |
| FIGURE 2 -9 TREE VIEW (EXPANDABLE FORM OF NETWORK COMPONENTS) | 34 |
| FIGURE 2- 10 OVERVIEW OF DIAGRAM VIEW OF A SAMPLE SYSTEM | 35 |
| | |
| FIGURE 3-1 COST ALLOCATION US\$M IN 2016 MONEY | 27 |
| FIGURE 3-2EXISTING AND PLANNED GENERATION AND TRANSMISSION SYSTEM | 28 |
| FIGURE 3- 3 LOADING ABOVE ITS RATINGS | 43 |
| FIGURE 3- 4 NODE VIEW OF WOLYTA SODO II..... | 44 |
| FIGURE 3-5NODE VIEW OF WOLYTA SODO II FOR PLACEMENT OF DSRS..... | 45 |
| FIGURE 3- 6 RELATION BETWEEN INJECTED INDUCTANCE AND LINE CURRENT | 46 |
| | |
| FIGURE 4- 1 LINE GRAPHS FOR BRANCHES LOADING, RATINGS AND PERCENTAGE | 50 |
| FIGURE 4-2 POWER FLOWS ON BRANCHES WITHOUT USING DSRS | 51 |
| FIGURE 4-3POWER FLOW ON BRANCHES USING DSRS..... | 54 |
| FIGURE 4-4COMPARISONS OF POWER FLOWS..... | 56 |
| FIGURE 4- 5 COMPARISONS OF POWER FLOWS | 56 |

FIGURE 4-6 CHANGES IN POWER FLOWS BY ADDING DSRs.....57

List of Tables

TABLE 3-1 TRANSMISSION AND SUB TRANSMISSION LINES ON THE EXISTING SYSTEM [1] 27

TABLE 3- 2 GENERATION DISPATCH 38

TABLE 3-3 INTERCONNECTION TRANSFER 39

TABLE 3-4 SEQUENCE OF EVENTS 40

TABLE 3-5 LOADING ABOVE ITS RATINGS 42

TABLE 3- 6 LINE PARAMETERS 46

TABLE 4- 1 TRANSMISSION LINES SELECTED FOR ANALYSIS 48

TABLE 4-2 BRANCHES LOADING, RATINGS AND PERCENTAGE WITHOUT DSR 49

TABLE 4-3 PLACEMENT OF DSR HAVING ITS REACTANCE VALUE 20% OF 132KV ALABA
– WOLYTA SODO II LINE..... 52

TABLE 4- 4 PLACEMENT OF DSR HAVING ITS REACTANCE VALUE 30% OF 132KV ALABA
– WOLYTA SODO II LINE..... 53

TABLE 4- 5 PLACEMENT OF DSR HAVING ITS REACTANCE VALUE 50% OF 132KV ALABA
– WOLYTA SODO II LINE..... 53

Acronyms

| | |
|---------|---------------------------------------------------|
| % | Percentage |
| ALA | Alaba |
| ASW | Active Smart Wire |
| DC | Direct Current |
| D-FACTS | Distributed FACTS |
| DOE | Department of Energy |
| DSI | Distributed Series Impedance |
| DSR | Distributed Series Reactance |
| DSSC | Distributed Series Static Compensator |
| DUM | Dummy |
| EEPG | Ethiopian Electric Power Grid |
| EHV | Extra High Voltage |
| EMS | Energy Management System |
| FACTS | Flexiable Alteranting Current Tranmission Systems |
| GRED | Great Renaissance Dam |
| GUI | Graphic User Interface |
| GW | Giga Watt |
| HV | High Voltage |
| km | Kilometer |
| kV | Kilo volt |
| M\$ | Million United States Dollar |
| MVAr | Mega Volt Amper |
| MW | Mega Watt |

| | |
|---------|--------------------------------------|
| NGCC | National Grid Control Center |
| OPF | Optimal Power Flow |
| PSS/E | Power System Simulator for Engineers |
| pu | Per unit |
| R | Resistance |
| RAS | Remedial Action Scheme |
| S | Apparent Power |
| SPS | Special Protection Scheme |
| T&D | Transmission and Distribution |
| TVA | Tennessee Valley Authority |
| U.S | United States |
| USD | United States Dollar |
| V | Voltage |
| VAR | Volt Amper |
| WS2 | Wolyta Sodo Two |
| Z | Impedance |
| μ H | Micro Henry |

Abstract

An important issue in today's power system is the need to analyze and determine the adequacy of transmission capacity. There is a need for approaches to increase transmission system capacity without construction of new transmission facilities, all while assuring secure operation of the grid. Smart grid technologies such as FACTS and DSRs can enhance capacity utilization and increase flexibility in controlling power flows on transmission lines.

Distributed Series Reactor (DSR) control is a new smart grid technology that can be applied to control flows in the transmission system. DSRs can be used to balance flows in a single line as well as to control the distribution of power flows in parallel lines. This thesis investigates the application of Distributed Series Reactors (DSRs) on Ethiopian National Grid transmission systems to control power flow and to improve the overloaded line capacity and shifting power to other parallel branches which are under loaded. Simulation studies are carried out on Ethiopian grid using power system simulation for Engineers (PSS/E). 400kV, 230kV and 132 kV transmission lines of the Ethiopian grid are considered for simulation studies.

Placement of a DSR having its reactance value 20% of the overloaded line enhances the existing transmission capacity utilization of the 400kV lines by 89.22%, for the 230kV lines by 81.28% and the same for 132kV lines by 83.79%. Moreover, the overloading condition of the 132kV line is improved by 95%.

Placement of a DSR having its reactance value 30% of the overloaded line enhances the existing transmission capacity utilization of the 400kV lines by 89.22%, the 230kV lines by 81.32% and the same for 132kV lines by 82.42%. Moreover, the overloading condition of the 132kV line is improved by 85%.

Placement of a DSR having its reactance value 50% of the overloaded line enhances the existing transmission capacity utilization of the 400kV lines by 89.22%, the 230kV

lines by 81.31% and the 132kV lines by 80.13%. Moreover, the overloading condition of the 132kV line is improved by 79%.

In this study cost benefit analysis of DSR placement having its reactance value 20% of the overloaded line is performed. The cost benefit analysis for the construction of new transmission line for 84.76% capacity improvement needs 12.25M\$ and the total cost for the same capacity improvement using DSRs are deployed on the overloaded line needs 3.33M\$. Comparing this total cost of DSRs which is 3.33M\$ with that of building new lines which is 12.25M\$, it appears that the DSRs implementation cost reduced by 27.18 % relative to the traditional approach of building new lines.

Key Words: Distributed Series Reactance (DSR), Ethiopian Transmission System, Power transfer capacity, Overloaded Lines and Cost Benefit Analysis.

CHAPTER 1

INTRODUCTION

1.1 Background

In recent years, Ethiopian grid system has been progressed in rapid development and expansion processes. Many big hydro power plants and very long EHV transmission lines has been added to the grid to serve the fast-growing economy of the country, also in the near future many more power plants and transmissions systems are expected to be connected with the power grid.

Interconnections and power trading with other control areas (neighboring countries), Sudan and Djibouti have been realized, enabling robustness and dynamicity of the grid. Further, power grid interconnectors will be available in the east African regions, example Ethio-kenya, Ethio-Sudan-Egypt, etc.

Since, Ethiopia has a great deal of hydro and wind power potential, the interconnectors will create opportunities for foreign electricity market, mainly to sell electricity to east African countries. Apart from this the interconnectors will have mutual benefits for reliability and security of the interconnected grid system itself and social-economical & political stability of the region.

In the last two decades local customers of EEP ranging from very big industries to small household customers, their demand for electric power is growing at a very fast rate. Foreign investment policy of the country is highly attractive and due to this various type of new industries are booming & being operational. To serve this vast electric power demand, improving existing power grid reliability and security is mandatory & highly essential.

Currently, EEU customers get access for electricity either through the National Electric Power Grid or through the Off-Grid system. The former is the most dynamic,

robust and very huge interconnected electricity infrastructure supplying most urban areas, being the backbone for industrialization and economic transformation, also having interconnectors with other National Power Grid (neighboring countries) for electricity export and trading. The later one is very small, self-contained system (SCS) supplying electricity to remote and localized areas very far from existing national grid system.

The Ethiopian National Grid is 100% powered by renewable energy resources mainly coming from hydro and wind power plants. Installed capacity of Hydro power plants is 2657MW, Wind power plant 328MW and others. In addition, GRED hydro power project having a capacity of 6000MW is also expected to be connected stage by stage. In the year 2020 the total installed capacity of the Ethiopian National Grid will be more than **10,000MW** [1].

There are **155** number of substation under transmission substation operation department, and **19** number of power plant substation managed by Generation operation department. Therefore, in total there are **174** number of substation in the grid system including 500/400/230/132/66/45/33/15kV substations. The Ethiopian National Grid Control Center-NGCC is responsible for the grid reliability operation & coordination.

A recent Department of Energy (DOE) report highlights the problem of congestion in transmission lines near major metropolitan centers. Transmission network infrastructures face much more public opposition and as a result take longer to get approvals and land for the construction of newlines. As the load continues to increase it is possible that the transmission network may not be able to keep up with the increase of the load.

In transmission system planning projects, the cost of congestions often a consideration. Building new transmission lines may not be the most cost effective approach to alleviating congestion [2]. Many researchers have looked for a way to

control power flow that is less costly than building new lines. For some cases, the only solution to control flow is to invest in new lines; A few studies [3] investigate several different methods for controlling power flow. Other authors use series and shunt compensator devices to control power flow. Other studies [4] propose using flexible alternating current transmission system devices, but these devices are expensive for large area implementations, but in some cases, there are other solutions. One new techniques for controlling power flow, distributed series reactors (DSRs), shows promise.

Distributed series reactors are lightweight devices that can be installed quickly on transmission lines [5]. Distributed series reactors can be used to increase the capacity of a transmission system by moving flow from heavily loaded lines to lines that are in parallel and which have unused capacity. This is accomplished by using the DSRs to increase the reactance of the heavily loaded lines. In the study here, DSRs are used as an alternative way to alleviate overloading problems, providing economic benefits overbuilding new transmission lines.

1.2 Statement of the Problem

The transmission system is the core part of power system network which deliver power to the distribution system. Maximize the capacity power flow on the transmission line plays a key role to reduce transmission networks take a much longer time to plan and construct and reduce investment on new lines, moreover getting transmissions line corridor has been a challenge specially in major cities like in Addis Ababa due to huge displacement cost are a head ache for the utility provider. The 132kV Alaba – Wolyta Sodo II transmission line which is connected to the 230kV and 400kV lines is overloaded and this line is connected to the maximum generating plant like Gibe III. It is a problem for using efficiently the 400kV lines which have a big capacity to transport more power to the load center. Moreover, it will be a cause for cascading failures for the power system. Analysis such kinds of problems on

applications of FACTS devices to improve overloading and unbalanced conditions using Power system simulation software for Engineers (PSS/E) on existing power grid.

These days, the Ethiopian Electric Power grid is highly suffering from frequent blackouts, 15 number of blackout has been recorded in the year 2015 alone [1]. Most blackouts were the results of cascading failures of the power system due to some lines are overloaded. Preventing such blackouts is a very important goal that requires detail study, analysis & close monitoring of the state of the power flow

This thesis considers or focuses on problems of overloading and unbalanced operating conditions in 400kV, 230kV and 132kV transmission system of Ethiopian national grid and investigates the methods for solving the above problems as well as to enhance the power transfer capacity of the transmission system.

1.3 Objectives of the Thesis

General Objective

The general objective of this thesis is to analyze and investigate the unbalanced and overloaded operating conditions of Ethiopian national grid transmission system and to explore the applications of FACTS devices for alleviation of these problem as well as to enhance to its power transfer capacity.

Specific Objectives of the Thesis

The specific objectives of the thesis research are as follows:

- To evaluate and analyze the power transfer capacity 400kV, 230kV and 132kV transmission systems of Ethiopian national grid and identify the unbalanced and overloaded operating conditions.

- To investigate the mitigation of unbalanced and overloaded operating conditions of the transmission system using DSRs
- To determine the capacity and location of DSR to solve the overloaded and unbalanced operating conditions.
- To carry out simulation studies using PSS/E (power system simulation for engineers) and compare the power transfer capacity with the existing transmission system with that obtained using the proposed technique or method.
- To carry out cost benefit analysis of the existing system with implementation of DSR and the new transmission system with the same power transfer capacity.
- To draw relevant conclusions and make recommendations for improvement of capacity on transmission systems on Ethiopian power grid (EEPG)

1.4 Methodology

132kV, 230kV and 400kV transmission systems from existing Ethiopian national grid are considered for the study of overloaded and unbalanced power system operating conditions. The capacity improvement analysis has been carried out using Power System Simulation for Engineers (PSS/E) during peak load of 2017 of the grid. Two cases are evaluated during power flow study where the capacity enhancements on 400kV, 230kV and 132kV transmission system are determined. The cases are: (1) Power flow study without DSRs are used; (2) Power flow study with placement of DSRs having its reactance value 20%,30% and 50% are operated on the overloaded line in an attempt to better utilize the capacity of each line.




Figure 1- 1 DSR placing and operating flow chart

1.5 Literature Review

Initial field trials distributed series reactor implications for future applications presented by Bruce Rogers [25]. The Distributed Series Reactor is a self-contained device, powered by induction from a transmission line conductor that increases the series impedance of a circuit by injecting series reactance. The concept was first demonstrated in 2002 – 2003 and has been demonstrated in pilot installations on HV

transmission lines. For a 161-kV line, assume 5 spans per mile and a device at each end of each span i.e. 10 devices per mile. Approximate impedance increase = 20%. An application had been tried on 39 bus system grid for a base line 1904 MW and increase the MW to 638 (33.5%) and line availability from 59 % to 93% using distributed series reactance.

The pilot test results: -

- Total Impedance Increase (33 DSRs / Phase @ 47 μ H / DSR): .226 % (degree of control limited by number of available devices and a test line that was longer than optimal for the demonstration)
- Devices also successfully used to adjust phase imbalance
- Single point failure of communication system identified for necessary design upgrade
- DSRs presently considered unsuitable for bundled conductor use, although technically feasible
- Simplest application is reduction of maximum contingency load for postponement of line up rate
- Ability to quickly relocate DSRs reduces cost to individual projects
- Future designs may provide capacitive injection to reduce reactive impedance
- Future designs with high speed controls may be low cost alternative to FACTS

Load growth and power flow control with DSRs: Balanced vs unbalanced transmission networks, Shamia Omran [26]. A new smart grid technology, the Distributed Series Reactor (DSRs), is investigated in this paper. DSRs can be used to balance flows in the phases of an unbalanced line or used to control the distribution of flow in a meshed network. In this paper, DSRs will be used to alleviate overloads that result due to increased load. The design is performed for an unbalanced, 3-phase system, and then for a balanced, 3-phase model derived from the unbalanced model,

where the symmetrical components transformation is used to create the balanced model.

- The authors have created 3-phase models of transmission systems for 7 different utilities in the U.S., where some of the transmission systems spanned multiple states, and included volt-age levels of 230 kV, 345 kV, and 500 kV, where the majority of the lines were not transposed. In several utilities there were no transposed lines in the transmission systems. The reasons for imbalance at the receiving end of a line can be due to impedance unbalance, load unbalance, and sending end voltage unbalance. This paper only addresses impedance unbalance, but as demonstrated in the case study in the paper, the effects of impedance unbalance (i.e., non-transposed lines) can be significant on flows and voltages. Thus, to investigate the effect on DSR design of the line impedance model, two cases are considered, an unbalanced, 3-phase impedance model, and a balanced, 3-phase impedance model. The balanced model is derived by assuming that the lines in the unbalanced model are transposed. In the unbalanced model the self-impedances are unequal with symmetrical but unequal off diagonal elements. The same is true for the shunt admittance matrix of the unbalanced model. In the balanced model the impedance matrix has diagonal elements that are equal in value and off diagonal elements that are zero

The author investigates:

- The overloads start to occur in the balanced model at 141% load growth, whereas overloads do not occur in the unbalanced model until 145% load growth is reached. At the 141% and 143% load levels, the unbalanced model has no overloads and no DSRs are needed. However, the balanced model experiences overloads at the 141% and 143% load levels, where 75 DSRs and 900 DSRs are required, respectively. This is quite a significant difference between the 2 models.

- At the 149% load level, 3750 DSRs are deployed in the unbalanced model to alleviate overloads whereas in the balanced mode 15550 DSRs are deployed
- For a given loading, use of the balanced model in the design results in many more DSRs for control than when the unbalanced model is used in the design. It was shown that the balanced model assumption, if used when lines are truly unbalanced, can lead to significant errors.
- The majority of the transmission system in the U.S. is unbalanced, and since significant errors can arise when just the impedance unbalance is considered.
- The application of DSRs can increase the utilization of the line capacity in a system. This increased utilization can delay or eliminate the need for building new transmission lines. Whether DSRs should be used to increase line utilization or new lines should be built is partly an economic question.

Investigation of distributed series reactors in power system applications and its economic implementation by Ahmet Onen [27]. The transmission system expansion planning process requires lots of calculations looking many years into the future, and the results are based on assumed load growth. If the load growth assumed in the planning process is not correct and unexpected load growth occurs for some load points, the transmission system could face serious congestion and even overloading problems.

In this paper, transmission line impedance adjustment techniques using distributed series reactance (DSR) is considered. The IEEE39 bus transmission system used in this work. Line ratings, line lengths, and load flows for the system have been taken. The DSR congestion relief factor is defined as the rate of maximum system loading without DSRs to the maximum system loading with DSRs, as given by equation (2.13)

$$\text{DSRCongestionReliefFactor} = \frac{\text{LoadingWithoutDSR}}{\text{LoadingwithDSR}} \quad (2.13)$$

This study represents a new control method of power flow by using DSR modules. Algorithm is tested on the IEEE New England (39bus) test system. The results and observations with the DSR algorithm are stated here:

- The proposed algorithm with DSR modules can be used to manage power flow and capacity expansion and reduce overloads when some areas require special load growth.
- The proposed algorithm with DSRs is tested for constant load growth applied to each bus, and the results show that the proposed algorithm is also useful for entire-system expansion planning
- Single contingency of generation outage is tested with the proposed algorithm. The results show that the proposed algorithm fully utilizes the capacity of the existing system by using DSRs when generation outages occurred
- Line outages are also tested with the proposed algorithm and one of the largest lines was taken out by considering the worst case; the results show that the DSR algorithm can utilize capacity effectively, when there are line outages and also overloading problems when there is a line contingency as well.
- Simulation results show the practicability and success of the DSR technique as a control for power flow in providing a cheaper alternative to the construction of new transmission lines.

Feasibility of DSR applications in transmission grid operation—Control of power flow and imbalanced voltage by Mohammad Nawaf Nazira^{*}, Shaimaa Omran^a, Robert Broadwater^b [31]. This paper studied the application of Distributed Series Reactors(DSRs) in increasing transmission capacity and reducing voltage imbalance in unbalanced transmission networks. The IEEE 39 bus standard transmission system model was modified to a 3-phase, unbalanced, model consisting of lines operating at 230 kV, 345 kV and 500 kV.

It was shown that as the network load is increased and with-out employing DSRs, the full capacity of the transmission network was underutilized as the low voltage line, the

230 kV line, over-loaded first, and the high voltage line, the 345 KV line, was left with significant unused transmission capacity. In order to increase the utilization of the high voltage line, DSRs are added to the low volt-age line, and this has the effect of pushing more power toward the alternate high voltage path.

With the unbalanced transmission lines evaluated, it is found that unsymmetrical operation of DSRs is more beneficial than symmetrical operation. With the unsymmetrical operation only half the number of DSRs is needed to achieve the same trans-mission capacity increase. Hence, unbalanced operation of DSRs over the phases of the low voltage line can result in substantial transmission capacity increase while using substantially fewer DSRs.

The economic analysis for symmetrical and unsymmetrical operation of DSRs demonstrated significant potential economic benefits from using DSRs.

The second part of the paper studied the application of DSRs to reduce voltage imbalance. In applications where reducing the voltage imbalance rather than increasing the transmission capacity is the main objective, DSRs can also be useful.

The modified 3-phase, IEEE 39 bus system is again used to study the voltage imbalance. In this case a 345 KV line in parallel with a 500 KV line was considered. It is found that under certain unsymmetrical DSR operation on the 500 kV line, the voltage imbalance at the receiving end of the line can be reduced from 0.275% to about 0.008%.

1.6 Organization of the Thesis

The thesis is organized into five Chapters:

In chapter 1 is an introductory part giving background of the study. The basic problem is described. The objectives of the thesis work are stated. The methodologies are clearly described and finally researchers done in the area of the application of

distributed series reactance have been discussed in detail. In Chapter 2 deals with fundamentals of FACTS Controllers deeply assessed. Different kinds of FACTS controllers and the basic principle have been discussed. The concept of using a distributed series compensator to control the power flow and the proposed power flow controller in this study clearly described.

In chapter 3, Ethiopian grid existing transmission system overview is evaluated. Overloaded and under loaded lines are identified at peak load power flow. Placement of distributed series reactance on overloaded line is conducted.

In Chapter 4 is simulation Studies using power system simulator for engineers (PSS/E) are carried out on the overloaded line. Performance evaluations without DSR and with DSR with regarding to capacity improvements of the 400kV, 230kV and 132kV transmission system have been investigated. The cost benefits Analysis of DSR with regard to construction of new transmission line is conducted.

Finally, conclusions, recommendations, and future researches are discussed in chapter 5. Results obtained from the thesis work are summarized and relevant conclusions have been drawn. Possible solutions for the problems during the thesis work have been recommended and future works in the area of the application of DSRs are proposed.

CHAPTER 2

FUNDAMENTALS OF FACTS CONTROLLERS

2.1 Introduction

In its most general expression, the FACTS concept is based on the substantial incorporation of power electronic devices and methods into the high-voltage side of the network, to make it electronically controllable. Many of the ideas upon which the foundation of FACTS rests evolved over a period of many decades. Nevertheless, FACTS, an integrated philosophy, is a novel concept that was brought to fruition during the 1980s [6]. FACTS look at ways of capitalizing on the many breakthroughs taking place in the area of high-voltage and high current power electronics, aiming at increasing the control of power flows in the high voltage side of the network during both steady-state and transient conditions. The new reality of making the power network electronically controllable has started to alter the way power plant equipment is designed and built as well as the thinking and procedures that go into the planning and operation of transmission and distribution networks. These developments may also affect the way energy transactions are conducted, as high-speed control of the path of the energy flow is now feasible. Owing to the many economical and technical benefits it promised, FACTS received the instinctive support of electrical equipment manufacturers, utilities, and research organizations around the world.

Several kinds of FACTS controllers have been commissioned in various parts of the world. The most popular are: load tap changers, phase angle regulators, static VAR compensators, thyristor-controlled series compensators, inter phase power controllers, static compensators, and unified power flow controllers. Providing the ability to control the flow of current can help the system operators to use the network resources more efficiently. State estimation and optimal power flow are such technique that

adjusts line flows, by monitoring the prevailing system conditions, to extract the unused capacity from the grid.

The objective of state estimation is to estimate the unknown network quantities, which can be voltage magnitudes, phase angles, etc., from the quantities that are easily measurable such as generator’s injected power, line reactance, transformer tap settings. [19, 20]

Optimal power flow simulations must be carried out every time the loading or the operating conditions on the network change. A central control and communication units are required to compute the new state of the system and adjust the control variables. Computational complexity and the requirement of an extensive communication capability make this approach difficult to implement for very large power networks

2.2 Types of FACTS Controllers




Figure 2-1 Types of FACTS controllers

FACTS devices change the system parameters, such as voltage magnitude, voltage angle, or the line reactance, to improve the transmission capacity and utilization of existing lines by controlling the flow of current through them.

Figure 2.2 shows a simple two bus system, with the associated parameters. The basic equation governing the flow of real and reactive power between the two buses/nodes is described by equations 2.1 and 2.2




Figure 2-2 Two Bus System

$$P_{12} = V_1 V_2 Z_s \cos(\theta_s - \delta) - \frac{V_2^2}{Z_s} \cos \theta_s \text{ Watt/Phase} \tag{2.1}$$

$$Q_{12} = \frac{V_1 V_2}{Z_s} \sin(\theta_s - \delta) - \frac{V_2^2}{Z_s} \sin \theta_s \text{ Watt/Phase} \tag{2.2}$$

P_{12} and Q_{12} : the flow of real and reactive power from Bus 1 to Bus 2,

V_1 and V_2 : the voltage magnitudes at the two buses,

δ : the phase difference between the voltages at the two buses,

$|Z_s|$: the absolute value of line impedance, and

θ_s : the angle of the line impedance

The equations can be further simplified if the line resistance (R) is neglected as shown in equations (2.3) and (2.4). This assumption holds true if the reactance of the line (X_L) is much greater than the resistance (R)

$$P_{12} = \frac{V_1 V_2}{X_L} \sin \delta$$
$$= \frac{V^2}{X_L} \sin \delta, \text{ if } |V_1| = |V_2| = |V| \quad (2.3)$$

$$Q_{12} = \frac{V_1 V_2}{X_L} \cos \delta - \frac{V_2^2}{X_S}$$
$$= \frac{V^2}{X_L} (\cos \delta - 1), \text{ if } |V_1| = |V_2| = |V| \quad (2.4)$$

Here X_L is the line reactance

The equation highlights that both the real and reactive power flows between any two buses can be controlled by changing the voltage magnitudes, voltage phase difference, or the reactive impedance of the line. All FACTS devices alter one or more of these system parameters to control the flow of power. Controlling the power flow by changing the different parameters is presented in the following sections.

Series controllers

The series controller could be variable impedance, such as capacitor, reactor, etc., or power electronics based variable source of main frequency, sub synchronous and harmonic frequencies to serve the desired need. In principle, all the series controllers inject voltage in series with the line. Even variable impedance multiplied by the current flow throughout, represents an injected series voltage in the line. As long as

the voltage is in phase quadrature with the line current, the series controller only supplies or consumes variable reactive power.

Shunt controllers

As in the case of series controllers, shunt controllers may be variable impedance, variable source or a combination of these. In principle all shunt controller inject current into the system. Even variable shunt impedance causes a variable current injection into the line. As long as injected current is in phase quadrature with the line voltage it supplies or consumes variable reactive power. Any other phase relationship will involve real power exchange also.

Combined Series – Series Controller

This could be a combination of separate series controllers, which are controlled in a coordinated manner, or it could be a unified controller. The series controllers could provide independent series reactive compensation but also could transfer real power among the lines via the power link (D.C link). The real power transfer capability of the unified series-series controller, referred to as interline power flow controller, makes it possible to balance both the real and reactive power flow in the lines. And there by maximize the utilization of the transmission system. Note that the term “unified” here means that the DC terminals of all controller converters are all connected together for real power transfer

Combined Series – Shunt Controller

This is a combination of series and shunt controllers which are controlled in a coordinated manner or a unified power flow controller with series and shunt elements. In principle combined shunt and series controller inject current in to the system with

the shunt part of the controller and voltage in series in the line with the series part of the controller. However, when the shunt and series controllers are unified, there can be a real power exchange between the series and shunt controllers via the power link.

2.3 Distributed Series Reactance

As adjusting the impedance and admittance of the transmission line is one method to control the Power flow, Distributed Series Reactor controller was first proposed as a D-FACTS device to fulfill this objective. Lines that is likely to see overloads at certain times of the day or under Defined contingency conditions can be modified with DSR modules to automatically control the line reactance and thus current flow.

The DSR adds reactance to the self-impedance (diagonal elements of the impedance matrix) of the line model [7]. The DSR addition affects the self-impedance of the line impedance matrix Z where Z_{ii} = self-impedance of phase i , and $i = A, B, C$. Z_{ij} = mutual impedance between phases i and j , and $i, j = A, B, C$.

The value of the reactance added depends on the number of DSR modules activated and the selected reactance for each DSR module [8].

Distributed Series Reactors has been developed by a vendor working initially with the Tennessee Valley Authority (TVA) and the Department of Energy Advanced Research Program Agency -Electric (ARPA-E) [12]. DSRs are clamped to phase conductors and powered by induction from the line current. A magnetic link allows the device to inject inductive reactance to increase line impedance. In a meshed transmission grid, increased impedance in one path results in transfer of power flow to other paths [8]. The distributed series reactor, shown in Figure 2.5 [9], consists of a split transformer hung from the conductor. The conductor forms the primary winding of the transformer. When the secondary winding is shorted, the unit operates in monitoring mode and negligible inductance is coupled in series with the line. When the secondary winding is opened, the magnetizing inductance of the transformer is coupled in series with the

line, and the unit operates in injection mode. While an individual device has a very small effect on the impedance of a line phase, adding numbers of them can change reactive impedance by several percent.




Figure 2 -3 Schematic Circuit of DSR [9]



Figure 2- 4 DSR connected to a transmission line [10]

DSR Installation

Fig. 2.6 shows a conceptual schematic of D-FACTS devices deployed on a power line to alter the power flow by changing the line impedance. Each module is rated at about 10 kVA and is clamped on the line, floating both electrically and mechanically. Each module can be controlled to increase or decrease the impedance of the line, or to leave

it unaltered. With a large number of modules operating together, it is possible to have a significant impact on the overall power flow in the line. The low volt ampere ratings of the modules are in line with mass manufactured power electronics systems in the industrial drives and uninterruptible power supply markets and suggests that it would be possible to realize extremely low cost. Finally, the use of a large number of modules results in high system reliability, as system operation is not compromised by the failure of a small number of modules.




Figure 2- 5 D-FACTS deployed on power line

Equation (2.5) shows how power flow varies with the line reactance. Control of real power flow on the line thus requires that the angle δ or the line impedance X_L be changed. A phase shifting transformer can be used to control the angle δ . This is an expensive non-scalable solution and provides limited dynamic control capability.

Alternatively, a single series compensator can be used to increase or decrease the effective reactive impedance X_L of the line, thus allowing control of real power flow between the two buses. The impedance change can be effected by series injection of a passive capacitive or inductive element in the line. Alternatively, a static inverter can also be used to realize a controllable active lossless element such as a negative or positive inductor or a synchronous fundamental voltage that is orthogonal to the line current

$$P_{12} = \frac{V_1 V_2 \sin \delta}{X_L} \quad (2.5)$$

Where V_1 and V_2 are the bus voltage magnitudes, δ is the voltage phase difference, and X_L is the line impedance. The concept of D-FACTS presents the highest potential to increase power flow and consequently the transfer capacity of a meshed transmission, sub transmission, and distribution network. In a meshed T&D network, the power transfer capacity of the system is constricted by the first line that reaches the thermal limit. The inability to effectively control power flow in such a network results in significant under-utilization of the overall system. D-FACTS devices offer the ability to improve the transfer capacity and grid utilization by routing power flow from overloaded lines to underutilized parts of the network. Capacitive compensation on underutilized lines would make them more receptive to the inflow of the current, while inductive compensation on overloaded lines would make them less attractive to current flow. In both cases, the throughput of the system is increased by diverting additional power flow from the congested parts of the network to the lines with available capacity.

Communication and Control

DSRs can be controlled in several ways. They can be pre-programmed to operate at a given current threshold, managed manually from an operating center in response to system conditions, or controlled automatically for more complex applications. Communications may be simply through one-way power line carrier, or two ways through cell phone circuits. Manual or automatic control is achieved as shown in Figure 2.7 through real-time communications. A Super DSR manages a set of proximate distributed series reactors and communicates with a DSR System Manager, which interfaces the entire fleet of DSRs with the energy management system (EMS). The central system manager allows configuring, monitoring and operating the DSRs as well as data archival. A DSR can provide line current, conductor temperature, fault location indication, fault current, ambient temperature, conductor vibration, conductor sag angle, and conductor blowout angle

When the DSR controller detects a fault, it returns the units to monitoring mode in less than 100microseconds to ensure that the DSRs do not interfere with existing protection schemes. To date, none of the DSR pilot deployments have required any changes to protection settings [11].

Applications include reliability improvement, delaying new line construction, reduction of congestion/ re-dispatch, simplification or removal of operating procedures, maintenance and construction outage support, phase balancing, and improved situational awareness




Figure 2-6 DSR communications

DSRs can be deployed to simplify or eliminate a remedial action scheme (RAS) or special protection scheme (SPS). In a study for a utility, a specific n-2 asset outage resulted in tripping generation and load with a RAS. Deploying DSRs on a number of

transmission lines simplified the RAS and eliminated 1200 megawatts (MW) of generation and load shedding.

Pilot Test

Distributed Series Reactors has been developed by a vendor working initially with the Tennessee Valley Authority (TVA) and the Department of Energy Advanced Research Program Agency -Electric (ARPA-E) [12].

The first pilot test included 100 units installed over 17 spans of a 21-mile 161 kV line owned by the Tennessee Valley Authority. Installations averaged approximately 10 minutes per unit, including wire brushing the conductor, installation of protector rods, and installation of an associated vibration damper [11].

2.4 DSR for Power Flow Controller

The concept of using a distributed series compensator to control the power flow has been suggested earlier [12]. A distributed series compensator is capable of providing the same control capability as that of conventional series FACTS devices but at high module reliability and lower cost. However, the technology is based on a voltage source inverter, implying a high dependency on power electronics and electrolytic capacitors. The current power electronics devices are generally not suited for use in the utility environment. The safe operating temperature range of the commercially available power electronic and control devices is between 80°C to 125°C, while the temperature extreme for power line conductors (100°C) can result in unsafe operating temperatures. Moving parts such as fans are not desirable making thermal management a major challenge as well. Further, the long-projected life (~30 years) suggests that dependence on electrolytic capacitors must be reduced. It is thus required to keep the power electronics at a minimal level to ensure a reliable system operation. Further, to realize the full control range of a distributed series compensator, a

communication interface is required. In particular, a capacitive voltage injection can only be induced on a line if local information about the Operating limits of other lines is made available to the controller. Communication adds another layer of cost and complexity and degrades the system reliability.

The distributed compensator was proposed with the objective of providing a continuous control range, which translates into varying the impedance of the entire line over a desired range. The proposed power flow controller is based on this idea and is introduced as a subcategory of Distributed FACTS devices. The injection of series VARS is made possible through injection of series impedance (inductor or a capacitor).

A Distributed Series Impedance (DSI) can control active power flow by realizing variable line impedance. The transfer capacity and consequently the grid utilization can be improved by routing the power flow from overloaded lines to underutilized parts of the network. Capacitive compensation on under-utilized lines makes them more receptive to the inflow of current, while inductive compensation on over-loaded lines makes them less attractive to current flow. In both the cases, the throughput of the system is increased by diverting additional power flow from the congested parts of the network to the lines with available capacity.

However, as in the case of DSSC, bidirectional control capability requires a communication interface to instruct the device to operate in the particular mode. Communication adds another layer of to the complexity network and can further delay the adoption of the technology. A desirable control objective would be to make the modules switch in or out at a predetermined point, thus eliminating the need for centralized control. This can be easily realized if the control is made unidirectional, and the amount of injection can be related to locally measured quantities, namely current and/or voltage. The particular case that exhibits this characteristic is that of purely inductive injection. This implementation, where the injected impedance can only increase the line impedance is referred to as the Distributed Series Reactance.

The control strategy is unidirectional and the devices can be made to operate autonomously based on the measured line current

Using distributed Series Reactance (DSR), at a system level, as the current in a particular line exceeds a predetermined value, increasing numbers of DSR modules are switched in, gradually increasing line impedance and diverting current to under-utilized lines. Pre-selected lines that are likely to see overload conditions at certain times of the day or under defined contingency conditions can be modified with DSR modules to automatically control the current flow.

Deployment of DSR modules on a power system can thus help to steer current from one part of the network to the other. The utilization of all the lines in the network can be gradually increased, bringing the system to its maximum power transfer capacity. Reliability of the system is also enhanced with the ability to share the overload between lines. A DSR system can not only restore a secure system operation under contingency conditions by diverting the excess current to other lines but can also improve the transmission capacity under such conditions. Thus, a self-healing network with controllable values can be obtained.

CHAPTER 3

ETHIOPIAN GRID TRANSMISSION SYSTEM AND DISTRIBUTED SERIES REACTANCE PLACEMENT

3.1 Introduction

In this section, the Ethiopian Electric Power grid has been assessed for its system overview for different voltage levels, installed equipment's for enhancing system performance, modeling of the transmission system in PSS/E for analysis of contingency results and investigation partial blackout the peak load of 2017. The placement of DSR on the transmission line identified through system load flow simulation.

Ethiopian National Grid System

The country is divided into 8 regional operation departments for the electricity network: Addis Ababa, Central region, Eastern region, Northern region, North-Eastern region, North-Western region, Southern region and Western region.

The Ethiopian Electric Power is the sole power utility in Ethiopia responsible for power generation, and transmission electrical energy all over the country. EEP supports the endeavors of the Federal Government of Ethiopia in promoting social and economic progress in all parts of the country.

The most salient policies promoted by EEP to meet its strategic goals are listed below:

- Fast development within the country of competitively priced and environmentally sustainable electricity generation projects
- Exploitation of indigenous energy sources (estimated Ethiopian hydro power potential ≥ 45 GW)
- Participation of the private sector in the above-mentioned developments

The cost allocation for generation, transmission, distribution and supply shown on Fig 3.1 for building these infrastructures is the following [1]:




Figure 3-1 cost allocation US\$M in 2016 money

System Overview

The total circuit lengths of transmission and sub-transmission lines on the existing system are shown in Table 3-1. EEP plans to phase out 45 kV in favor of 66 kV and also to replace some 66 kV lines with 132 kV. A map of the existing system and the planned transmission projects up to 2016 is shown in Figure 3-2 [28].

Table 3-1 Transmission and sub transmission lines on the existing system [1]

| No. | Voltage level (kV) | Single circuit | Double circuit | Total |
|--------------|--------------------------|----------------|----------------|---------------|
| 1 | 400 kV Transmission Line | 621 | 63 | 684 |
| 2 | 230 kV Transmission Line | 3,376 | 1,607 | 4,983 |
| 3 | 132 kV Transmission Line | 4,509 | 133 | 4,641 |
| 4 | 66 kV Transmission Line | 1,902 | | 1,902 |
| 5 | 45 kV Transmission Line | 243 | 9 | 252 |
| TOTAL | | 10,650 | 1,811 | 12,461 |

Reactive compensation is installed at various locations across the network on the system and includes shunt capacitors with a total capacity of approximately 200 MVAR and shunt reactors (both line and bus bar connected), with a total capacity of

approximately 700 MVar. In 2017, the peak generation (including Ethiopia peak demand, losses and exports) was 2078.9 MW.



Figure 3-2 existing and planned generation and transmission system

400kV Network

The 400-kV network is currently limited to a few transmission lines and substations. These include an interconnection between Gilgel Gibe II/ III power plants and SebetaII to Gelan substation in the south of Addis Ababa and an interconnection between Beles power plant, Bahir Dar, Sululta, Debremarkos and Geberguracha substation to the north of Addis Ababa.

230kV Network

The 230-kV network includes;

- A complete ring around Addis Ababa, including; Sululta, Gefersa, Sebeta kality and Cotobie II to Legetafo.
- Interconnections between Addis Ababa and power plants to the south east including Koka and Melka Wakena.
- Interconnection between Koka and Dire Dawa in the east, with interconnected to Djibouti.
- North-western corridor, including interconnection with Finchaa, Debre Markos, Tis-Abay and Beles power plants and interconnected to Sudan via Metema.
- Northern corridor including Combolcha, Alamata, Mekele and Tekeze power plant.
- A 230-kV transmission line between Bahir Dar and Alamata interconnects the north western and northern corridors

132kV, 66kV and 45 kV

The extent of the 132-kV network has been used extensively in the past for transmission, however in many parts of the network, due to extension of the 230-kV system, 132 kV is now effectively used more for sub-transmission along with 66 kV and 45 kV.

3.2 Ethiopian Grid System Modeling Using PSS/E

The model was developed by the Ethiopian Electric Power most closely refined to 2017 peak load.

Professional software package PSS/E (Power System Simulator for Engineering) is developed by Siemens PTI (Power Technologies International)

PSS/E is a comprehensive time-tested tool for performing power flow (including optimal power flow), short circuit, and transient stability simulation (including long term) of power system networks. The program, used by utility engineers and others worldwide for well over three decades, employs the latest numerical algorithms to efficiently solve networks with up to 150,000 buses with no loss of solution accuracy or computer time

The PSS/E-33 program package has a modern, easy-to-use, Microsoft Foundation Class (MFC), graphical user interface (GUI) for power flow as well as dynamic simulation. The GUI contains commands for recording capability which can be used to automate repetitive calculations.

User-switchable choice of five solution methods including Newton-Raphson (full, decoupled, fast decoupled), Gauss-Seidel, and modified Gauss-Seidel.

PSS/E is comprised of the following calculation modules:

- PSS/E Power Flow
- PSS/E Optimal Power Flow (PSS/E OPF)
- PSS/E Balanced or Unbalanced Fault Analysis
- PSS/E Dynamic Simulation

Module is basic PSS/E program module and it is powerful and easy-to use for basic power flow network analysis. Besides analysis tool this module is also used for Data handling, updating, and manipulation

PSS/E is not set up to solve any specific problem; rather, it is set of computational tools that are directed by the user in an interactive manner. By applying these tools in the appropriate sequence, the engineer can handle a wide range of investigations for the planning and operation of electric power systems.

Through the PSS/E interface the following functions and analyses are available:

- Power flow and related network functions
- Optimal power flow
- Open access
- Fault analysis
- Network equivalency
- Dynamic simulation
- One-line diagrams
- Program automation

Additionally, one of the most basic premises of PSS/E is that the engineer can derive the greatest benefit from computational tools by retaining intimate control over their application. IPLAN program language and or Python programs can be used within PSS/E for batch control and automation of the simulation processes

Overview of the PSS/E User Interface

The PSS/E interface supports a variety of interactive facilities including:

- Introduction, modification and deletion of network data using a spreadsheet.
- Creation of networks and one-line diagrams.
- Steady-state analyses (load flow, fault analysis, optimal power flow, etc.).
- Presentation of steady-state analysis results.
- Dynamic simulations (transient, dynamic and long-term stability analysis
- Presentation of Dynamic simulation results.

Once PSS/E opened, the key elements of the user interface are the Tree View, Spreadsheet View, Diagram View and the Output Bar, as pointed out in Figure 2.8




Figure 2 -7Key Elements of the Interface Tree View, Main Menu, Toolbars, Spreadsheet, View Output Bar Diagram, View Status Bar.

Spreadsheet View

All network data components (e.g., buses, lines, loads) are represented within worksheet style tabs on the spreadsheet. The spreadsheet, or workbook, is synchronized with the bus subsystem selector so that only a subset of the data may be

viewed at any time. New network elements may be entered or modified directly in the appropriate worksheet, or existing ones deleted. In the Spreadsheet View, standard Windows commands such as copy and paste actions are supported.

Sorting and filtering capabilities are provided to increase usability, especially with large systems. At program startup the Spreadsheet View is not shown. It will appear when a raw data or saved case file is opened. The Spreadsheet View is the default view for the interface and remains open once it is populated. It can be minimized, but if closed will remove the current network from PSS/EE.

In Figure 2.9, the Bus tab has been selected and the spreadsheet reflects the bus data records within the working case. Other data items may be viewed by clicking on the other tabs located at the bottom of the spreadsheet view.

| Bus Number | Bus Name | Base kV | Area Number/Name | Zone Number/Name | Owner Number/Name | Code | Voltage (pu) | Angle (deg) | G-I |
|------------|----------|---------|------------------|------------------|-------------------|------|--------------|-------------|-----|
| 101 | NUC-A | 21.6 | 1 FLAPCO | 77 PLANT | 11 GEN 1 | 2 | 1.0200 | 16.55 | |
| 102 | NUC-B | 21.6 | 1 FLAPCO | 77 PLANT | 11 GEN 1 | 2 | 1.0200 | 16.55 | |
| 151 | NUCPANT | 500.0 | 1 FLAPCO | 1 FIRST | 1 TRAN 1 | 1 | 1.0119 | 10.89 | |
| 152 | MID500 | 500.0 | 1 FLAPCO | 1 FIRST | 1 TRAN 1 | 1 | 1.0171 | -1.12 | |
| 153 | MID230 | 230.0 | 1 FLAPCO | 1 FIRST | 1 TRAN 1 | 1 | 0.9930 | -3.24 | |
| 154 | DOWNTN | 230.0 | 1 FLAPCO | 1 FIRST | 1 TRAN 1 | 1 | 0.9389 | -9.89 | |
| 201 | HYDRO | 500.0 | 2 LIGHTCO | 2 SECOND | 22 GEN 2 | 1 | 1.0400 | 6.16 | |
| 202 | EAST500 | 500.0 | 2 LIGHTCO | 2 SECOND | 2 TRAN 2 | 1 | 1.0088 | -1.32 | |
| 203 | EAST230 | 230.0 | 2 LIGHTCO | 2 SECOND | 2 TRAN 2 | 1 | 0.9665 | -6.92 | |
| 204 | SUB500 | 500.0 | 2 LIGHTCO | 2 SECOND | 2 TRAN 2 | 1 | 0.9787 | -3.73 | |
| 205 | SUB230 | 230.0 | 2 LIGHTCO | 2 SECOND | 2 TRAN 2 | 1 | 0.9490 | -9.18 | |
| 206 | URBGEN | 18.0 | 2 LIGHTCO | 2 SECOND | 22 GEN 2 | -2 | 1.0236 | -2.97 | |
| 211 | HYDRO_G | 20.0 | 2 LIGHTCO | 2 SECOND | 22 GEN 2 | 2 | 1.0404 | 12.92 | |
| 3001 | MINE | 230.0 | 5 WORLD | 5 FIFTH | 55 GEN 5 | 1 | 1.0298 | -1.37 | |
| 3002 | E. MINE | 500.0 | 5 WORLD | 5 FIFTH | 5 TRAN 5 | 1 | 1.0279 | -1.83 | |
| 3003 | S. MINE | 230.0 | 5 WORLD | 5 FIFTH | 5 TRAN 5 | 1 | 1.0233 | -2.25 | |
| 3004 | WEST | 500.0 | 5 WORLD | 5 FIFTH | 5 TRAN 5 | 1 | 1.0165 | -3.43 | |
| 3005 | WEST | 230.0 | 5 WORLD | 5 FIFTH | 5 TRAN 5 | 1 | 0.9948 | -5.18 | |
| 3006 | UPTOWN | 230.0 | 5 WORLD | 5 FIFTH | 5 TRAN 5 | 1 | 0.9940 | -3.79 | |

Figure 2- 8 Overview of the Spreadsheet View

Tree View

The Tree View provides a hierarchical, expandable and collapsible list view of the network, OPF, dynamics, model, and plot data in the system (as shown in Figure 2.10).

It is synchronized with the bus subsystem selector to enable the user to reduce the amount of data presented at any one time. The Tree View is also synchronized with the Spreadsheet and Diagram Views, reflecting their current content.




Figure 2 -9 Tree View (expandable form of network components)

Diagram View

The Diagram View is used to create, expand and display one-line diagrams of the electrical system (as shown in Figure 2.11). As new elements are added to the diagram, the Spreadsheet and Tree Views are automatically updated to reflect the addition

Additional diagram capabilities include the ability to view power flow, short-circuit analysis, reliability and dynamic simulation results. The Diagram View is not automatically opened. It is initiated by opening an existing one-line drawing file, or by starting a new diagram window.

The Diagram View can directly import old PSS/E DRAW files, which can then be saved to the new diagram Slider (SLD) format.




Figure 2- 10 Overview of Diagram View of a sample system

Given an existing PSS/E case, a one-line diagram may easily be built or expanded, bus by bus. This is accomplished by activating a Diagram View, right-clicking on an existing bus within the diagram or tree view and selecting Grow. All items connected to the selected bus are automatically drawn on the diagram. Simple mouse operations may then be used to rearrange elements on the diagram.

3.3 Model in PSS/E

EEP provided a PSS/E network model, which formed the basis of the analysis. The model was refined to more closely represent the network in 2017 peak load and the generation is 2078.9 MW (including the peak load, exports and the loss). The peak 2017 data's are line R in (pu), line X in (pu), charging B in (pu), ratings of A, B, and C phases in MVA and line lengths in km are listed in **Appendix B**.

Performance Evaluation of Existing Transmission System

Network analysis was conducted on the existing Ethiopian transmission system, to identify constraints and to develop a model which would provide the basis for the transmission expansion plan. In this section of the report we discuss the findings of the studies on the existing system and identify reinforcements required to support peak demand conditions across the network.

A summary of the assessment results is shown that 285 lines are monitored and during contingency analysis 12 lines are tripped, and a number of loads sheds done for corrective action are 12 lines with further details including summary of contingency analysis study results provided in **Appendix A**.

Load Flow Studies

The load flow plots may be found in **Appendix A**. Under maximum load, intact

network conditions, a number of transmission line and transformer overloads, VAR limits of the existing power generating stations, and peak load flow were found, and are listed in **Appendix C**.

In order to maximize a peak load flow, it was necessary to significantly reduce the overloaded lines and fully utilize the unused capacity of the 230kV and 400kV lines.

Numerous transformer overloads were found, mostly in the Addis Ababa region and these are listed in **Appendix C**. These will be addressed through replacement of existing transformers as required and through transfer of load to new substations in certain cases. Voltages below and above the planning limits were found on the bus bars listed in **Appendix D**.

Contingency Analysis

The transmission system currently carries very little redundancy and therefore is generally unable to withstand line or transformer outages without loss of supply to part of the network. Many of the substations are supplied over single radial 132 kV and 230kV circuits and will of course lose supply completely on loss of that circuit. Even if two parallel lines exist on some parts of the area due to unbalanced transmission lines exist in the network, some lines are overloaded first and have an additional impact for cascade tripping. As the network is developed, it is assumed that supply to these substations will be improved such that N-1 security is achieved. Investigation of overloaded lines has to be carried due to sudden outages of units, lines and transformers and a remedial action has to be taken like alleviating overloaded lines by balancing the transmission lines and push more power from overloaded lines to those lines that have unused capacity. The existing system contingency analysis has attached on **Appendix A**.

3.4 Investigation of Partial Blackout of the System as of 2017

The partial system blackout occurred at around 06:11 on 04th Nov 2017 (SCADA time).

Immediately prior to the incident the system conditions were as follows:

Table 3- 2 Generation Dispatch

| No. | Power Station | Number Units on the System Available | Total Generation MW |
|------------|----------------------|---------------------------------------------|----------------------------|
| 1 | Beles HPP | 1,3 and 4 | 330 |
| 2 | Gilgele Gibe II HPP | 2,3 and 4 | 325 |
| 3 | Tekeze HPP | 1 and 3 | 142 |
| 4 | Fincha HPP | All | 120 |
| 5 | Gigle Gibe I HPP | All | 140 |
| 6 | Melkewakena HPP | 1 | 55 |
| 7 | Koka HPP | 1 | 15 |
| 8 | Awash II | 2 | 25 |

| | | | |
|------------------|------------------|-------------|---------|
| 9 | Awash III | 2 | 13 |
| 10 | Adama Wind II | All | 5.66 |
| 11 | Adama Wind I | All | 1.81 |
| 12 | Gilegla Gibe III | 1,4,5 and 6 | 613.55 |
| 13 | Ashegoda wind | All | 0.1 |
| Total Generation | | | 1786.12 |

Table 3-3 Interconnection Transfer

| Interconnection | Transfer MW |
|-----------------|-------------|
| Sudan | 157 |
| Djibouti | 54.66 |

Preliminary Grid Disturbance Report:

- Type of Grid disturbance is type C (More than 80% of the grid affected)
- Affected Area: Except North West region all areas were affected

- Plant and/or Equipment directly involved: Except Beles power plant and North West region all power Plants and Substations were involved.

Immediately prior to the grid affected the following circuit was out of service;

- Bahir Dar – Mota 230kV by Earth fault

The sequence of events provided by the Transmission System Operator

Table 3-4 Sequence of Events

| Time | Circuit /Generator Tripping | Effect |
|-------------|------------------------------------|-----------------------------------------|
| 06:13 | Bahir dar - Alamata -230 kV line | Over current |
| 06:14 | Beles HPP | Reverse Power |
| 06:15 | MelkaWakena HPP | Over current/Overloaded |
| 06:15 | Koka HPP | Over current |
| 06:15 | Awash III HPP | Over Current |
| 06:15 | Awash II HPP | Over current |
| 06:17 | All Tekeze Generation | Over Frequency Trip |
| 06:17 | W/sodoll – Gelan 400kv line | Thought to be the cause of the blackout |

| | | |
|-------|-------------------------------------------|---------------------|
| 06:18 | GG III | Over Frequency Trip |
| 06:18 | Adama wind II | Voltage loss |
| 06:20 | Adama Wind I | Voltage loss |
| 06:51 | GGII HPP | Over Frequency Trip |
| 06:51 | Gelan – Kaliti I 230kv linr I and line II | Unknown |
| 06:52 | GGI HPP | Over Frequency Trip |
| 06:54 | Ashegoda wind | Loss of Voltage |
| 06:56 | Fincha HPP | Over Frequency Trip |

The existing system assessment showed that:

- Tripping of Bahir dar - Mota 230kv line also caused to trip Bahir dar – Alamata 230kv line with over current which isolate Beles from the grid at the same time
- The grid is weak does not fulfill the N-1 criteria during contingencies [1].
- There are overloaded lines and transformers during peak time certain times of a day and during contingencies.
- Poor protection coordination systems.
- A review has to be carried out under frequency load shedding.

- The grid peak demand serves approximately 2079MW (60% in Addis Ababa) [1]
- Mostly radial lines with limited interconnection.
- 230 kV and 132 kV are the most extensively used in the network
- 230 kV interconnectors to Djibouti and Sudan with limited capacity

Generally speaking, when line is overloaded EEP operators follow the traditional way of shedding loads automatically and manually to save the system from contingencies and blackout and partial blackout following cascade tripping of the system parameters.

EEP solving the overloaded lines problems by constructing new transmission lines instead of using FACTS devise to alleviate overloads and delay investment costs.

On this study uses DSRs on overloaded lines due to peak load at certain time of the day by identifying after load flow analysis. Distributed series reactors can be used to increase the capacity of a transmission system by moving flow from heavily loaded lines to lines that are in parallel and which have unused capacity.

3.5 DSRs Placement to Improve the Performance of Transmission System

The line overloads were all in shown one the Table 3.5 peak load flow of 2017 and it shows loading above from its ratings.

Table 3-5loading above its ratings

| X----- FROM BUS -----X X----- TO BUS -----X | | | | | | | | | |
|---------------------------------------------|----------------------|------|--------|--------------------|------|-----|----------------|--------------------|--|
| BUS# | X----NAME----X BASKV | AREA | BUS# | X-- NAME --X BASKV | AREA | CKT | LOADING IN MVA | RATING SET A (MVA) | |
| 112001 | ADDIS CENTER 132 | 12 | 112005 | KALITI1 132 | 12 | 1 | 85.6 | 82 | |
| 112009 | MEKANISA 132 | 12 | 114002 | SEBATA -I 132 | 14 | 1 | 95 | 82 | |
| 113002 | ALABA 132 | 13 | 113009 | SHASHEMENE 132 | 13 | 1 | 106.5 | 89 | |
| 113002 | ALABA 132 | 13 | 113012 | W SODO-II 132 | 13 | 1 | 112 | 89 | |

| | | | | | | | | |
|--------|-----------|----|--------|----------------|----|---|------|----|
| 113003 | AWASA 132 | 13 | 113009 | SHASHEMENE 132 | 13 | 1 | 88.1 | 82 |
|--------|-----------|----|--------|----------------|----|---|------|----|

Here have seen clearly on Figure 3.3 during peak time of 2017 the system with a generation of 2079 MW (including peak loads, exports and loss) are shown here:




Figure 3- 3 loading above its ratings

Following DSRs operating flow chart as showed in Fig 1.1 the maximum peak load overloading lines more than its ratings are listed above. Addis Center – Kality 132kV line is a radial line and omitted putting DSRs on it. Mekanisa- Sebta I 132kV line has connected branch only Sebta I- Gefersa 230 kV line and not include the highest voltage level of the system (400kV lines). Alaba –Shashemene and Awasa – Shashemene have nodes of connecting branches of 132kV transmission lines and have same impedance and overloading capability. The only line, Alaba –Wolyta SodoII 132kV, has the highest overloading among them. In addition to this, the node is connected with the highest voltage level of the system 400kV Wolyta Sodo II-Gilgle Gibe II and which is connected to the main load center of the capital city (which is 60% of the generation) [1]. For further reference please see the network diagram attached on **Appendix D**.

The flow shown on the Wolyta Sodo II node bus connected branches in MW and MVar, the bus voltage in KV and PU and the angle in degree. The node view shown in Fig 3-4




Figure 3- 4 Node View of Wolyta Sodo II

The DSR technology is based on increasing the impedance of a line, thereby pushing power flow from the line to other parallel paths. When a transmission line approaches its thermal rating, DSR modules may be activated to increase line impedance. This increases the power flow through parallel lines that may still have remaining capacity, more fully utilizing the capacity of the transmission system. The algorithm used here to place and operate DSRs is showed in Figure 1.1

The DSRs has placed on the overloaded 132kV Alaba –Wolyta Sodo II line, has a thermal capacity of the line 809A.

For the 10KVA rated DSRs, the required impedance for the module will be:

$$R = S/I^2 \tag{3.1}$$

$$R = \frac{10,000}{809^2}$$

$$R = 0.01528\Omega$$

The DSR modules used for this study have an inductance of one module 0.05 mH/module (0.01528 Ω). The DSR Modules on transmission line has been deployed having its reactance value 20%, 30% and 50% of the Alaba- Wolyta Sodo II line. A dummy bus (WS2-ALA-DUM) inserted between Wolyta Sodo II and Alaba 132KV line. A dummy bus (WS2-ALA-DUM1) having its reactance value 20% of overloaded line is inserted between Wolyta Sodo II and WS2-ALA-DUM. A dummy bus (WS2-ALA-DUM2) having its reactance value 30% of overloaded line inserted between Wolyta Sodo II and WS2-ALA-DUM and a dummy bus (WS2-ALA-DUM3) having its reactance value 50% of overloaded line is inserted between Wolyta Sodo II and WS2-ALA-DUM. The placement of DSRs on the line shown on Figure 3.5 here:




Figure 3-5 Node View of Wolyta Sodo II for Placement of DSRs

Wolyta Sodo II-Alaba 132kV line parameters shown on the following Table 3.6

Table 3- 6 Line parameters

| Operating voltage(kV) | Loading Capacity(MVA) | Length of line (km) | R(ohm) | X(ohm) |
|-----------------------|-----------------------|---------------------|-----------|-----------|
| 132 | 89 | 61.81 | 13.887224 | 26.137918 |

As the overall control objective is to keep the lines from thermal overload, the control strategy is seen to be very simple. The control algorithm is given by the line a relation between line current and injected inductance, as shown in Figure 3.6 [7] and explained by equation (3.2). The same controller, but with different set points is located on each module.




Figure 3- 6 Relation between injected inductance and line current

$$L_{inj} = L_f \frac{(I-I_0)}{(I_{thermal}-I_0)} \quad (3.2)$$

Here L_{inj} is the required injection; L_f is the final value of inductance with all the DSR modules on the line active, I_0 is the threshold value of current, I is the line current, and $I_{thermal}$ is the thermal limit beyond which there is no injection.

The range for inductance injection (L_f) is 100% of the line reactance and it was determined by system simulation to assess worst case requirements of thermal overload.

CHAPTER 4

PERFORMANCE EVALUATION OF THE TRANSMISSION SYSTEM WITH DSRs AND COST BENEFIT ANALYSIS

4.1 Introduction

This chapter begins by describing the selection criteria for connected branches of Wolyta Sodo II- Alaba 132kV transmission lines. The aim is pushing more power to the high voltage level which is the 400kV and the 230 kV transmission lines connected to the node of overloaded line. Based on the structure of the Ethiopian grid network the effect of DSR could see on the nearby lines which is directly or indirectly connected to the overloaded line. The loading of these lines has been taken during the peak load of 2017. The following table 4.1 shows lines selected for analysis

Table 4- 1 Transmission lines selected for analysis

| X----- FROM BUS -----X X----- TO BUS -----X | | | | | | | | | | | |
|---------------------------------------------|-----------------|-------|------|--------|-----------------|-------|------|-----|------------------|-----------------|------------------|
| BUS# | X-- NAME --X | BASKV | AREA | BUS# | X-- NAME --X | BASKV | AREA | CKT | LOADING (MVA) | RATING (MVA) | PERCENT (MVA) |
| 113012 | W SODO-II | 132 | 13 | 113028 | W SODO-I | 132 | 13 | 1 | 27.6 | 89 | 31 |
| 413001 | WOLAYTA | 400 | 13 | 415001 | GI GIBE-2 | 400 | 15 | 1 | 409.4 | 1973 | 20.7 |
| 402002 | GELAN | 400 | 12 | 413001 | WOLAYTA | 400 | 13 | 1 | 527.5 | 1973 | 26.7 |
| 402002 | GELAN | 400 | 12 | 414001 | SEBETA-2 | 400 | 14 | 1 | 222.1 | 1973 | 11.3 |
| 212001 | KALITI1 | 230 | 12 | 212005 | GELAN | 230 | 12 | 1 | 49.3 | 331 | 14.9 |
| 112005 | KALITI1 | 132 | 12 | 112011 | GELAN | 132 | 12 | 1 | 110.4 | 115 | 96 |
| 211001 | KOKA | 230 | 11 | 212005 | GELAN | 230 | 12 | 1 | 118.5 | 331 | 35.8 |
| 402002 | GELAN | 400 | 12 | 414001 | SEBETA-2 | 400 | 14 | 1 | 222.1 | 1973 | 11.3 |
| 214001 | SEBATA-1 | 230 | 14 | 214002 | SEBETA-2 | 230 | 14 | 1 | 236.5 | 280 | 84.5 |
| 108003 | GEFERSA | 132 | 8 | 114002 | SEBATA -I | 132 | 14 | 1 | 19.5 | 82 | 23.8 |
| 112009 | MEKANISA | 132 | 12 | 114002 | SEBATA -I | 132 | 14 | 1 | 95 | 82 | 115.8 |
| 113002 | ALABA | 132 | 13 | 113008 | HOSAINA | 132 | 13 | 1 | 11.4 | 89 | 12.8 |
| 213005 | HOSAINA | 230 | 13 | 214003 | WOLKITE | 230 | 14 | 1 | 23.5 | 402 | 5.9 |
| 213004 | ALABA | 230 | 13 | 213005 | HOSAINA | 230 | 13 | 1 | 30.6 | 402 | 7.6 |
| 113008 | HOSAINA | 132 | 13 | 115005 | G.GIBE NEW | 132 | 15 | 1 | 24 | 89 | 27 |

The load flow simulations of the existing transmission system 400kV, 230kV and 132KV voltage levels without DSRs and with DSR are conducted. Analysis of the simulation result is also presented in item 4.4 on result analysis in regards to the capacity improvements of the lines. The load flow analysis is carried out using PSS/E software [13].

4.2 Simulation Studies of the Transmission System without DSR

The loads are considered the peak load of 2017, which is the generation of 2078.9 MW [28]. This operating point determines the maximum amount of power that can be transferred over the transmission lines without DSRs. The loading and ratings of the transmission lines capacity without DSRs connected to 132kV Wolyta Sodo II bus is shown in table 4.2 and Figure 4.1. It can be seen that the 132-kV line is about to reach its maximum capacity, while there is capacity still available on 230kv lines. On the other hand, shows that all the lines of the 400-kV line have available transmission capacity.

Table 4-2 Branches loading, Ratings and percentage without DSR

| BRANCHES NAMES | WIHOUT DSR | | |
|--------------------------------|--------------|-------------|----------------|
| | LOADING(MVA) | RATING(MVA) | PERCENTAGE (%) |
| W SODO-II 132kV-W SODO-I 132kV | 27.6 | 89 | 31 |
| WOLAYTA 400kV-GI GIBE-2 400kV | 409.4 | 1973 | 20.7 |
| GELAN 400kV-WOLAYTA 400kV | 527.5 | 1973 | 26.7 |
| GELAN 400kV-SEBETA-2 400kV | 222.1 | 1973 | 11.3 |
| KALITI1 230kV-GELAN 230kV | 49.3 | 331 | 14.9 |
| KALITI1 132kV-GELAN 132kV | 110.4 | 115 | 96 |
| KOKA 230kV-GELAN 230kV | 118.5 | 331 | 35.8 |
| GELAN 400kV-SEBETA-2 400kV | 222.1 | 1973 | 11.3 |
| SEBETA 1-230kV-SEBETA 2-230kV | 236.5 | 280 | 84.5 |
| GEFERSA 132kV-SEBETA 1-132kV | 19.5 | 82 | 23.8 |
| MEKANISA 132kV-SEBETA1-132kV | 95 | 82 | 115.8 |
| ALABA 132kV-HOSAINA 132kV | 11.4 | 89 | 12.8 |
| HOSAINA 230kV-WOLKITE 230kV | 23.5 | 402 | 5.9 |
| ALABA 230kV-HOSAINA230kV | 30.6 | 402 | 7.6 |
| HOSAINA 132kV-G.GIBE NEW 132kV | 24 | 89 | 27 |




Figure 4- 1 Line graphs for branches loading, ratings and percentage

The nearby branches connected to the overloaded line, Figure 4-1 shows the 400KV lines have average 82.5% unused capacity without DSRs. The 230KV lines have average 70.3% unused capacity without DSRs and the 132KV lines have an average unused capacity is 49% without DSRs.




Figure 4-2 Power flows on Branches without using DSRs

4.3 Simulation Studies of the Transmission System with DSRs

Placement of DSRs having its reactance value 20%, 30% and 50% of 132kV Alaba to Wolyta Sodo II line are operated on the three phases of the 132-kV line. As can be seen from Tables 4.3, 4.4 and 4.5, by increasing the reactance of the overloaded line by 20% (adding 342 DSRs rated at 10kVA, 0.01528Ω), by 30% (adding 513DSRs

rated at 10kVA, 0.01528Ω) and by 50% (adding 856DSRs rated at 10kVA, 0.01528Ω) across the three phases, the overload on the 132-kV Alaba - Wolyta Sodo II line can be removed and power flow is transferred to the parallel branches of 400kV and 230 kV line.

Table 4-3 Placement of DSR Having its Reactance Value 20% of 132kVAlaba – Wolyta Sodo II line

| X----- FROM BUS -----X X----- TO BUS -----X | | | | | | | | | | | |
|---------------------------------------------|--------------|-------|------|--------|--------------|-------|------|-----|---------------|-------------|------------|
| BUS# | X-- NAME --X | BASKV | AREA | BUS# | X-- NAME --X | BASKV | AREA | CKT | LOADING (MVA) | RATING(MVA) | PERCENT(%) |
| 113012 | W SODO-II | 132 | 13 | 113028 | W SODO-I | 132 | 13 | 1 | 27.6 | 89 | 31 |
| 413001 | WOLAYTA | 400 | 13 | 415001 | GI GIBE-2 | 400 | 15 | 1 | 484.9 | 1973 | 24.6 |
| 402002 | GELAN | 400 | 12 | 413001 | WOLAYTA | 400 | 13 | 1 | 566.3 | 1973 | 28.7 |
| 402002 | GELAN | 400 | 12 | 414001 | SEBETA-2 | 400 | 14 | 1 | 248.4 | 1973 | 12.6 |
| 212001 | KALITI1 | 230 | 12 | 212005 | GELAN | 230 | 12 | 1 | 44.7 | 331 | 13.5 |
| 112005 | KALITI1 | 132 | 12 | 112011 | GELAN | 132 | 12 | 1 | 115 | 115 | 100 |
| 211001 | KOKA | 230 | 11 | 212005 | GELAN | 230 | 12 | 1 | 130.2 | 331 | 39.3 |
| 402002 | GELAN | 400 | 12 | 414001 | SEBETA-2 | 400 | 14 | 1 | 248.4 | 1973 | 12.6 |
| 214001 | SEBATA-1 | 230 | 14 | 214002 | SEBETA-2 | 230 | 14 | 1 | 251.2 | 280 | 89.7 |
| 108003 | GEFERSA | 132 | 8 | 114002 | SEBATA -I | 132 | 14 | 1 | 18.9 | 82 | 23 |
| 112009 | MEKANISA | 132 | 12 | 114002 | SEBATA -I | 132 | 14 | 1 | 96.7 | 82 | 117.9 |
| 113002 | ALABA | 132 | 13 | 113008 | HOSAINA | 132 | 13 | 1 | 37.3 | 89 | 42 |
| 213005 | HOSAINA | 230 | 13 | 214003 | WOLKITE | 230 | 14 | 1 | 68.2 | 402 | 17 |
| 213004 | ALABA | 230 | 13 | 213005 | HOSAINA | 230 | 13 | 1 | 69.7 | 402 | 17.3 |
| 113008 | HOSAINA | 132 | 13 | 115005 | G.GIBE NEW | 132 | 15 | 1 | 48.1 | 89 | 54 |

Table 4- 4 Placement of DSR having its Reactance Value 30% of 132kVAlaba – Wolyta Sodo II line

| X----- FROM BUS -----X X----- TO BUS -----X | | | | | | | | | | | |
|---------------------------------------------|--------------|-------|------|--------|--------------|-------|------|-----|---------------|-------------|------------|
| BUS# | X-- NAME --X | BASKV | AREA | BUS# | X-- NAME --X | BASKV | AREA | CKT | LOADING (MVA) | RATING(MVA) | PERCENT(%) |
| 113012 | W SODO-II | 132 | 13 | 113028 | W SODO-I | 132 | 13 | 1 | 27.6 | 89 | 31 |
| 413001 | WOLAYTA | 400 | 13 | 415001 | GI GIBE-2 | 400 | 15 | 1 | 485.5 | 1973 | 24.6 |
| 402002 | GELAN | 400 | 12 | 413001 | WOLAYTA | 400 | 13 | 1 | 565.7 | 1973 | 28.7 |
| 402002 | GELAN | 400 | 12 | 414001 | SEBETA-2 | 400 | 14 | 1 | 248.4 | 1973 | 12.6 |
| 212001 | KALITI1 | 230 | 12 | 212005 | GELAN | 230 | 12 | 1 | 45.3 | 331 | 13.7 |
| 112005 | KALITI1 | 132 | 12 | 112011 | GELAN | 132 | 12 | 1 | 115.2 | 115 | 100.2 |
| 211001 | KOKA | 230 | 11 | 212005 | GELAN | 230 | 12 | 1 | 130.1 | 331 | 39.3 |
| 402002 | GELAN | 400 | 12 | 414001 | SEBETA-2 | 400 | 14 | 1 | 248.4 | 1973 | 12.6 |
| 214001 | SEBATA-1 | 230 | 14 | 214002 | SEBETA-2 | 230 | 14 | 1 | 250.6 | 280 | 89.5 |
| 108003 | GEFERSA | 132 | 8 | 114002 | SEBATA -I | 132 | 14 | 1 | 23.2 | 82 | 28.3 |
| 112009 | MEKANISA | 132 | 12 | 114002 | SEBATA -I | 132 | 14 | 1 | 98 | 82 | 119.5 |
| 113002 | ALABA | 132 | 13 | 113008 | HOSAINA | 132 | 13 | 1 | 37.3 | 89 | 41.9 |
| 213005 | HOSAINA | 230 | 13 | 214003 | WOLKITE | 230 | 14 | 1 | 68.1 | 402 | 16.9 |
| 213004 | ALABA | 230 | 13 | 213005 | HOSAINA | 230 | 13 | 1 | 69.6 | 402 | 17.3 |
| 113008 | HOSAINA | 132 | 13 | 115005 | G.GIBE NEW | 132 | 15 | 1 | 48 | 89 | 53.9 |

Table 4- 5 Placement of DSR having its Reactance Value 50% of 132kVAlaba – Wolyta Sodo II line

| X----- FROM BUS -----X X----- TO BUS -----X | | | | | | | | | | | |
|---------------------------------------------|--------------|-------|------|--------|--------------|-------|------|-----|---------------|-------------|------------|
| BUS# | X-- NAME --X | BASKV | AREA | BUS# | X-- NAME --X | BASKV | AREA | CKT | LOADING (MVA) | RATING(MVA) | PERCENT(%) |
| 113012 | W SODO-II | 132 | 13 | 113028 | W SODO-I | 132 | 13 | 1 | 27.6 | 89 | 31 |
| 413001 | WOLAYTA | 400 | 13 | 415001 | GI GIBE-2 | 400 | 15 | 1 | 486.1 | 1973 | 24.6 |
| 402002 | GELAN | 400 | 12 | 413001 | WOLAYTA | 400 | 13 | 1 | 565.1 | 1973 | 28.6 |
| 402002 | GELAN | 400 | 12 | 414001 | SEBETA-2 | 400 | 14 | 1 | 248.4 | 1973 | 12.6 |
| 212001 | KALITI1 | 230 | 12 | 212005 | GELAN | 230 | 12 | 1 | 45.9 | 331 | 13.9 |
| 112005 | KALITI1 | 132 | 12 | 112011 | GELAN | 132 | 12 | 1 | 115.4 | 115 | 100.4 |
| 211001 | KOKA | 230 | 11 | 212005 | GELAN | 230 | 12 | 1 | 130.1 | 331 | 39.3 |
| 402002 | GELAN | 400 | 12 | 414001 | SEBETA-2 | 400 | 14 | 1 | 248.4 | 1973 | 12.6 |
| 214001 | SEBATA-1 | 230 | 14 | 214002 | SEBETA-2 | 230 | 14 | 1 | 250.1 | 280 | 89.3 |
| 108003 | GEFERSA | 132 | 8 | 114002 | SEBATA -I | 132 | 14 | 1 | 31.9 | 82 | 38.9 |
| 112009 | MEKANISA | 132 | 12 | 114002 | SEBATA -I | 132 | 14 | 1 | 99.3 | 82 | 121.1 |
| 113002 | ALABA | 132 | 13 | 113008 | HOSAINA | 132 | 13 | 1 | 37.2 | 89 | 41.7 |
| 213005 | HOSAINA | 230 | 13 | 214003 | WOLKITE | 230 | 14 | 1 | 68.1 | 402 | 16.9 |
| 213004 | ALABA | 230 | 13 | 213005 | HOSAINA | 230 | 13 | 1 | 69.6 | 402 | 17.3 |
| 113008 | HOSAINA | 132 | 13 | 115005 | G.GIBE NEW | 132 | 15 | 1 | 47.9 | 89 | 53.8 |

Placement of DSRs having its reactance value 30% and 50% of the overloaded Alaba to Wolyta Sodo II line, the alternative passes which don't require DSRs previously for Kality 1 –Gelan 132kV and Mekanisa -Sebta 1 132kV lines getting a significant overload and requires additional placement of DSR to remove the overload and transfer the excess power to the 400kV and 230 kV line. Placement of DSRs having its reactance value 20 % (342 DSRs rated at 10kVA, 0.01528Ω) of the overloaded Alaba to Wolyta Sodo II line for alleviating the existing transmission line is enhanced the capacity for parallel branches for 400kV, 230kV and 132kV lines and moreover the overloading conditions is improved. The capacity improvement having its reactance value 20% of the overloaded line Alaba to Wolyta Sodo II is shown in the following Figure 4.3




Figure 4-3 Power Flow on Branches using DSRs

Calculations for number of DSRs modules to change line reactance by 1%

| | |
|--------------------------------------------|-----------|
| LINE VOLTAGE | 132KV |
| THERMAL CAPACITY | 106.8MVA |
| CURRENT CARRYING CAPACITY | 700A |
| # OF CONDUCTOR /DIAMETER (CM) | 2.54/2.54 |
| REACTANCE IN OHMS / KM | 0.42OHMS |
| REACTIVE VOLTAGE DROP /KM | 294V |
| 1% COMPENSATION/ KM | 2.94V |
| DSR KVA/KM-1% COMPENSATION | 2.38KVA |
| TOTAL 10KVA DSRs MODULE /KM/1%COMPENSATION | 0.238 |

Taking the 132 kV Alaba to Wolyta Sodo II overloaded line, it has seen that the reactive voltage drop is 294V/km at rated current corresponding to 0.42 ohms/km).A 1% change in the impedance thus requires an injection of 2.94 V/km, corresponding to a combined DSR rating of 2.38 kVA/km based on three phase injection. A variation of 20% in line impedance would thus need 47.6 kVA or 4.76 (~5) of the 10 kVA DSR modules/km or approximately 2 modules per conductor per km.

4.4 Analysis of Simulation Results

Power Flow

Figs. 4.4and 4.5shows the comparison of power flows without and with DSRs of having its reactance value 20% of Alaba to Wolyta Sodo II transmission line. Power flows over the 132kV, 230 kV and 400kV branches connected to the overloaded line are shown here.




Figure 4-4 Comparisons of Power Flows




Figure 4- 5 Comparisons of Power Flows

From the figure 3.3 it can be seen that when without DSRs placement to Alaba to Wolyta Sodo II transmission line, Kality to Gelan ,Gefersa to Sebta 1 and Alaba to Hosina 132-kV lines are going to be overloaded while there is still a huge transmission capacity available on Wolyta to Gibe 2 ,Gelan to Wolyta ,Gelan to Sebta I and Gelan to Sebta II 400 kV lines. By adding DSRs to Alaba to Wolyta Sodo II 132-kV line the power flow is shifted to the 400-kV lines. However, this method shifts power flow from all lines which are connected to 132-kV line. As a result, excess power is transferred from Alaba to Wolyta Sodo II 132kV transmission line to its connected branches of the 400kV and 230 kV transmission lines. The capacity enhancement due to placement of DSRs are presented on the following Figure 4.6




Figure 4-6 Changes in Power Flows by Adding DSRs

Voltage profile before and after DSRs Operation

This thesis is done keeping the voltage profile within the range of acceptable standard

limits. The following figure 4-7 shows the voltage profile before and after DSRs operation.




Figure 4-7 voltage profile after and before DSRs operation for branches connected to the overloaded lines

4.5 Cost Benefit Analysis of Using DSRs

In this section the economics approaches to DSR implementation is evaluated in terms of the cost of new transmission line construction. Based on the cost of construction of 132 kV line for 61.81km to enhance the power transfer capacity of the transmission system by 84.8% with the same power transfer capacity of the transmission system for the dollar worth of DSRs implementation is calculated [31]. DSRs are commercially sold with an estimated cost used in the work here of \$10,000 per module [29]. The cost of new transmission line construction for 132kV line pre-km is 181,924.46 USD/Km [30].

MVA flow increase over the 400-kV line for DSR operation is calculated as follows:

Cost of increase MVA flow

$$= \frac{\text{change in MVA flow due to DSRs on the lines}}{\text{The loading Capacity of the line}} \times (\text{Transmission line length} \times \text{Cost of transmission line per km})$$

$$\text{Cost of Increase MVA flow (400kV)} = \frac{(75.5+38.8+26.3+26.3)}{1975} 61.81\text{km} \times 0.2\text{M\$/km} \quad (4.1)$$

$$= 1.04\text{M\$}$$

MVA flow increase over the 230-kV line for DSR operation is calculated as follows:

$$\text{Cost of Increase MVA flow (230kV)} = \frac{(11.7+14.7+44.7+39.1)}{402} (61.81\text{km} \times 0.2\text{M\$/km}) \quad (4.2)$$

$$= 3.39\text{M\$}$$

MVA flow increase over the 132 kV line for DSR operation is calculated as follows:

$$\text{Cost of Increase MVA flow (132kV)} = \frac{(4.6+1.7+25.9+24.1)}{89} (61.81\text{km} \times 0.2\text{M\$/km}) \quad (4.3)$$

$$= 7.82\text{M\$}$$

Where 1975MVA, 402MVA and 89MVA are the loading capacity of 400, 230 and 132kV lines.

The total cost of increase MVA flow is the sum of equation (4.1), (4.2) and (4.3)

$$= 12.25\text{M\$} \quad (4.4)$$

To calculate the investment cost per DSR the cost of the MVA increase is divided by the number of DSRs giving

$$\begin{aligned} \text{Cost per DSR} &= \frac{12.25M\$}{333} && (4.5) \\ &= 36,787\$/\text{DSR} \end{aligned}$$

So, the cost for the 333 DSRs deployed for the overloaded line will be

$$333 \times \$10,000 = 3.33M\$ \quad (4.6)$$

Comparing this total cost of DSRs in (4.6) with that of building new lines in (4.4) it appears that the DSRs implementation reduced the cost by 27.18 % relative to the traditional approach of building new lines.

As per the Ethiopian Electric Utility the current price of electricity or electric tariff is at 0.27Cents (ETB) per kilowatt hour (kwh) [1]. The annual rate of return has been calculated using the future and present value:

$$\text{Future Value } (F) = \text{Present Value } (P)(1 + \text{Rate of return})^t \quad (4.7)$$

Where 't' is the time in years.

The investment cost of the DSRs to increase the MVA flow on a transmission line which is considered as the present value 3.33M\$ for the year 2018 and the future value after 2 years which is the year 2020 is 5.6M\$. The rate of return from equation (4.7) is:

$$\text{Rate of Return} = \left(\frac{F}{P}\right)^{\frac{1}{t}} - 1 \quad (4.8)$$

The rate of return is 30% and which is returned the investment cost within 3.4years.

CHAPTER 5

CONCLUSIONS, RECOMMENDATIONS AND FUTURE WORK

5.1 INTRODUCTION

Based on the results obtained through simulation studies of the existing Wolyta Sodo II – Alaba 132kV transmission line and the system using DSRs at appropriate locations, the following conclusions and recommendation are made in this chapter. Furthermore, suggestions for further investigations of this research are also presented at the end of the chapter.

5.2 CONCLUSIONS

Today's grid meets today's requirements, but new and different demands are driving the expansion and adaptation of the transmission grid and the evolution of its supporting institutions. Meanwhile, transmission infrastructure projects are facing several challenges. Some of these challenges include delayed construction due to sitting and permitting issues, congestion, and under-utilization of already existing transmission facilities.

One of the existing solutions and opportunities to improve transmission capacity is the deployment DSRs and its techniques that better utilize the existing network facilities and improves the capacity of the grid.

This work presents a conclusion on 132kV, 230kV and 400kV transmission system connected to the overloaded Wolyta Sodo II – Alaba 132kV line. The placement of DSRs having its reactance value 20% of overloaded line reactance enhances the capacity utilization of the transmission system by 84.8%.

A cost benefit analysis of DSRs for improving an overloaded Alaba to Wolyta Sodo II transmission line with construction of new line was presented. In the cost benefit

analysis, the study of the system with 61.81km the cost of new line construction for enhancing the power flow by 84.8% is 12.25M\$. The cost of implementation of DSRs enhancing the same capacity is 3.33M\$. Therefore, the savings become 8.92M\$.

DSRs implementation can reduce the cost by 27.18 % in managing capacity enhancement and can delay making investments in new line construction until capacity enhancement is proven to be true. Thus, a major value of DSRs is handling overloads and makes enhanced system operating conditions and is delaying larger investments.

5.3 RECOMNDATIONS

Based on the result analysis of this thesis work, it is strongly recommended that EEP has to implement DSRs on Alaba to Wolyta Sodo II transmission line to enhance the capacity of the transmission system on the existing grid, and EEP transmission planners have to incorporate such kind of studies rather only engaging construction of new transmission lines, as a result the company minimizes cost for budgeting a billion dollars for each year for new line construction.

The power company, EEP has to develop a data base and incorporate to their system for such kinds of research results for future reference during transmission planning which helps the company as well the country for efficiently use un utilized 400kV,230kV and 132kV transmission lines.

5.4 SUGGESTIONS OF FUTURE WORK

Gibe III starts generate power in full capacity, most of the transmission lines and transformers in the system getting overloaded. The loss of any transmission line results in overloading and partial blackout. For effective utilization of all the transmission system DSRs are given the promise for reliable and inexpensive power

flow control. Effective implementation of DSRs in our grid needs further studies on EEP transmission system.

1. In this thesis, basically have two modes of operation of DSRs have been considered for simulation studies. Further studies may be carried out to investigate the behavior of transient faults on EEP transmission system.
2. For implementation of DSRs during transient faults, the existing protection coordination scheme of EEP transmission system may be studied.

REFERNCES

- [1] EEP document, Review for Ethiopian Power System, volume 1for power system simulator study provided to consultant's page 4.
- [2] Onen A, Cheng D, Arghandeh R, et al. Smart model - based coordinated control based on feeder losses, energy consumption, and voltage violations. *ElectrPower Compo Syst.* 2013;41(16):1686–1696.
- [3] Alam M, Razzak M, Hasan M, Chowd hury A. Transmission capacity enhancement of east - west interconnectors using series - shunt compensation.2012 7th International Conference on Electrical & Computer Engineering(ICECE)20 - 22 Dec. 2012;579–582.
- [4] Ren Y, Piao Z. Theoretical research and simulation of series compensation technology of distribution line. *Electronic and Mechanical Engineering and Information Technology (EMEIT), 2011 International Conference, 12 August 2011, Volume 4*2094–2097.
- [5] Divan D, Johal H. Distributed FACTS—a new concept for realizing gridpower flow control. *IEEE Trans Power Electr.* 2007; 22(6):2253–2260.
- [6] The Electric Power Research Institute (EPRI), the utility arm of North American utilities (Hingorani and Gyugyi 2000).
- [7] H. Johal, "Distributed Series Reactance: A New Approach to Realize Grid Power Flow Control," School of Electrical and Computer Engineering, Georgia Institute of Technology, Dec. 2008.

- [8] S. Omran, R. Broadwater, J. Hambrick and M. Dilek, "DSR Design Fundamentals: Power Flow Control," in 2014 IEEE Power and Energy Society General Meeting, July 2014.
- [9] H.M. Merrill and F.C. Schwepe, "Bad Data Suppression in Power System Static State Estimation," in IEEE Transactions on Power Apparatus and Systems, vol.90, issue6, Sept.1973, pp.2718-2715.
- [10] <http://www.smartwires.com.Usedunder> fair use, 2015
- [11] I. Grant, F. Kreikebaum, J. Shultz, S. Omran and R. Broadwater, "Initial Field Trials of Distributed Series Reactors and Implications for Future Application," in CIGRE US National Committee 2014 Grid of the Future Symposium, 2014.
- [12] D. Divan, W. Brumsickle, R. Schneider, B. Kranz, R. Gascoigne, D. Bradshaw, M.Ingram and I. Grant, "A Distributed Static Series Compensator System for Realizing Active Power Flow Control on Existing Power Lines," IEEE Transactions on Power Delivery, vol. 22, no. 1, pp. 642,649, Jan. 2007.
- [13] H. Shaalan, J. Thompson, R. Broadwater and M. Ellis, "Distribution engineering tool features a flexible framework," Computer Applications in Power, IEEE, vol. 8, pp. 21-24,1995.
- [14] L. R. Feinauer, K. J. Russell and R. P. Broadwater, "Graph trace analysis and generic algorithms for interdependent reconfigurable system design and control," Naval Engineers Journal, vol. 120, pp. 29-40, 2008.
- [15] D. Cheng, D. Zhu, R. P. Broadwater and S. Lee, "A graph trace-based reliability analysis of electric power systems with time-varying loads and dependent failures," Electric Power Systems Research, vol. 79, pp. 1321-1328, 2009

- [16] D. Cheng, Y. Liang, D. Zhu and R. P. Broadwater, "Real-Time Power Electric System Modeling, Assessment and Reliability Prediction," Power Systems Conference and Exposition, 2009. PSCE'09. IEEE/PES, pp. 1-6, 2009
- [17] J. Hambrick and R. Broadwater, "Advantages of Integrated System Model-Based Control for Electrical Distribution System Automation," World Congress, pp. 6117-6120, 2011
- [18] K. Russell and R. Broadwater, "Model-based automated reconfiguration for fault isolation and restoration," in Innovative Smart Grid Technologies (ISGT), 2012 IEEE PES, 201
- [19] W.F. Tinney and C.E. Hart, "Power Flow Solution by Newton's Method," in IEEE Transactions on Power Apparatus and Systems, vol. 86, issue 11, Nov. 1976, pp.1449- 1460.
- [20] B. Stott and O. Alsac, "Fast Decoupled Load Flow", in IEEE Transactions on Power Apparatus and Systems, vol. 93, issue 3, May 1974, pp. 859- 869.
- [21] O.J.M. Smith, "Power System State Estimation," in IEEE Transactions on Power Apparatus and Systems, vol. 89, issue 3, March 1970, pp. 363- 379.
- [22] H.M. Merrill and F.C. Schweppe, "Bad Data Suppression in Power System Static State Estimation," in IEEE Transactions on Power Apparatus and Systems, vol. 90, issue 6, Sept. 1973, pp. 2718- 2715.
- [23] L. Gyugyi, "Power electronics in electric utilities: static VAR compensators," "Proceedings of the IEEE, vol. 76, no. 4, pp. 483-494, Apr 1988.
- [24] L. Gyugyi, "Dynamic compensation of AC transmission lines by solid-state synchronous voltage sources," IEEE Transactions on Power Delivery, vol. 9, no. 2, pp. 904-911, April1994.

- [25] Initial Field Trials of Distributed Series Reactors and Implications for Future Applications presented by BRUCE ROGERS, Director, Technology Innovation, TVA, CIGRE US National Committee 2014 Grid of the Future Symposium.
- [26] Shaimaa Omran^a, *, Robert Broadwater^b, Joshua Hambrick^c, Murat Dilek^c, Chifong Thomas^d, Frank Kreikebaum^d “Load growth and power flow control with DSRs: Balanced vs unbalanced transmission networks “Electrical power system research 145(2017)207-213
- [27] Ahmet Onen, Department of Electrical and Electronics Engineering, Abdullah Gul University, Kayseri, Turkey. Investigation of distributed series reactors in power system applications and its economic implementation. Research Article DOI DOI10.1002/etep/etep.2259 in 2016 2016
- [28] Ethiopian power system expansion master plan interim report overview volume 4; transmission planning page 2-2
- [29] AEP, “American Electric Power Transmission Facts. [Online]. Available: <http://www.aep.com/about/transmission/docs/transmission-facts.pdf>. Retrieved: Dec. 2016.
- [30] EEP Transmission Projects contract No. Co/33.20/077/00 dated Jan 31, 2017, for construction of HV Transmission Network Rehabilitation and Upgrading project, contract 3, volume 1, bill of quantities, page 1, and item 1.8
- [31] Feasibility of DSR applications in transmission grid operation—Control of power flow and imbalanced voltage by Mohammad Nawaf Nazir^a, *, Shaimaa Omran^a, Robert Broadwater^b, Electric Power System Research 131 (2016) 187-194

APPENDIX A: Summary of Contingency Analysis

Table A-1 Summary of N-1 Contingency

| | |
|------------------------------------------------|-------|
| Number of Monitored Branches | = 285 |
| Number of Monitored Interfaces | = 0 |
| Number of Contingencies Base Case | = 303 |
| Number of Voltage Monitored Buses | = 282 |
| Number of Voltage Monitored Records | = 1 |
| Number of Voltage Monitored Bus Records | = 282 |
| Number of Buses in the case | = 930 |
| Number of Loads shed due to post contingency | = 12 |
| Number of Loads shed due to tripping | = 12 |
| Number of Loads shed due to corrective actions | = 12 |

Table A-2 Monitored lines

| Monitored Lines | | | | | | |
|------------------------|--------------------------------|--------|--------------------|-----------|-----------|-----------|
| MON# | BRANCHES | | | RATE A | RATE B | RATE C |
| 1 | 101001 ADD EAST-II 132.00 1 | 132.00 | 101003 COTEBEI-I | 91 | 91 | 91 |
| 2 | 101001 ADD EAST-II 132.00 1 | 132.00 | 101012 ADDIS-NORTH | 91 | 91 | 91 |
| 3 | 101002 B.WGN-TP 132.00 1 | 132.00 | 101003 COTEBEI-I | 82 | 82 | 82 |
| 4 | 101002 B.WGN-TP 132.00 1 | 132.00 | 101005 WERGENU | 82 | 82 | 82 |

| | | | | | | | |
|----|-----------------------------------|----------|--------|-------------|-----|-----|-----|
| 5 | 101002 B.WGN-TP 132.00 1 | 132.00 | 101017 | KALITI1 | 82 | 82 | 82 |
| 6 | 101003 COTEBEI-I 132.00 1 | 132.00 | 101007 | ADDIS-E1 | 91 | 91 | 91 |
| 7 | 101003 COTEBEI-I 132.00 2 | 132.00 | 101007 | ADDIS-E1 | 91 | 91 | 91 |
| 8 | 101003 COTEBEI-I 132.00 1 | 132.00 | 101009 | AYAT | 82 | 82 | 82 |
| 9 | 101003 COTEBEI-I TP132.00 1 | 132.00 | 101010 | BOLE-LEMI | 82 | 82 | 82 |
| 10 | 101004 SULULTA-132 132.00 1 | 132.00 | 102036 | DANGOTE CEM | 115 | 115 | 115 |
| 11 | 101004 SULULTA-132 66.000 1 | 132.00 | 601001 | SULULTA | 25 | 25 | 25 |
| 12 | 101006 LEGETAFO 132.00 1 | 132.00 | 101009 | AYAT | 82 | 82 | 82 |
| 13 | 101006 LEGETAFO BERHAN132.00 1 | 132.00 | 102001 | DEBRE | 82 | 82 | 82 |
| 14 | 101010 BOLE-LEMI MB132.00 1 | TP132.00 | 101011 | BOLE-LEMI | 82 | 82 | 82 |
| 15 | 101010 BOLE-LEMI 132.00 1 | TP132.00 | 101020 | KLT.N-TP | 82 | 82 | 82 |
| 16 | 101012 ADDIS-NORTH 132.00 1 | 132.00 | 101014 | MINILIK TS | 82 | 82 | 82 |
| 17 | 101013 GEFERSA 132.00 1 | 132.00 | 101014 | MINILIK TS | 82 | 82 | 82 |
| 18 | 101013 GEFERSA 132.00 1 | 132.00 | 101017 | KALITI1 | 82 | 82 | 82 |
| 19 | 101013 GEFERSA 132.00 1 | 132.00 | 101028 | SEBATA -I | 82 | 82 | 82 |
| 20 | 101013 GEFERSA 132.00 1 | 132.00 | 102009 | HABESHA TP | 91 | 91 | 91 |
| 21 | 101015 ADDIS CENTER 132.00 1 | 132.00 | 101017 | KALITI1 | 82 | 82 | 82 |

| | | | | | | |
|----|--------------------------------|--------|-------------------|-----|-----|-----|
| 22 | 101016 GOFA 132.00 1 | 132.00 | 101021 MEKANISA | 91 | 91 | 91 |
| 23 | 101017 KALITI1 132.00 1 | 132.00 | 101019 KALITI TWO | 82 | 82 | 82 |
| 24 | 101017 KALITI1 132.00 1 | 132.00 | 101020 KLT.N-TP | 82 | 82 | 82 |
| 25 | 101017 KALITI1 132.00 1 | 132.00 | 101021 MEKANISA | 82 | 82 | 82 |
| 26 | 101017 KALITI1 132.00 1 | 132.00 | 101022 YESU | 115 | 115 | 115 |
| 27 | 101017 KALITI1 132.00 1 | 132.00 | 101023 GELAN | 115 | 115 | 402 |
| 28 | 101017 KALITI1 132.00 1 | 132.00 | 101024 INDODE TS | 115 | 115 | 115 |
| 29 | 101017 KALITI1 132.00 1 | 132.00 | 101027 KALITI GIS | 82 | 82 | 82 |
| 30 | 101018 KALTI-NORTH 132.00 1 | 132.00 | 101020 KLT.N-TP | 82 | 82 | 82 |
| 31 | 101019 KALITI TWO 132.00 1 | 132.00 | 101025 NEFASILK | 91 | 91 | 91 |
| 32 | 101019 KALITI TWO 132.00 1 | 132.00 | 101027 KALITI GIS | 91 | 91 | 91 |
| 33 | 101021 MEKANISA 132.00 1 | 132.00 | 101028 SEBATA -I | 82 | 82 | 82 |
| 34 | 101022 YESU 132.00 1 | 132.00 | 101023 GELAN | 115 | 115 | 115 |
| 35 | 101023 GELAN 132.00 1 | 132.00 | 101024 INDODE TS | 115 | 115 | 115 |
| 36 | 101023 GELAN 132.00 1 | 132.00 | 102017 ELALA-TP | 115 | 115 | 115 |
| 37 | 101023 GELAN 132.00 1 | 132.00 | 102035 DBZT2-TP | 115 | 115 | 115 |
| 38 | 101023 GELAN 132.00 1 | 132.00 | 102037 KNORIA TEX | 115 | 115 | 115 |

| | | | | | | |
|----|------------------------------------|--------|--------------------|-----|-----|-----|
| 39 | 101028 SEBATA -I 2132.00 2 | 132.00 | 101030 ADDIS WEST | 91 | 91 | 91 |
| 40 | 102001 DEBRE BERHAN 132.00 1 | 132.00 | 106004 SHOWA-ROBIT | 82 | 82 | 82 |
| 41 | 102003 DERBA-CEMENT 132.00 1 | 132.00 | 102006 DERBA-TAP | 91 | 91 | 91 |
| 42 | 102004 HORMAT 132.00 1 | 132.00 | 104005 GHEDO | 89 | 89 | 89 |
| 43 | 102005 MUGER 132.00 2 | 132.00 | 102038 DANGOTE TP | 91 | 91 | 91 |
| 44 | 102006 DERBA-TAP 132.00 1 | 132.00 | 102009 HABESHA TP | 91 | 91 | 91 |
| 45 | 102006 DERBA-TAP 132.00 1 | 132.00 | 102038 DANGOTE TP | 91 | 91 | 91 |
| 46 | 102008 HABESHA CEM 132.00 1 | 132.00 | 102009 HABESHA TP | 91 | 91 | 91 |
| 47 | 102010 AWASH-7KL 132.00 1 | 132.00 | 102020 METAHARA | 82 | 82 | 82 |
| 48 | 102010 AWASH-7KL 132.00 1 | 132.00 | 103001 ASEBETEFIR | 115 | 115 | 115 |
| 49 | 102010 AWASH-7KL OUNKUR132.00 1 | 132.00 | 103022 SIRBA | 115 | 115 | 115 |
| 50 | 102010 AWASH-7KL 132.00 1 | 132.00 | 103023 AWASH TS | 115 | 115 | 115 |
| 51 | 102012 ADAMI TULU 132.00 1 | 132.00 | 102013 ASSELA | 82 | 82 | 82 |
| 52 | 102012 ADAMI TULU 132.00 1 | 132.00 | 102040 BUTAJIRA | 91 | 91 | 91 |
| 53 | 102012 ADAMI TULU 132.00 1 | 132.00 | 105009 SHASHEMENE | 82 | 82 | 82 |
| 54 | 102013 ASSELA 132.00 1 | 132.00 | 102032 WON SUG TP | 82 | 82 | 82 |
| 55 | 102014 AWASH2 132.00 1 | 132.00 | 102015 AWASH-3 | 82 | 82 | 82 |

| | | | | | | |
|----|----------------------------------|--------|--------------------|-----|-----|-----|
| 56 | 102014 AWASH2 132.00 1 | 132.00 | 102018 KOKA | 82 | 82 | 82 |
| 57 | 102014 AWASH2 132.00 1 | 132.00 | 102022 WONJI-TP | 82 | 82 | 82 |
| 58 | 102014 AWASH2 132.00 1 | 132.00 | 102032 WON SUG TP | 82 | 82 | 82 |
| 59 | 102014 AWASH2 TS132.00 1 | 132.00 | 102042 WULENCHTI | 82 | 82 | 82 |
| 60 | 102016 ELALA-GEDA 132.00 1 | 132.00 | 102017 ELALA-TP | 82 | 82 | 82 |
| 61 | 102017 ELALA-TP 132.00 1 | 132.00 | 102018 KOKA | 82 | 82 | 82 |
| 62 | 102018 KOKA 132.00 1 | 132.00 | 102021 NAZRETH2 | 82 | 82 | 82 |
| 63 | 102018 KOKA 132.00 1 | 132.00 | 102022 WONJI-TP | 82 | 82 | 82 |
| 64 | 102018 KOKA 132.00 1 | 132.00 | 102031 MOJO II MOB | 115 | 115 | 115 |
| 65 | 102018 KOKA 132.00 1 | 132.00 | 102035 DBZT2-TP | 82 | 82 | 82 |
| 66 | 102020 METAHARA 132.00 1 | 132.00 | 102021 NAZRETH2 | 82 | 82 | 82 |
| 67 | 102020 METAHARA TS132.00 1 | 132.00 | 102029 MELKAJILO | 82 | 82 | 82 |
| 68 | 102021 NAZRETH2 132.00 1 | 132.00 | 102030 ADAM-I WIND | 82 | 82 | 82 |
| 69 | 102022 WONJI-TP 132.00 1 | 132.00 | 102024 WONJIPULP | 82 | 82 | 82 |
| 70 | 102023 M WAK-YUGO 132.00 1 | 132.00 | 105009 SHASHEMENE | 89 | 89 | 89 |
| 71 | 102023 M WAK-YUGO 132.00 1 | 132.00 | 105013 YADOT | 91 | 91 | 91 |
| 72 | 102025 METEHARA-TS TS132.00 1 | 132.00 | 102029 MELKAJILO | 115 | 115 | 115 |

| | | | | | | | |
|----|-----------------------------------|--------|--------------------|--|-----|-----|-----|
| 73 | 102025 METEHARA-TS 132.00 1 | 132.00 | 103023 AWASH TS | | 115 | 115 | 115 |
| 74 | 102026 MODJO TS TS132.00 1 | 132.00 | 102042 WULENCHTI | | 82 | 82 | 82 |
| 75 | 102031 MOJO II MOB 132.00 1 | 132.00 | 102037 KNORIA TEX | | 115 | 115 | 115 |
| 76 | 102032 WON SUG TP 132.00 1 | 132.00 | 102033 WON SUG | | 82 | 82 | 82 |
| 77 | 102034 DB-ZEIT2 132.00 1 | 132.00 | 102035 DBZT2-TP | | 82 | 82 | 82 |
| 78 | 103001 ASEBETEFIR 132.00 1 | 132.00 | 103014 AFDEM TS | | 115 | 115 | 115 |
| 79 | 103001 ASEBETEFIR 132.00 1 | 132.00 | 103025 MIESSO TS | | 402 | 402 | 402 |
| 80 | 103002 DIRE DAWA 1 132.00 1 | 132.00 | 103003 DIRE DAWA 3 | | 82 | 82 | 82 |
| 81 | 103002 DIRE DAWA 1 CEM132.00 1 | 132.00 | 103016 NATIONAL | | 82 | 82 | 82 |
| 82 | 103003 DIRE DAWA 3 132.00 1 | 132.00 | 103008 D.DAWA-2 | | 82 | 82 | 82 |
| 83 | 103003 DIRE DAWA 3 132.00 1 | 132.00 | 103009 D.DAW-DS | | 115 | 115 | 115 |
| 84 | 103005 FIK 132.00 1 | 132.00 | 103006 HARAR-3 | | 91 | 91 | 91 |
| 85 | 103006 HARAR-3 132.00 1 | 132.00 | 103008 D.DAWA-2 | | 115 | 115 | 115 |
| 86 | 103006 HARAR-3 132.00 1 | 132.00 | 103018 JIJIGA I | | 115 | 115 | 115 |
| 87 | 103007 HURSO 132.00 1 | 132.00 | 103015 GOTA | | 115 | 115 | 115 |
| 88 | 103014 AFDEM TS 132.00 1 | 132.00 | 103015 GOTA | | 115 | 115 | 115 |
| 89 | 103022 SIRBA OUNKUR 132.00 1 | 132.00 | 103025 MIESSO TS | | 115 | 115 | 115 |

| | | | | | | |
|-----|-------------------------------------|--------|-------------------|-----|-----|-----|
| 90 | 104001 ASSOSA 132.00 1 | 132.00 | 104003 MENDI | 63 | 63 | 63 |
| 91 | 104002 GHIMBI 132.00 1 | 132.00 | 104003 MENDI | 91 | 91 | 91 |
| 92 | 104002 GHIMBI 132.00 1 | 132.00 | 104008 NEKEMPTE | 89 | 89 | 89 |
| 93 | 104005 GHEDO 132.00 1 | 132.00 | 104008 NEKEMPTE | 89 | 89 | 89 |
| 94 | 104007 GIDA-AYANA 132.00 1 | 132.00 | 104008 NEKEMPTE | 91 | 91 | 91 |
| 95 | 104008 NEKEMPTE 132.00 1 | 132.00 | 108003 B.BEDELE | 91 | 91 | 91 |
| 96 | 105002 ARBA MINCH 132.00 1 | 132.00 | 105024 W SODO-I | 89 | 89 | 89 |
| 97 | 105003 ALABA 132.00 1 | 132.00 | 105008 HOSAINA | 89 | 89 | 89 |
| 98 | 105003 ALABA 132.00 1 | 132.00 | 105009 SHASHEMENE | 89 | 89 | 89 |
| 99 | 105003 ALABA MOBILE132.00 1 | 132.00 | 105025 AWASA | 82 | 82 | 82 |
| 100 | 105004 AWASA 132.00 1 | 132.00 | 105009 SHASHEMENE | 82 | 82 | 82 |
| 101 | 105004 AWASA 132.00 1 | 132.00 | 105014 YIRGALEM | 82 | 82 | 82 |
| 102 | 105005 BOCULUGUMA MARIAM132.00 1 | 132.00 | 105007 HAGER | 115 | 115 | 115 |
| 103 | 105006 DILLA MARIAM132.00 1 | 132.00 | 105007 HAGER | 91 | 91 | 91 |
| 104 | 105006 DILLA 132.00 1 | 132.00 | 105014 YIRGALEM | 91 | 91 | 91 |
| 105 | 105008 HOSAINA 132.00 1 | 132.00 | 108005 G.GIBE NEW | 89 | 89 | 89 |
| 106 | 105010 SAWLA 132.00 1 | 132.00 | 105017 KEY AFER | 115 | 115 | 115 |

| | | | | | | |
|-----|-----------------------------------|--------|--------------------|-----|-----|-----|
| 107 | 105010 SAWLA 132.00 1 | 132.00 | 105024 W SODO-I | 91 | 91 | 91 |
| 108 | 105011 SHAKISO 132.00 1 | 132.00 | 105014 YIRGALEM | 82 | 82 | 82 |
| 109 | 105012 W SODO-II 132.00 1 | 132.00 | 105024 W SODO-I | 89 | 89 | 89 |
| 110 | 105024 W SODO-I SODO66.000 1 | 132.00 | 605005 WOLAYTA | 25 | 25 | 25 |
| 111 | 106001 ALEM KETEMA 132.00 1 | 132.00 | 106002 AKISTA | 91 | 91 | 91 |
| 112 | 106002 AKISTA 132.00 1 | 132.00 | 106003 COMBOLCHA-I | 91 | 91 | 91 |
| 113 | 106003 COMBOLCHA-I III132.00 1 | 132.00 | 106005 COMBOLCHA-I | 91 | 91 | 91 |
| 114 | 106004 SHOWA-ROBIT 132.00 1 | 132.00 | 106006 KEMISSIE | 115 | 115 | 115 |
| 115 | 106005 COMBOLCHA-III 132.00 1 | 132.00 | 106006 KEMISSIE | 115 | 115 | 115 |
| 116 | 107001 B.DAR2 132.00 1 | 132.00 | 107002 T-ABAY2 | 91 | 91 | 91 |
| 117 | 107001 B.DAR2 132.00 2 | 132.00 | 107002 T-ABAY2 | 91 | 91 | 91 |
| 118 | 108001 ABA 132.00 1 | 132.00 | 108007 JIMMA NEW | 91 | 91 | 91 |
| 119 | 108002 AGARO 132.00 1 | 132.00 | 108003 B.BEDELE | 89 | 89 | 89 |
| 120 | 108003 B.BEDELE 230.00 1 | 132.00 | 208004 BEDELLE | 40 | 40 | 40 |
| 121 | 108004 BONGA 132.00 1 | 132.00 | 108008 MIZAN | 91 | 91 | 91 |
| 122 | 108004 BONGA 132.00 1 | 132.00 | 108009 JIMMA OLD | 91 | 91 | 91 |
| 123 | 108005 G.GIBE NEW 132.00 1 | 132.00 | 108006 GI GIBE-1 | 89 | 89 | 89 |

| | | | | | | |
|-----|--------------------------------|--------|--------------------|-----|-----|-----|
| 124 | 108007 JIMMA NEW 132.00 1 | 132.00 | 108009 JIMMA OLD | 91 | 91 | 91 |
| 125 | 109001 ADIGRAT 132.00 1 | 132.00 | 109008 WUKRO-TP | 89 | 89 | 89 |
| 126 | 109002 ADWA TP132.00 1 | 132.00 | 109012 ABIADI MB | 89 | 89 | 89 |
| 127 | 109004 MEKELE 132.00 1 | 132.00 | 109005 MESOBO | 89 | 89 | 89 |
| 128 | 109004 MEKELE 132.00 1 | 132.00 | 109008 WUKRO-TP | 89 | 89 | 89 |
| 129 | 109004 MEKELE TP132.00 1 | 132.00 | 109012 ABIADI MB | 89 | 89 | 89 |
| 130 | 109004 MEKELE 230.00 1 | 132.00 | 209004 MEKELE | 63 | 63 | 63 |
| 131 | 109007 WUKRO 132.00 1 | 132.00 | 109008 WUKRO-TP | 89 | 89 | 89 |
| 132 | 109012 ABIADI MB TP132.00 1 | 132.00 | 109013 ABIADI MB | 89 | 89 | 89 |
| 133 | 201001 LEGETAFO 230.00 1 | 230.00 | 201002 SULULTA | 402 | 402 | 402 |
| 134 | 201001 LEGETAFO 230.00 2 | 230.00 | 201002 SULULTA | 402 | 402 | 402 |
| 135 | 201001 LEGETAFO 230.00 1 | 230.00 | 201004 COTOBEI-I | 402 | 402 | 402 |
| 136 | 201001 LEGETAFO 230.00 2 | 230.00 | 201004 COTOBEI-I | 402 | 402 | 402 |
| 137 | 201001 LEGETAFO 230.00 1 | 230.00 | 201005 BOLEARABSTP | 402 | 402 | 402 |
| 138 | 201001 LEGETAFO 230.00 1 | 230.00 | 206001 COMBOL-II | 318 | 318 | 318 |
| 139 | 201002 SULULTA 230.00 1 | 230.00 | 201007 GEFERSA | 318 | 318 | 318 |
| 140 | 201002 SULULTA 230.00 2 | 230.00 | 201007 GEFERSA | 318 | 318 | 318 |

| | | | | | | |
|-----|--------------------------------|--------|--------------------|-----|-----|-----|
| 141 | 201002 SULULTA 230.00 2 | 230.00 | 202001 CHANCHO230 | 402 | 402 | 402 |
| 142 | 201005 BOLEARABSTP 230.00 1 | 230.00 | 201006 BOLE ARABSE | 402 | 402 | 402 |
| 143 | 201005 BOLEARABSTP 230.00 1 | 230.00 | 201009 KALITII1 | 402 | 402 | 402 |
| 144 | 201007 GEFERSA 230.00 1 | 230.00 | 201008 TORHAYILOCH | 402 | 402 | 402 |
| 145 | 201007 GEFERSA 230.00 1 | 230.00 | 204003 GHEDO | 280 | 280 | 280 |
| 146 | 201007 GEFERSA 230.00 3 | 230.00 | 204003 GHEDO | 402 | 402 | 402 |
| 147 | 201008 TORHAYILOCH 230.00 1 | 230.00 | 201011 SEBATA-1 | 402 | 402 | 402 |
| 148 | 201009 KALITII1 230.00 1 | 230.00 | 201010 GELAN | 331 | 331 | 331 |
| 149 | 201009 KALITII1 230.00 2 | 230.00 | 201010 GELAN | 331 | 331 | 331 |
| 150 | 201009 KALITII1 230.00 1 | 230.00 | 201011 SEBATA-1 | 274 | 274 | 274 |
| 151 | 201010 GELAN 230.00 1 | 230.00 | 201017 EIZ TAP 1 | 331 | 331 | 331 |
| 152 | 201010 GELAN 230.00 1 | 230.00 | 202011 KOKA | 331 | 331 | 331 |
| 153 | 201010 GELAN WND 2 1 | 230.00 | 3WNDTR GELAN3WT-1 | 500 | 0 | 0 |
| 154 | 201010 GELAN WND 2 2 | 230.00 | 3WNDTR GELAN3WT-2 | 500 | 0 | 0 |
| 155 | 201010 GELAN WND 2 3 | 230.00 | 3WNDTR GELAN3WT-3 | 500 | 0 | 0 |
| 156 | 201011 SEBATA-1 230.00 1 | 230.00 | 201012 SEBETA-2 | 280 | 280 | 280 |
| 157 | 201011 SEBATA-1 230.00 2 | 230.00 | 201012 SEBETA-2 | 280 | 280 | 280 |

| | | | | | | |
|-----|---------------------------------|--------|---------------------|-----|-----|-----|
| 158 | 201011 SEBATA-1 230.00 1 | 230.00 | 202020 WOLKITE | 402 | 402 | 402 |
| 159 | 201012 SEBETA-2 230.00 1 | 230.00 | 201016 SEBETA TS | 280 | 280 | 280 |
| 160 | 201012 SEBETA-2 230.00 2 | 230.00 | 201016 SEBETA TS | 280 | 280 | 280 |
| 161 | 201017 EIZ TAP 1 230.00 1 | 230.00 | 202011 KOKA | 274 | 274 | 274 |
| 162 | 202003 GEBRE-GURCHA 400.00 1 | 230.00 | 402001 GEBRE-GURCHA | 125 | 125 | 125 |
| 163 | 202003 GEBRE-GURCHA 400.00 2 | 230.00 | 402001 GEBRE-GURCHA | 125 | 125 | 125 |
| 164 | 202008 AWSH-7KL 230.00 1 | 230.00 | 202011 KOKA | 353 | 353 | 353 |
| 165 | 202008 AWSH-7KL 230.00 1 | 230.00 | 203002 DIRE DAWA3 | 353 | 353 | 353 |
| 166 | 202011 KOKA 230.00 1 | 230.00 | 202012 MELKA-WAKNA | 257 | 257 | 257 |
| 167 | 202011 KOKA 230.00 2 | 230.00 | 202012 MELKA-WAKNA | 257 | 257 | 257 |
| 168 | 202011 KOKA WF230.00 1 | 230.00 | 202015 ADAMA II | 402 | 402 | 402 |
| 169 | 202011 KOKA 230.00 1 | 230.00 | 203003 HURSO | 402 | 402 | 402 |
| 170 | 202011 KOKA 230.00 2 | 230.00 | 203003 HURSO | 402 | 402 | 402 |
| 171 | 202012 MELKA-WAKNA 230.00 1 | 230.00 | 202017 M WAK-YUGO | 257 | 257 | 257 |
| 172 | 202012 MELKA-WAKNA 230.00 1 | 230.00 | 205001 RAMO | 402 | 402 | 402 |
| 173 | 202020 WOLKITE 230.00 1 | 230.00 | 205003 HOSAINA | 402 | 402 | 402 |
| 174 | 202020 WOLKITE 230.00 1 | 230.00 | 208006 G.GIBE NEW | 280 | 280 | 280 |

| | | | | | | |
|-----|---------------------------------|--------|-------------------|-----|-----|-----|
| 175 | 203001 ADIGALA 230.00 1 | 230.00 | 203003 HURSO | 402 | 402 | 402 |
| 176 | 203001 ADIGALA 230.00 1 | 230.00 | 203009 ADIGALA-TS | 402 | 402 | 402 |
| 177 | 203001 ADIGALA 230.00 1 | 230.00 | 203014 MILO TS | 402 | 402 | 402 |
| 178 | 203002 DIRE DAWA3 230.00 1 | 230.00 | 203003 HURSO | 255 | 255 | 255 |
| 179 | 203002 DIRE DAWA3 230.00 2 | 230.00 | 203003 HURSO | 255 | 255 | 255 |
| 180 | 203003 HURSO 230.00 1 | 230.00 | 203013 HURSO TS | 402 | 402 | 402 |
| 181 | 203008 LONNIS TS 230.00 1 | 230.00 | 203013 HURSO TS | 402 | 402 | 402 |
| 182 | 203008 LONNIS TS 230.00 1 | 230.00 | 203014 MILO TS | 402 | 402 | 402 |
| 183 | 203009 ADIGALA-TS 230.00 1 | 230.00 | 203011 AYISHA TS | 402 | 402 | 402 |
| 184 | 203011 AYISHA TS 230.00 1 | 230.00 | 203012 DAWALE TS | 402 | 402 | 402 |
| 185 | 203015 GODE 230.00 1 | 230.00 | 205001 RAMO | 402 | 402 | 402 |
| 186 | 204001 FINCHA 230.00 1 | 230.00 | 204002 FINCHA-II | 318 | 318 | 318 |
| 187 | 204001 FINCHA 230.00 1 | 230.00 | 204003 GHEDO | 284 | 284 | 284 |
| 188 | 204001 FINCHA MARKOS230.00 1 | 230.00 | 207002 DEBRE- | 280 | 280 | 280 |
| 189 | 204002 FINCHA-II 230.00 1 | 230.00 | 204003 GHEDO | 318 | 318 | 318 |
| 190 | 204002 FINCHA-II 230.00 1 | 230.00 | 204004 NESHE | 318 | 318 | 318 |
| 191 | 204003 GHEDO 230.00 1 | 230.00 | 208006 G.GIBE NEW | 274 | 274 | 274 |

| | | | | | | |
|-----|----------------------------------|--------|--------------------|-----|-----|-----|
| 192 | 205002 ALABA 230.00 1 | 230.00 | 205003 HOSAINA | 402 | 402 | 402 |
| 193 | 206001 COMBOL-II 230.00 1 | 230.00 | 206008 WOLDIYA MOB | 318 | 318 | 318 |
| 194 | 206001 COMBOL-II 230.00 1 | 230.00 | 206011 SEMERA | 318 | 318 | 318 |
| 195 | 206008 WOLDIYA MOB 230.00 1 | 230.00 | 209001 ALAMATA | 318 | 318 | 318 |
| 196 | 206009 GASHENA 230.00 1 | 230.00 | 207003 GASHENA-TAP | 318 | 318 | 318 |
| 197 | 206010 DITCHETO 230.00 1 | 230.00 | 206011 SEMERA | 318 | 318 | 318 |
| 198 | 207001 BAHIR DAR2 230.00 1 | 230.00 | 207004 GONDAR 2 | 402 | 402 | 402 |
| 199 | 207001 BAHIR DAR2 230.00 2 | 230.00 | 207004 GONDAR 2 | 402 | 402 | 402 |
| 200 | 207001 BAHIR DAR2 230.00 1 | 230.00 | 207006 MOTA | 280 | 280 | 280 |
| 201 | 207001 BAHIR DAR2 TP230.00 1 | 230.00 | 207007 NIFAS MEW | 318 | 318 | 318 |
| 202 | 207002 DEBRE-MARKOS 230.00 1 | 230.00 | 207006 MOTA | 280 | 280 | 280 |
| 203 | 207003 GASHENA-TAP TP230.00 1 | 230.00 | 207007 NIFAS MEW | 318 | 318 | 318 |
| 204 | 207003 GASHENA-TAP 230.00 1 | 230.00 | 209001 ALAMATA | 318 | 318 | 318 |
| 205 | 207004 GONDAR 2 230.00 1 | 230.00 | 207005 METEMA | 318 | 318 | 318 |
| 206 | 207004 GONDAR 2 230.00 2 | 230.00 | 207005 METEMA | 402 | 402 | 402 |
| 207 | 207007 NIFAS MEW TP230.00 1 | 230.00 | 207008 N.MEWCHA | 318 | 318 | 318 |
| 208 | 208001 GAMBELA2 230.00 1 | 230.00 | 208002 METU | 402 | 402 | 402 |

| | | | | | | |
|-----|----------------------------------|--------|--------------------|------|------|------|
| 209 | 208002 METU 230.00 1 | 230.00 | 208004 BEDELLE | 318 | 318 | 318 |
| 210 | 208004 BEDELLE 230.00 1 | 230.00 | 208008 AGARO | 402 | 402 | 402 |
| 211 | 208005 GI GIBE-1 230.00 1 | 230.00 | 208006 G.GIBE NEW | 274 | 274 | 274 |
| 212 | 208005 GI GIBE-1 230.00 2 | 230.00 | 208006 G.GIBE NEW | 274 | 274 | 274 |
| 213 | 208006 G.GIBE NEW 230.00 1 | 230.00 | 208007 JIMMA NEW | 402 | 402 | 402 |
| 214 | 208007 JIMMA NEW 230.00 1 | 230.00 | 208008 AGARO | 402 | 402 | 402 |
| 215 | 209001 ALAMATA 230.00 1 | 230.00 | 209007 MEHONI | 318 | 0 | 0 |
| 216 | 209001 ALAMATA 230.00 1 | 230.00 | 209013 ASHEGODA WF | 402 | 402 | 402 |
| 217 | 209002 ENDASILASIE 230.00 1 | 230.00 | 209003 HUMERA | 318 | 318 | 318 |
| 218 | 209002 ENDASILASIE 230.00 1 | 230.00 | 209006 TEKEZE | 318 | 318 | 318 |
| 219 | 209004 MEKELE 230.00 1 | 230.00 | 209006 TEKEZE | 318 | 318 | 318 |
| 220 | 209004 MEKELE 230.00 2 | 230.00 | 209006 TEKEZE | 318 | 318 | 318 |
| 221 | 209004 MEKELE 230.00 1 | 230.00 | 209007 MEHONI | 402 | 402 | 402 |
| 222 | 209004 MEKELE 230.00 1 | 230.00 | 209013 ASHEGODA WF | 402 | 402 | 402 |
| 223 | 401001 SULULTA GURCHA400.00 1 | 400.00 | 402001 GEBRE- | 1341 | 1341 | 1341 |
| 224 | 401001 SULULTA MARKOS400.00 1 | 400.00 | 407003 DEBRE | 1341 | 1341 | 1341 |
| 225 | 401002 GELAN 400.00 1 | 400.00 | 401003 SEBETA-2 | 1973 | 1973 | 1973 |

| | | | | | | |
|-----|--------------------------------------|--------|--------------------|------|-------|------|
| 226 | 401002 GELAN 400.00 1 | 400.00 | 405001 WOLAYTA 400 | 1973 | 1973 | 1973 |
| 227 | 401002 GELAN WND 1 1 | 400.00 | 3WNDTR GELAN3WT-1 | 500 | 0 | 0 |
| 228 | 401002 GELAN WND 1 2 | 400.00 | 3WNDTR GELAN3WT-2 | 500 | 0 | 0 |
| 229 | 401002 GELAN WND 1 3 | 400.00 | 3WNDTR GELAN3WT-3 | 500 | 0 | 0 |
| 230 | 401003 SEBETA-2 400.00 1 | 400.00 | 402004 HOLETA-400 | 1205 | 1205 | 1205 |
| 231 | 401003 SEBETA-2 400.00 2 | 400.00 | 402004 HOLETA-400 | 1205 | 1205 | 1205 |
| 232 | 401003 SEBETA-2 400.00 1 | 400.00 | 408001 GI GIBE-2 | 1341 | 1341 | 1341 |
| 233 | 404001 GRAN RENAISSANCE 400.00 1 | 400.00 | 407002 BELES | 543 | 533 | 543 |
| 234 | 405001 WOLAYTA 400 400.00 1 | 400.00 | 405004 G-GIBE3 | 1973 | 1973 | 1973 |
| 235 | 405001 WOLAYTA 400 400.00 2 | 400.00 | 405004 G-GIBE3 | 1973 | 1973 | 1973 |
| 236 | 405001 WOLAYTA 400 400.00 1 | 400.00 | 408001 GI GIBE-2 | 1973 | 19793 | 1973 |
| 237 | 407001 BAHIRDAR-II 400.00 1 | 400.00 | 407002 BELES | 1341 | 1341 | 1341 |
| 238 | 407001 BAHIRDAR-II MARKOS400.00 1 | 400.00 | 407003 DEBRE | 1341 | 1341 | 1341 |
| 239 | 408001 GI GIBE-2 400.00 1 | 400.00 | 408002 G.GIBE NEW | 1341 | 1341 | 1341 |

APPENDIX B: Peak Load 2017 Data's

Table B-1 Load Data's

| Bus Number | Bus Name | Area Name | Zone Name | Pload (MW) | Qload (Mvar) |
|------------|--------------------|--------------|--------------|------------|--------------|
| 101001 | ASSOSA 132.00 | ASOSA | BENSHANGUL-G | 2.465 | 1.194 |
| 101002 | GHIMBI 132.00 | ASOSA | OROMIA | 0 | 0 |
| 101004 | TULUCAPIGOLD132.00 | ASOSA | OROMIA | 1.9571 | 0.9479 |
| 102004 | D.BERHAN 132.00 | EASTERN A.A. | AMHARA | 1.825 | 0.8839 |
| 102005 | SULULTA-132 132.00 | EASTERN A.A. | OROMIA | 13.1781 | 6.3824 |
| 102007 | COTOBI-II 132.00 | EASTERN A.A. | ADDIS ABABA | 4.8748 | 2.361 |
| 102007 | COTOBI-II 132.00 | EASTERN A.A. | ADDIS ABABA | 26.7472 | 12.9543 |
| 102009 | CHANCHO 132.00 | EASTERN A.A. | OROMIA | 10.3222 | 4.9993 |
| 102013 | SHOAXING-LI 132.00 | EASTERN A.A. | ADDIS ABABA | 11.1226 | 2.8956 |
| 102014 | MSP-STEEL 132.00 | EASTERN A.A. | ADDIS ABABA | 15.5119 | 7.5146 |
| 103001 | ASEBETEFIR 132.00 | EASTERN | OROMIA | 0.0467 | 0.0226 |
| 103002 | D.DAWA-1 132.00 | EASTERN | DIRE DAWA | 0.0205 | 0.0099 |
| 103007 | HURSO 132.00 | EASTERN | OROMIA | 0 | 0 |
| 103008 | D.DAWA-2 132.00 | EASTERN | DIRE DAWA | 38.706 | 18.7462 |
| 103009 | D.DAW-DS 132.00 | EASTERN | DIRE DAWA | 0.0766 | 0.0371 |

| | | | | | |
|--------|------------------|-----------------|-----------|---------|--------|
| 103010 | D.DAWA-TS 132.00 | EASTERN | DIRE DAWA | 4.1365 | 2.0034 |
| 103013 | KEBRIDHER 132.00 | EASTERN | SOMALE | 0.5 | 0.242 |
| 103016 | AFDEM 132.00 | EASTERN | AMHARA | 4.1365 | 2.0034 |
| 103017 | BIKE 132.00 | EASTERN | AMHARA | 4.1365 | 2.0034 |
| 103019 | MEGALA 132.00 | EASTERN | AMHARA | 4.1365 | 2.0034 |
| 103020 | MIESO 132.00 | EASTERN | AMHARA | 4.1365 | 2.0034 |
| 105022 | BERKOT 132.00 | JIJIGA | SOMALE | 7.1782 | 3.4766 |
| 105024 | FAFEM 132.00 | JIJIGA | SOMALE | 7.1782 | 3.4766 |
| 106002 | AKSTA 132.00 | NORTH EASTER | AMHARA | 2.5094 | 1.2154 |
| 106005 | COMBOL-II 132.00 | NORTH EASTER | AMHARA | 0 | 0 |
| 106006 | KEMISSIE 132.00 | NORTH EASTER | AMHARA | 0 | 0 |
| 106007 | ZEMERO 132.00 | NORTH EASTER | AMHARA | 9.4908 | 4.5966 |
| 107001 | B.DAR2 132.00 | NORTH WESTER | AMHARA | 0 | 0 |
| 108004 | GHEDO 132.00 | NORTHERN A.A | OROMIA | 0 | 0 |
| 108005 | GUDER 132.00 | NORTHERN A.A | OROMIA | 0 | 0 |
| 108006 | MUGER 132.00 | NORTHERN A.A | OROMIA | 0.0766 | 0.0371 |
| 109002 | ADWA 132.00 | NORTHERN | TIGRAY | 0 | 0 |
| 109003 | ALAMATA 132.00 | NORTHERN | TIGRAY | 2.19 | 1.0607 |
| 109004 | MEKELE 132.00 | NORTHERN | TIGRAY | 11.8599 | 5.744 |
| 110001 | AWSH-7KL 132.00 | SEMERA | OROMIA | 10.9597 | 5.308 |
| 110003 | DK290 TS 132.00 | SEMERA | AFAR | 4.1365 | 2.0034 |

| | | | | | | |
|--------|-------------|--------|-----------------|-------------|---------|---------|
| 111001 | A.TULU | 132.00 | SOUTH EASTER | OROMIA | 0 | 0 |
| 111002 | ASSELA | 132.00 | SOUTH EASTER | OROMIA | 0 | 0 |
| 111003 | AWASH2 | 132.00 | SOUTH EASTER | OROMIA | 0.9498 | 0.46 |
| 111007 | KOKA | 132.00 | SOUTH EASTER | OROMIA | 3.1313 | 1.5166 |
| 111010 | METEHRATAP | 132.00 | SOUTH EASTER | OROMIA | 4.1365 | 2.0034 |
| 111016 | METEHARA-TS | 132.00 | SOUTH EASTER | OROMIA | 4.1365 | 2.0034 |
| 111018 | ABYSSINIAN | 132.00 | SOUTH EASTER | OROMIA | 9.63 | 4.66 |
| 112001 | A.CENTER | 132.00 | SOUTHERN A.A | ADDIS ABABA | 30.5063 | 14.7749 |
| 112005 | KALITI1 | 132.00 | SOUTHERN A.A | ADDIS ABABA | 4.8748 | 2.361 |
| 112009 | MEKANISA | 132.00 | SOUTHERN A.A | ADDIS ABABA | 14.0079 | 6.7843 |
| 112011 | AKAKI 2 | 132.00 | SOUTHERN A.A | ADDIS ABABA | 4.8927 | 2.3697 |
| 112013 | INDODE | 132.00 | SOUTHERN A.A | ADDIS ABABA | 4.1365 | 2.0034 |
| 113001 | A.MINCH | 132.00 | SOUTHERN | S.N.N.P | 6.2216 | 3.0132 |
| 113002 | ALABA | 132.00 | SOUTHERN | S.N.N.P | 0.2262 | 0.1096 |
| 113003 | AWASA | 132.00 | SOUTHERN | S.N.N.P | 1.6969 | 0.8218 |
| 113004 | BOCU LUGUMA | 132.00 | SOUTHERN | OROMIA | 0 | 0 |
| 113005 | DILLA | 132.00 | SOUTHERN | S.N.N.P | 0.1131 | 0.0548 |
| 113008 | HOSAINA | 132.00 | SOUTHERN | S.N.N.P | 0.1131 | 0.0548 |
| 113009 | S.SHEMEN | 132.00 | SOUTHERN | OROMIA | 4.697 | 2.2749 |

| | | | | | | |
|--------|--------------------|--------|-----------------|------------------|---------|---------|
| 113010 | SAWLA | 132.00 | SOUTHERN | S.N.N.P | 0.3394 | 0.1644 |
| 113011 | SHAKISO | 132.00 | SOUTHERN | OROMIA | 0 | 0 |
| 113012 | W.SODO | 132.00 | SOUTHERN | S.N.N.P | 1.9468 | 0.9429 |
| 113014 | YIRGALEM | 132.00 | SOUTHERN | S.N.N.P | 0.5657 | 0.274 |
| 113016 | YABELO | 132.00 | SOUTHERN | OROMIA | 0 | 0 |
| 114002 | SEBATA | 132.00 | WESTERN A.A. | ADDIS ABABA | 14.9052 | 7.2189 |
| 115002 | AGARO | 132.00 | WESTERN | OROMIA | 10 | 5 |
| 115003 | B.BEDELE | 132.00 | WESTERN | OROMIA | 0 | 0 |
| 115004 | BONGA | 132.00 | WESTERN | S.N.N.P | 0.1131 | 0.0548 |
| 115010 | NEKEMPTTE | 132.00 | WESTERN | OROMIA | 0 | 0 |
| 115011 | GIDAMI | 132.00 | ASOSA | BENSHANGUL- G | 1.056 | 0.512 |
| 115013 | ATANGO | 132.00 | WESTERN | OROMIA | 0 | 0 |
| 115014 | TUM | 132.00 | WESTERN | S.N.N.P | 0.6787 | 0.3287 |
| 202003 | CHANCHO230 | 230.00 | NORTHERN A.A | OROMIA | 34.2509 | 16.5885 |
| 202003 | CHANCHO230 | 230.00 | NORTHERN A.A | OROMIA | 3.257 | 1.5774 |
| 202005 | FITCHE 2 | 230.00 | EASTERN A.A. | OROMIA | 3.1705 | 1.5355 |
| 202008 | GEBRE-GURCHA230.00 | | EASTERN A.A. | OROMIA | 11.0959 | 5.374 |
| 203001 | ADIGALA | 230.00 | EASTERN | EXPORT | 0 | 0 |
| 203003 | DJIB-PK12 | 230.00 | ASOSA | EXPORT | 74.6869 | 37.3434 |
| 203006 | DIRE-IND-230230.00 | | EASTERN | DIRE DAWA | 0 | 0 |
| 203007 | LASARAT | 230.00 | EASTERN | SOMALE | 4.1365 | 2.0034 |
| 203008 | LONNIS | 230.00 | EASTERN | SOMALE | 4.1365 | 2.0034 |

| | | | | | |
|--------|--------------------|-----------------|--------|----------|---------|
| 203010 | MIESO 230.00 | EASTERN | AMHARA | 4.1365 | 2.0034 |
| 203011 | SHI-KUL-230 230.00 | EASTERN | SOMALE | 4.1365 | 2.0034 |
| 203012 | SUBURBAN 230.00 | EASTERN | OROMIA | 4.1365 | 2.0034 |
| 203013 | ADIGALA-TS 230.00 | EASTERN | EXPORT | 4.1365 | 2.0034 |
| 206002 | TOSAMETAL 230.00 | NORTH EASTER | OROMIA | 19.5709 | 9.4786 |
| 206004 | WOLDIA 230.00 | NORTH EASTER | AMHARA | 3.6501 | 1.7678 |
| 206004 | WOLDIA 230.00 | NORTH EASTER | AMHARA | 5.5111 | 2.6692 |
| 206005 | SUN-HI-GUL 230.00 | SEMERA | AFAR | 24.3223 | 11.7798 |
| 206006 | TERU 230.00 | SEMERA | AFAR | 8.1074 | 3.9266 |
| 207001 | B.DAR2 230.00 | NORTH WESTER | AMHARA | 2.19 | 1.0607 |
| 207003 | GASHENA 230.00 | NORTH WESTER | AMHARA | 0 | 0 |
| 207005 | GONDAR2 230.00 | NORTH WESTER | AMHARA | 7.6651 | 3.7124 |
| 207006 | METEMA 230.00 | NORTH WESTER | EXPORT | 180 | 90 |
| 207008 | N.MEW TP 230.00 | NORTH WESTER | AMHARA | 0 | 0 |
| 207009 | N.MEWCHA 230.00 | NORTH WESTER | AMHARA | 0.6844 | 0.3315 |
| 207010 | DEJEN 230.00 | NORTH WESTER | AMHARA | 0.6844 | 0.3315 |
| 207013 | SUDAN-GADARE230.00 | NORTH WESTER | EXPORT | 200.0001 | 97.1771 |
| 207013 | SUDAN-GADARE230.00 | NORTH WESTER | EXPORT | 180 | 87.177 |
| 207013 | SUDAN-GADARE230.00 | NORTH | EXPORT | 20 | 9.6863 |

| | | | | | | |
|--------|--------------------|--|--------------|--------------|----------|---------|
| | | | WESTER | | | |
| 208007 | GINCHI 230.00 | | NORTHERN A.A | OROMIA | 3.2618 | 1.5798 |
| 209002 | ENDASILA 230.00 | | NORTHERN | TIGRAY | 1.5728 | 0.7617 |
| 209004 | MEKELE 230.00 | | NORTHERN | TIGRAY | 0 | 0 |
| 209008 | DALOL 230.00 | | NORTHERN | AFAR | 5.4798 | 2.654 |
| 209009 | MEKELEPVC 230.00 | | NORTHERN | TIGRAY | 7.3065 | 3.5387 |
| 210002 | DITCHETO 230.00 | | SEMERA | AFAR | 0 | 0 |
| 210003 | SEMERA 230.00 | | SEMERA | AFAR | 0 | 0 |
| 211003 | MODJO3230 230.00 | | SOUTH EASTER | OROMIA | 16.1247 | 7.8096 |
| 211005 | NAZERET-ADAM230.00 | | SOUTH EASTER | OROMIA | 13.1777 | 6.3823 |
| 212002 | DUKEM230 230.00 | | SOUTHERN A.A | OROMIA | 46.6439 | 22.5907 |
| 212003 | DB-ZEIT3230 230.00 | | SOUTHERN A.A | OROMIA | 83.7242 | 40.5495 |
| 212003 | DB-ZEIT3230 230.00 | | SOUTHERN A.A | OROMIA | 41.0055 | 19.8599 |
| 212005 | AKAKI2-230 230.00 | | SOUTHERN A.A | ADDIS ABABA | 100.0001 | 50 |
| 213002 | RAMO 230.00 | | EASTERN | OROMIA | 1.0406 | 0.5037 |
| 213006 | GINIR 230.00 | | SOUTHERN | OROMIA | 0 | 0 |
| 215005 | JIMMA 230.00 | | WESTERN | OROMIA | 50 | 26 |
| 414001 | SEBETA-2 400.00 | | WESTERN A.A. | OROMIA | 200 | 100 |
| 507001 | GRAN RENAI5 500.00 | | NORTH WESTER | BENSHANGUL-G | 70 | 35 |
| 507003 | HOLETA-500 500.00 | | NORTHERN A.A | OROMIA | 23.6416 | 11.4502 |

| | | | | | |
|--------|--------------------|--------------|---------|---------|--------|
| 507003 | HOLETA-500 500.00 | NORTHERN A.A | OROMIA | 4.7384 | 2.2949 |
| 507006 | SUDAN-RABAK 500.00 | NORTH WESTER | EXPORT | 70 | 33.902 |
| 602002 | FITCHE 2 66.000 | EASTERN A.A. | OROMIA | 13.9593 | 6.7609 |
| 602002 | FITCHE 2 66.000 | EASTERN A.A. | OROMIA | 17.868 | 8.6539 |
| 603003 | BEDDESA 66.000 | EASTERN | OROMIA | 0.0167 | 0.008 |
| 603006 | HARAR1 66.000 | EASTERN | HARARI | 0 | 0 |
| 604002 | GAMBELA1 66.000 | GAMBELA | GAMBELA | 0.9525 | 0.4613 |
| 606003 | DESIE 66.000 | NORTH EASTER | AMHARA | 1.46 | 0.7071 |
| 606004 | LALIBELA 66.000 | NORTH EASTER | AMHARA | 1.5728 | 0.7617 |
| 606005 | SEKOTA 66.000 | NORTH EASTER | AMHARA | 1.5728 | 0.7617 |
| 607001 | B.DAR1 66.000 | NORTH WESTER | AMHARA | 13.0338 | 6.3125 |
| 607004 | DABAT 66.000 | NORTH WESTER | AMHARA | 1.3688 | 0.6629 |
| 607005 | DANGLA 66.000 | NORTH WESTER | AMHARA | 0 | 0 |
| 607007 | FNOT-SLM 66.000 | NORTH WESTER | AMHARA | 0.6844 | 0.3315 |
| 607008 | GONDAR2 66.000 | NORTH WESTER | AMHARA | 0 | 0 |
| 607011 | WORETA 66.000 | NORTH WESTER | AMHARA | 2.5164 | 1.2188 |
| 608004 | GEFERSA 66.000 | SOUTHERN | OROMIA | 0 | 0 |
| 609002 | ADWA 66.000 | NORTHERN | TIGRAY | 0 | 0 |

| | | | | | |
|--------|--------------------|-----------------|------------------|---------|---------|
| 609005 | SHIRE 66.000 | NORTHERN | TIGRAY | 0 | 0 |
| 611001 | BALEROBE 66.000 | SOUTH EASTER | OROMIA | 0 | 0 |
| 613001 | NEG-BORE 66.000 | SOUTHERN | OROMIA | 0 | 0 |
| 613003 | SHAKISO 66.000 | SOUTHERN | OROMIA | 0.274 | 0.1327 |
| 614003 | WOLKITE 66.000 | WESTERN A.A. | S.N.N.P | 2.0377 | 0.9869 |
| 615002 | TEPI 66.000 | WESTERN | S.N.N.P | 1.6057 | 0.7777 |
| 712002 | AKAKI 45.000 | SOUTHERN A.A | ADDIS ABABA | 1.3652 | 0.6612 |
| 712007 | KALITI1 45.000 | SOUTHERN A.A | ADDIS ABABA | 16.4189 | 7.9521 |
| 714002 | ADDIS-W2 45.000 | WESTERN A.A. | ADDIS ABABA | 16.6264 | 8.0426 |
| 801001 | ASSOSA 33.000 | ASOSA | BENSHANGUL- G | 1.1672 | 0.5653 |
| 801002 | GHIMBI 15.000 | ASOSA | OROMIA | 3.3683 | 1.6313 |
| 801003 | MENDI 33.000 | ASOSA | OROMIA | 2.8615 | 1.3858 |
| 801004 | ASSOSA 15.000 | ASOSA | BENSHANGUL- G | 2.7234 | 1.3191 |
| 802001 | ADDIS-E1 15.000 | EASTERN A.A. | ADDIS ABABA | 12 | 5.882 |
| 802002 | B.WRGENU 15.000 | EASTERN A.A. | ADDIS ABABA | 61.4667 | 29.7697 |
| 802005 | D.BERHAN 15.000 | EASTERN A.A. | AMHARA | 8.2854 | 4.0129 |
| 802008 | SULULTA-15 15.000 | EASTERN A.A. | OROMIA | 35.3638 | 17.1274 |
| 802009 | ADDIS-E2 15.000 | EASTERN A.A. | ADDIS ABABA | 58.0066 | 28.094 |
| 802010 | COTOBIE-15B215.000 | EASTERN | ADDIS ABABA | 41.9436 | 20.3142 |

| | | | | | |
|--------|--------------------|--------------|-------------|---------|---------|
| | | A.A. | | | |
| 802012 | SULULTA-33 33.000 | EASTERN A.A. | OROMIA | 3.7225 | 1.8029 |
| 802016 | BOLE-LEMI 33.000 | EASTERN A.A. | ADDIS ABABA | 9.7907 | 4.7418 |
| 802016 | BOLE-LEMI 33.000 | EASTERN A.A. | ADDIS ABABA | 33.5044 | 16.2269 |
| 802018 | FITCHE 2 15.000 | EASTERN A.A. | OROMIA | 7.0727 | 3.4255 |
| 802019 | SHEGOLE 15.000 | NORTHERN A.A | OROMIA | 13.1919 | 6.3891 |
| 802020 | DASHEN_BEER 33.000 | ASOSA | TIGRAY | 10 | 4.84 |
| 803001 | A.TEFERI 15.000 | EASTERN | OROMIA | 4.6685 | 2.2611 |
| 803002 | ADIGALA 33.000 | EASTERN | EXPORT | 0.2888 | 0.1398 |
| 803003 | ALEMAYA 15.000 | EASTERN | OROMIA | 5.5829 | 2.7039 |
| 803004 | ALEMAYA-33 33.000 | EASTERN | OROMIA | 2.9043 | 1.4066 |
| 803005 | ASEBE-33 33.000 | EASTERN | OROMIA | 0.0373 | 0.018 |
| 803006 | BABILE 15.000 | EASTERN | OROMIA | 1.7972 | 0.8704 |
| 803007 | BEDESSA 15.000 | EASTERN | OROMIA | 4.3025 | 2.0839 |
| 803008 | CHELENKO 15.000 | EASTERN | OROMIA | 3.8033 | 1.842 |
| 803009 | D.DAWA1- 15.000 | EASTERN | DIRE DAWA | 0 | 0 |
| 803010 | D.DAWA-2 15.000 | EASTERN | DIRE DAWA | 4.8722 | 2.3598 |
| 803011 | D.DAWA3 15.000 | EASTERN | DIRE DAWA | 3.3472 | 1.6212 |
| 803012 | FIK 33.000 | EASTERN | OROMIA | 0 | 0 |
| 803013 | HARAR 15.000 | EASTERN | HARARI | 5.3939 | 2.6124 |
| 803014 | HARAR3 33.000 | EASTERN | HARARI | 7.3401 | 3.5549 |
| 803017 | D.DAWA1- 15.000 | EASTERN | DIRE DAWA | 15.7109 | 7.6091 |
| 803018 | HARAR3 15.000 | EASTERN | HARARI | 4.805 | 2.3272 |

| | | | | | |
|--------|--------------------|-----------------|-----------|----------|---------|
| 803020 | SHI-KULEN IR33.000 | EASTERN | SOMALE | 24.6294 | 11.9286 |
| 803022 | DIRE-IND 33.000 | EASTERN | DIRE DAWA | 102.9624 | 49.867 |
| 804001 | DEMBI DO 15.000 | GAMBELA | OROMIA | 3.0639 | 1.484 |
| 804002 | GAMBELA1 15.000 | GAMBELA | GAMBELA | 2.4726 | 1.1975 |
| 804004 | METU 33.000 | GAMBELA | OROMIA | 0.8411 | 0.4073 |
| 804005 | SOR 15.000 | GAMBELA | OROMIA | 0 | 0 |
| 804006 | METU 15.000 | GAMBELA | OROMIA | 1.9036 | 0.922 |
| 805001 | JIJIGA 15.000 | JIJIGA | SOMALE | 0 | 0 |
| 805002 | JIJIGA2 33.000 | JIJIGA | SOMALE | 6.9642 | 3.3729 |
| 805003 | JIJIGA2 15.000 | JIJIGA | SOMALE | 10.1109 | 4.8969 |
| 806001 | A-KETEMA 33.000 | NORTH EASTER | AMHARA | 3.6823 | 1.7834 |
| 806002 | AKSTA 33.000 | NORTH EASTER | AMHARA | 9.6142 | 4.6564 |
| 806003 | COMBOL-1 15.000 | NORTH EASTER | AMHARA | 19.2133 | 9.3054 |
| 806004 | DESIE 15.000 | NORTH EASTER | AMHARA | 12.2432 | 5.9297 |
| 806005 | LALIBELA 15.000 | NORTH EASTER | AMHARA | 1.8376 | 0.89 |
| 806006 | SEKOTA 15.000 | NORTH EASTER | AMHARA | 1.5408 | 0.7463 |
| 806007 | SHWA-RBT 15.000 | NORTH EASTER | AMHARA | 3.7577 | 1.8199 |
| 806012 | COMBOLIND 33.000 | NORTH EASTER | AMHARA | 110.016 | 53.2832 |
| 807002 | B.DAR2-1 15.000 | NORTH WESTER | AMHARA | 15.0504 | 7.2893 |
| 807003 | BITCHENA 15.000 | NORTH WESTER | AMHARA | 4.7812 | 2.3156 |

| | | | | | | |
|--------|----------|--------|--------------|--------------|---------|---------|
| 807004 | DABAT | 15.000 | NORTH WESTER | AMHARA | 3.8016 | 1.8412 |
| 807005 | DANGLA | 15.000 | NORTH WESTER | AMHARA | 10.3343 | 5.0052 |
| 807006 | DB-MRKOS | 15.000 | NORTH WESTER | AMHARA | 4.7068 | 2.2797 |
| 807007 | FNOT-SLM | 15.000 | NORTH WESTER | AMHARA | 9.1334 | 4.4235 |
| 807008 | GASHENA | 33.000 | NORTH WESTER | AMHARA | 6.1606 | 2.9837 |
| 807010 | GONDER1 | 15.000 | NORTH WESTER | AMHARA | 1.568 | 0.7594 |
| 807011 | METEMA | 33.000 | NORTH WESTER | EXPORT | 3.7227 | 1.8031 |
| 807012 | MOTA | 33.000 | NORTH WESTER | AMHARA | 3.1319 | 1.5168 |
| 807014 | N-MEWCHA | 33.000 | NORTH WESTER | AMHARA | 4.1071 | 1.9891 |
| 807015 | PAWIE | 15.000 | NORTH WESTER | BENSHANGUL-G | 4.3268 | 2.0956 |
| 807017 | B.DAR2-2 | 15.000 | NORTH WESTER | AMHARA | 6.5461 | 3.1705 |
| 807019 | GONDAR2 | 15.000 | NORTH WESTER | AMHARA | 23.2578 | 11.2643 |
| 807021 | WORETA | 15.000 | NORTH WESTER | AMHARA | 7.5267 | 3.6454 |
| 807022 | GONDER | 15.000 | NORTH WESTER | AMHARA | 1.5544 | 0.7528 |
| 808002 | ADDIS-N | 15.000 | NORTHERN A.A | ADDIS ABABA | 60.8985 | 29.4945 |
| 808004 | FINCHAA | 15.000 | NORTHERN A.A | OROMIA | 4.0938 | 1.9826 |
| 808005 | FNCH-SG1 | 15.000 | NORTHERN | OROMIA | 5.1809 | 2.5092 |

| | | | | | | |
|--------|--------------------|--|--------------|--------|---------|---------|
| | | | A.A | | | |
| 808006 | FNCH-SG2 15.000 | | NORTHERN A.A | OROMIA | 4.0132 | 1.9437 |
| 808008 | GEFERSA 15.000 | | NORTHERN A.A | OROMIA | 18.2972 | 8.8618 |
| 808009 | GHEDO 15.000 | | NORTHERN A.A | OROMIA | 3.4287 | 1.6606 |
| 808010 | GINCHI 15 15.000 | | NORTHERN A.A | OROMIA | 4.6364 | 2.2455 |
| 808011 | GUDER 15.000 | | NORTHERN A.A | OROMIA | 9.0285 | 4.3727 |
| 808012 | MUGER 15.000 | | NORTHERN A.A | OROMIA | 17.0056 | 8.2362 |
| 808016 | MUGER2 15.000 | | NORTHERN A.A | OROMIA | 21.4868 | 10.4065 |
| 809001 | ADIGRAT 15.000 | | NORTHERN | TIGRAY | 6.1998 | 3.0028 |
| 809002 | ADWA 15.000 | | NORTHERN | TIGRAY | 12.1704 | 5.8944 |
| 809003 | ALAMATA1 15.000 | | NORTHERN | TIGRAY | 0 | 0 |
| 809004 | HUMERA 33.000 | | NORTHERN | TIGRAY | 4.2407 | 2.0539 |
| 809005 | MAYCHEW 15.000 | | NORTHERN | TIGRAY | 2.4981 | 1.2099 |
| 809006 | MEKELE 15.000 | | NORTHERN | TIGRAY | 22.4273 | 10.862 |
| 809007 | MESOBO 6.3000 | | NORTHERN | TIGRAY | 39.4996 | 19.1305 |
| 809008 | SHIRE ENDASI15.000 | | NORTHERN | TIGRAY | 2.8796 | 1.3946 |
| 809011 | WUKRO 15.000 | | NORTHERN | TIGRAY | 4.2031 | 2.0356 |
| 809012 | ALAMATA2 15.000 | | NORTHERN | TIGRAY | 2.3468 | 1.1366 |
| 809013 | SHIRE ENDASI33.000 | | NORTHERN | TIGRAY | 4.0855 | 1.9787 |
| 809014 | SHIRE-33-2 15.000 | | NORTHERN | TIGRAY | 0 | 0 |
| 809014 | SHIRE-33-2 15.000 | | NORTHERN | TIGRAY | 0 | 0 |
| 809015 | MEHONI33 33.000 | | NORTHERN | TIGRAY | 5.6333 | 2.7284 |

| | | | | | | |
|--------|----------|--------|-----------------|--------|---------|--------|
| 809016 | DANSHA | 33.000 | NORTHERN | TIGRAY | 5.6333 | 2.7284 |
| 810001 | AMIBARA | 15.000 | SEMERA | OROMIA | 4.2434 | 2.0552 |
| 810003 | AWSH-7KL | 15.000 | SEMERA | OROMIA | 4.54 | 2.1989 |
| 810004 | DITCHETO | 33.000 | SEMERA | AFAR | 0 | 0 |
| 810005 | SEMERA | 33.000 | SEMERA | AFAR | 6.8075 | 3.297 |
| 811001 | A.TULU | 15.000 | SOUTH EASTER | OROMIA | 9.5004 | 4.6012 |
| 811004 | ASSELA | 15.000 | SOUTH EASTER | OROMIA | 13.9584 | 6.7603 |
| 811005 | AWASH II | 15.000 | SOUTH EASTER | OROMIA | 4.2508 | 2.0587 |
| 811006 | AWASH-2 | 15.000 | SOUTH EASTER | OROMIA | 3.8387 | 1.8591 |
| 811007 | AWASH-3 | 15.000 | SOUTH EASTER | OROMIA | 0 | 0 |
| 811008 | BALEROB | 15.000 | SOUTH EASTER | OROMIA | 8.0376 | 3.8928 |
| 811009 | ELALA-GD | 15.000 | SOUTH EASTER | OROMIA | 9.7978 | 4.7453 |
| 811010 | GOBESSA | 33.000 | SOUTH EASTER | OROMIA | 2.4531 | 1.1881 |
| 811011 | KOKA | 15.000 | SOUTH EASTER | OROMIA | 4.1279 | 1.9992 |
| 811012 | KOKA2 15 | 15.000 | SOUTH EASTER | OROMIA | 0 | 0 |
| 811013 | M.WK-YUG | 15.000 | SOUTH EASTER | OROMIA | 6.8437 | 3.3145 |
| 811014 | METAHARA | 15.000 | SOUTH EASTER | OROMIA | 10.2032 | 4.9416 |
| 811015 | MODJO | 15.000 | SOUTH EASTER | OROMIA | 3.9349 | 1.9058 |

| | | | | | | |
|--------|-----------|--------|-----------------|-------------|---------|---------|
| 811016 | NAZ-II | 15.000 | SOUTH EASTER | OROMIA | 35.173 | 17.035 |
| 811017 | NAZRET1 | 15.000 | SOUTH EASTER | OROMIA | 0 | 0 |
| 811018 | NURAERA | 15.000 | SOUTH EASTER | OROMIA | 3 | 1.23 |
| 811019 | WONJIPUL | 15.000 | SOUTH EASTER | OROMIA | 17.0492 | 8.2573 |
| 812001 | A.CENTER | 15.000 | SOUTHERN A.A | ADDIS ABABA | 60.8985 | 29.4945 |
| 812003 | ADS-II | 15.000 | SOUTHERN A.A | ADDIS ABABA | 56.3494 | 27.2913 |
| 812004 | AKAKI | 15.000 | SOUTHERN A.A | ADDIS ABABA | 7.2205 | 3.4971 |
| 812005 | AKAKI-SP | 15.000 | SOUTHERN A.A | ADDIS ABABA | 8.887 | 4.3041 |
| 812008 | DB-ZEIT2 | 15.000 | SOUTHERN A.A | OROMIA | 46.5388 | 22.2337 |
| 812009 | DUKEM | 15.000 | SOUTHERN A.A | OROMIA | 1.3098 | 0.6344 |
| 812010 | KALITI1 | 15.000 | SOUTHERN A.A | ADDIS ABABA | 19.0819 | 9.2418 |
| 812011 | KALITI2- | 15.000 | SOUTHERN A.A | ADDIS ABABA | 23.0585 | 11.1678 |
| 812012 | KALTI-N | 15.000 | SOUTHERN A.A | ADDIS ABABA | 14.6238 | 7.0826 |
| 812013 | MEKANISA | 15.000 | SOUTHERN A.A | ADDIS ABABA | 45 | 22 |
| 812014 | NEFASILK | 15.000 | SOUTHERN A.A | ADDIS ABABA | 23.6198 | 11.4396 |
| 812015 | YESU | 15.000 | SOUTHERN A.A | OROMIA | 6.405 | 3.1021 |
| 812018 | KILINTO15 | 15.000 | SOUTHERN | TIGRAY | 23.8058 | 11.5297 |

| | | | | | | |
|--------|--------------------|--|--------------|---------|---------|--------|
| | | | A.A | | | |
| 812019 | DB-ZEIT3 15.000 | | SOUTHERN A.A | OROMIA | 2.653 | 1.2849 |
| 812020 | EAST INDUSTR33.000 | | SOUTHERN A.A | OROMIA | 20 | 9.69 |
| 813001 | ALABA 15.000 | | SOUTHERN | S.N.N.P | 5.3829 | 2.607 |
| 813002 | A.MINCH 15.000 | | SOUTHERN | S.N.N.P | 12.841 | 6.2192 |
| 813003 | AWASA 15.000 | | SOUTHERN | S.N.N.P | 19.4072 | 9.3994 |
| 813004 | BOCU LUGUMA 33.000 | | SOUTHERN | OROMIA | 6.1134 | 2.9608 |
| 813005 | DILLA 33.000 | | SOUTHERN | S.N.N.P | 3.5122 | 1.701 |
| 813006 | DILLA-1 15.000 | | SOUTHERN | S.N.N.P | 0 | 0 |
| 813007 | H-MARIAM 33.000 | | SOUTHERN | OROMIA | 4.4963 | 2.1776 |
| 813008 | HOSAINA 15.000 | | SOUTHERN | S.N.N.P | 8.0614 | 3.9043 |
| 813009 | NEG-BORE 33.000 | | SOUTHERN | OROMIA | 1.6353 | 0.792 |
| 813010 | S.SHME-1 15.000 | | SOUTHERN | OROMIA | 29.8521 | 14.458 |
| 813011 | SAWLA 33.000 | | SOUTHERN | S.N.N.P | 2.3877 | 1.1564 |
| 813012 | SHAKISO 15.000 | | SOUTHERN | OROMIA | 11.2166 | 5.4325 |
| 813013 | W.SODO 15.000 | | SOUTHERN | S.N.N.P | 10.9331 | 5.2952 |
| 813014 | YADOT 33.000 | | SOUTHERN | OROMIA | 0 | 0 |
| 813015 | YIRGALEM 15.000 | | SOUTHERN | S.N.N.P | 0 | 0 |
| 813016 | DILLA-2 15.000 | | SOUTHERN | S.N.N.P | 12.171 | 5.8947 |
| 813017 | NEG-BORE 15.000 | | SOUTHERN | OROMIA | 2.8583 | 1.3843 |
| 813018 | YIRGALEM 15.000 | | SOUTHERN | S.N.N.P | 14.0488 | 6.8042 |
| 813019 | YIRGALEM 33.000 | | SOUTHERN | S.N.N.P | 3.5122 | 1.701 |
| 813021 | GODE33 33.000 | | SOUTHERN | SOMALE | 4.6827 | 2.2675 |
| 813032 | AWASA15-2 15.000 | | SOUTHERN | S.N.N.P | 5.4695 | 2.649 |
| 813034 | YIRGALEM 15.000 | | SOUTHERN | S.N.N.P | 1.7161 | 0.8313 |

| | | | | | |
|--------|--------------------|-----------------|-------------|---------|---------|
| 813035 | YIRGALEM-IND33.000 | SOUTHERN | S.N.N.P | 91.966 | 44.541 |
| 813036 | AWASA INDUST33.000 | SOUTHERN | S.N.N.P | 81.7326 | 39.5848 |
| 813036 | AWASA INDUST33.000 | SOUTHERN | S.N.N.P | 91.9658 | 44.5409 |
| 814001 | ADDIS-W1 15.000 | WESTERN A.A. | ADDIS ABABA | 16.6264 | 8.0426 |
| 814003 | BUTAJIRA 15.000 | WESTERN A.A. | S.N.N.P | 6.0378 | 2.9243 |
| 814004 | GEDJA 15.000 | WESTERN A.A. | ADDIS ABABA | 5 | 2.3 |
| 814005 | SABATA-B 15.000 | WESTERN A.A. | ADDIS ABABA | 22.2775 | 10.7895 |
| 814005 | SABATA-B 15.000 | WESTERN A.A. | ADDIS ABABA | 28.3916 | 13.7507 |
| 814007 | WOLISO 15.000 | WESTERN A.A. | OROMIA | 13.6221 | 6.5975 |
| 814008 | WOLKITE 33.000 | WESTERN A.A. | S.N.N.P | 2.9257 | 1.417 |
| 814009 | BUTAJIRA33 33.000 | WESTERN A.A. | S.N.N.P | 3.565 | 1.7265 |
| 814011 | WOLISO-33 33.000 | WESTERN A.A. | OROMIA | 1.946 | 0.9425 |
| 814012 | WOLKITE 15.000 | WESTERN A.A. | S.N.N.P | 4.4948 | 2.177 |
| 814013 | BLACK-LION 15.000 | WESTERN A.A. | ADDIS ABABA | 21.0672 | 10.2033 |
| 814020 | BUE33 33.000 | WESTERN A.A. | S.N.N.P | 3 | 1.4529 |
| 814021 | BUE15 15.000 | WESTERN A.A. | S.N.N.P | 2 | 0.9686 |
| 815001 | ABA 15.000 | WESTERN | OROMIA | 4.1747 | 2.0218 |
| 815002 | AGARO 15.000 | WESTERN | OROMIA | 6.0808 | 2.9451 |

| | | | | | | |
|--------|------------|--------|---------|---------|---------|--------|
| 815003 | B.BEDELE | 15.000 | WESTERN | OROMIA | 8.3926 | 4.0647 |
| 815004 | BONGA | 15.000 | WESTERN | S.N.N.P | 5.8031 | 2.8105 |
| 815005 | G.GIBE | 15.000 | WESTERN | OROMIA | 3.1712 | 1.5359 |
| 815007 | GIDA-AYANA | 33.000 | WESTERN | OROMIA | 8.7546 | 4.24 |
| 815008 | JIMMA | 15.000 | WESTERN | OROMIA | 11.6933 | 5.6633 |
| 815009 | MIZAN | 33.000 | WESTERN | S.N.N.P | 1.6639 | 0.8059 |
| 815010 | NEKEMPTTE | 15.000 | WESTERN | OROMIA | 7.1112 | 3.4441 |
| 815011 | TEPI | 15.000 | WESTERN | S.N.N.P | 2.886 | 1.3978 |
| 815013 | BONGA | 33.000 | WESTERN | S.N.N.P | 2.1938 | 1.0625 |

Table B-2 Branches Data's

| From Bus Number | From Bus Name | To Bus Number | To Bus Name | Line R (pu) | Line X (pu) | Charging B (pu) | Rate A ,Band C phases | Length |
|-----------------|--------------------|---------------|--------------------|-------------|-------------|-----------------|-----------------------|--------|
| 101001 | ASSOSA 132.00 | 101003 | MENDI 132.00 | 0.097877 | 0.195833 | 0.03766 | 91 | 80 |
| 101002 | GHIMBI 132.00 | 101003 | MENDI 132.00 | 0.15905 | 0.318229 | 0.06119 | 91 | 130 |
| 101002 | GHIMBI 132.00 | 101004 | TULUCAPIGOLD132.00 | 0.0909 | 0.1714 | 0.03295 | 115 | 70 |
| 101002 | GHIMBI 132.00 | 107008 | DEDSSA 132.00 | 0.0659 | 0.1242 | 0.02389 | 115 | 50.75 |
| 101002 | GHIMBI 132.00 | 115010 | NEKEMPTTE 132.00 | 0.108689 | 0.204569 | 0.03963 | 89 | 84.29 |
| 101002 | GHIMBI 132.00 | 115010 | NEKEMPTTE 132.00 | 0.1097 | 0.2052 | 0.04019 | 115 | 84.29 |
| 101002 | GHIMBI 132.00 | 115015 | KAMASHI 132.00 | 0.2277 | 0.4261 | 0.08341 | 115 | 175 |
| 101003 | MENDI 132.00 | 115011 | GIDAMI 132.00 | 0.194883 | 0.367188 | 0.070606 | 115 | 150 |
| 102001 | ADE-II 132.00 | 102003 | COTOBI-I 132.00 | 0.006679 | 0.013363 | 0.00257 | 91 | 5.46 |
| 102001 | ADE-II 132.00 | 108001 | ADDIS-N 132.00 | 0.012156 | 0.024323 | 0.00468 | 91 | 9.94 |
| 102002 | B.WGN-TP 132.00 | 102003 | COTOBI-I 132.00 | 0.003664 | 0.005967 | 0.00114 | 82 | 2.45 |
| 102002 | B.WGN-TP 132.00 | 102006 | B.WRGENU 132.00 | 0.00673 | 0.010959 | 0.0021 | 82 | 4.5 |

| | | | | | | | | |
|--------|-----------------------|--------|--------------------|----------|----------|----------|-----|--------|
| 102002 | B.WGN-TP 132.00 | 112005 | KALITHI 132.00 | 0.0129 | 0.0197 | 0.00378 | 103 | 8.1 |
| 102003 | COTOB-I 132.00 | 102004 | D.BERHAN 132.00 | 0.160706 | 0.261701 | 0.05018 | 82 | 107.46 |
| 102003 | COTOB-I 132.00 | 102010 | ADDIS-E1 132.00 | 0.00114 | 0.00713 | 0.05777 | 100 | 6 |
| 102003 | COTOB-I 132.00 | 102010 | ADDIS-E1 132.00 | 0.00114 | 0.00713 | 0.05777 | 100 | 6 |
| 102003 | COTOB-I 132.00 | 102012 | AYAT TS 132.00 | 0.010469 | 0.017047 | 0.003272 | 82 | 7 |
| 102003 | COTOB-I 132.00 | 112016 | KILINTO 132.00 | 0.011024 | 0.016804 | 0.003222 | 103 | 6.9 |
| 102004 | D.BERHAN 132.00 | 102014 | MSP-STEEL 132.00 | 0.087038 | 0.141737 | 0.027179 | 82 | 58.2 |
| 102004 | D.BERHAN 132.00 | 102015 | DEBRE-BIREHA132.00 | 0.00095 | 0.00594 | 0.04814 | 100 | 5 |
| 102004 | D.BERHAN 132.00 | 106004 | SHWA-RBT 132.00 | 0.085976 | 0.140007 | 0.02685 | 82 | 57.49 |
| 102005 | SULULTA-132 132.00 | 112015 | DANGOTECEM 132.00 | 0.0806 | 0.1518 | 0.02918 | 115 | 62 |
| 102007 | COTOB-II 132.00 | 102012 | AYAT TS 132.00 | 0.001496 | 0.002435 | 0.000467 | 82 | 1 |
| 102007 | COTOB-II 132.00 | 102013 | SHOAXING-LI 132.00 | 0.05982 | 0.097414 | 0.01868 | 82 | 40 |
| 102007 | COTOB-II 132.00 | 102015 | DEBRE-BIREHA132.00 | 0.14955 | 0.243534 | 0.0467 | 82 | 100 |
| 102013 | SHOAXING-LI 132.00 | 102014 | MSP-STEEL 132.00 | 0.002692 | 0.004384 | 0.000841 | 82 | 1.8 |
| 103001 | ASEBETEFIR 132.00 | 103020 | MIESO 132.00 | 0.035332 | 0.066571 | 0.012801 | 115 | 27.2 |
| 103002 | D.DAWA-1 132.00 | 103003 | D.DAWA-3 132.00 | 0.005491 | 0.008943 | 0.00171 | 82 | 3.67 |
| 103003 | D.DAWA-3 132.00 | 103004 | DD.DS-TP 132.00 | 0.005384 | 0.008767 | 0.00168 | 82 | 3.6 |
| 103003 | D.DAWA-3 132.00 | 103008 | D.DAWA-2 132.00 | 0.018588 | 0.030269 | 0.0058 | 82 | 12.43 |
| 103003 | D.DAWA-3 132.00 | 103009 | D.DAW-DS 132.00 | 0.004677 | 0.008812 | 0.001695 | 115 | 3.6 |
| 103004 | DD.DS-TP 132.00 | 103009 | D.DAW-DS 132.00 | 0.002835 | 0.004617 | 0.00089 | 82 | 1.9 |
| 103004 | DD.DS-TP 132.00 | 110001 | AWSH-7KL 132.00 | 0.306578 | 0.499244 | 0.09572 | 82 | 205 |
| 103005 | FIK 132.00 | 103006 | HARAR-3 132.00 | 0.188288 | 0.376729 | 0.07244 | 91 | 153.9 |
| 103006 | HARAR-3 | 103011 | ALEMAYA 132.00 | 0.030934 | 0.058285 | 0.011207 | 115 | 23.81 |

| | | | | | | | | | |
|--------|---------------------|--------|------------------|----------|----------|----------|-----|--------|--|
| | 132.00 | | | | | | | | |
| 103006 | HARAR-3 132.00 | 103012 | BABILE 132.00 | 0.03248 | 0.061198 | 0.011768 | 115 | 25 | |
| 103006 | HARAR-3 132.00 | 103015 | HARAR-4 132.00 | 0.0052 | 0.0098 | 0.00188 | 115 | 4 | |
| 103007 | HURSO 132.00 | 103010 | D.DAWA-TS 132.00 | 0.020398 | 0.038432 | 0.00739 | 115 | 15.7 | |
| 103007 | HURSO 132.00 | 103019 | MEGALA 132.00 | 0.025919 | 0.048836 | 0.009391 | 115 | 19.95 | |
| 103008 | D.DAWA-2 132.00 | 103011 | ALEMAYA 132.00 | 0.035079 | 0.066094 | 0.012709 | 115 | 27 | |
| 103009 | D.DAW-DS 132.00 | 103010 | D.DAWA-TS 132.00 | 0.008185 | 0.015422 | 0.002965 | 115 | 6.3 | |
| 103012 | BABILE 132.00 | 105001 | JJIGA2 132.00 | 0.090945 | 0.171354 | 0.032949 | 115 | 70 | |
| 103013 | KEBRIDHER 132.00 | 113006 | GODE 132.00 | 0.2274 | 0.4284 | 0.08237 | 115 | 175 | |
| 103016 | AFDEM 132.00 | 103017 | BIKE 132.00 | 0.034689 | 0.065359 | 0.012568 | 115 | 26.7 | |
| 103016 | AFDEM 132.00 | 103020 | MIESO 132.00 | 0.055217 | 0.104037 | 0.020005 | 115 | 42.5 | |
| 103017 | BIKE 132.00 | 103019 | MEGALA 132.00 | 0.059114 | 0.11138 | 0.021417 | 115 | 45.5 | |
| 103020 | MIESO 132.00 | 110003 | DK290 TS 132.00 | 0.05866 | 0.110523 | 0.021252 | 115 | 45.15 | |
| 105001 | JJIGA2 132.00 | 105024 | FAFEM 132.00 | 0.1169 | 0.2203 | 0.043236 | 115 | 90 | |
| 105022 | BERKOT 132.00 | 108014 | DEGEHABUR 132.00 | 0.0922 | 0.1738 | 0.03342 | 115 | 71 | |
| 105024 | FAFEM 132.00 | 108014 | DEGEHABUR 132.00 | 0.1169 | 0.2203 | 0.04236 | 115 | 90 | |
| 106001 | A-KETEMA 132.00 | 106002 | AKSTA 132.00 | 0.183755 | 0.36766 | 0.0707 | 91 | 150.19 | |
| 106002 | AKSTA 132.00 | 106003 | COMBOL-I 132.00 | 0.129687 | 0.259479 | 0.04989 | 91 | 106 | |
| 106002 | AKSTA 132.00 | 106003 | COMBOL-I 132.00 | 0.1379 | 0.2581 | 0.05054 | 115 | 106 | |
| 106003 | COMBOL-I 132.00 | 106005 | COMBOL-II 132.00 | 0.008564 | 0.017135 | 0.00329 | 91 | 7 | |
| 106003 | COMBOL-I 132.00 | 106005 | COMBOL-II 132.00 | 0.0091 | 0.017 | 0.00334 | 115 | 7 | |
| 106003 | COMBOL-I 132.00 | 106005 | COMBOL-II 132.00 | 0.0091 | 0.017 | 0.00334 | 115 | 7 | |
| 106003 | COMBOL-I 132.00 | 106006 | KEMISSIE 132.00 | 0.049436 | 0.092514 | 0.018119 | 115 | 38 | |
| 106003 | COMBOL-I 132.00 | 106008 | DESSIE 132.00 | 0.0165 | 0.0311 | 0.00598 | 115 | 12.7 | |
| 106004 | SHWA-RBT 132.00 | 106006 | KEMISSIE 132.00 | 0.104076 | 0.194766 | 0.038145 | 115 | 80 | |
| 106004 | SHWA-RBT | 106007 | ZEMERO 132.00 | 0.1951 | 0.3652 | 0.07152 | 115 | 150 | |

| | | | | | | | | | |
|--------|--------------------|--------|--------------------|----------|----------|----------|-----|--------|--|
| | 132.00 | | | | | | | | |
| 107001 | B.DAR2 132.00 | 107002 | T-ABAY2 132.00 | 0.035482 | 0.070505 | 0.01381 | 91 | 28.96 | |
| 107001 | B.DAR2 132.00 | 107002 | T-ABAY2 132.00 | 0.035482 | 0.070505 | 0.01381 | 91 | 28.96 | |
| 107001 | B.DAR2 132.00 | 107006 | DANGLA-132 132.00 | 0.0898 | 0.168 | 0.0329 | 115 | 69 | |
| 107001 | B.DAR2 132.00 | 107006 | DANGLA-132 132.00 | 0.0898 | 0.168 | 0.0329 | 115 | 69 | |
| 107003 | PAWIE 132.00 | 107004 | BELESSUGRFAC132.00 | 0.084562 | 0.158248 | 0.030993 | 115 | 65 | |
| 107003 | PAWIE 132.00 | 107004 | BELESSUGRFAC132.00 | 0.084562 | 0.158248 | 0.030993 | 115 | 65 | |
| 107003 | PAWIE 132.00 | 107006 | DANGLA-132 132.00 | 0.1416 | 0.2668 | 0.05131 | 115 | 109 | |
| 107003 | PAWIE 132.00 | 107006 | DANGLA-132 132.00 | 0.1416 | 0.2668 | 0.05131 | 115 | 109 | |
| 107006 | DANGLA-132 132.00 | 107007 | SHAWERA 132.00 | 0.1756 | 0.3287 | 0.06437 | 115 | 135 | |
| 107008 | DEDSSA 132.00 | 115010 | NEKEMPTE 132.00 | 0.0848 | 0.1597 | 0.03071 | 115 | 65.25 | |
| 108001 | ADDIS-N 132.00 | 108015 | MINILIK TS 132.00 | 0.002492 | 0.004058 | 0.000778 | 82 | 1.667 | |
| 108002 | DERBA-CEMENT132.00 | 108007 | DERBA-TAP 132.00 | 0.0605 | 0.12105 | 0.02328 | 91 | 49.45 | |
| 108002 | DERBA-CEMENT132.00 | 108011 | DERBA-TAP2 132.00 | 0.0605 | 0.12105 | 0.02328 | 91 | 49.45 | |
| 108003 | GEFERSA 132.00 | 108007 | DERBA-TAP 132.00 | 0.075855 | 0.151771 | 0.02918 | 91 | 62 | |
| 108003 | GEFERSA 132.00 | 108011 | DERBA-TAP2 132.00 | 0.075855 | 0.151771 | 0.02918 | 91 | 62 | |
| 108003 | GEFERSA 132.00 | 108015 | MINILIK TS 132.00 | 0.014123 | 0.022998 | 0.004411 | 82 | 9.444 | |
| 108003 | GEFERSA 132.00 | 112005 | KALITHI 132.00 | 0.037014 | 0.060275 | 0.01156 | 82 | 24.75 | |
| 108003 | GEFERSA 132.00 | 114003 | SEBTA-TP 132.00 | 0.016122 | 0.026253 | 0.00503 | 82 | 10.78 | |
| 108004 | GHEDO 132.00 | 108005 | GUDER 132.00 | 0.043829 | 0.082493 | 0.01598 | 89 | 33.99 | |
| 108004 | GHEDO 132.00 | 115010 | NEKEMPTE 132.00 | 0.149436 | 0.281261 | 0.05449 | 89 | 115.89 | |
| 108006 | MUGER 132.00 | 108007 | DERBA-TAP 132.00 | 0.022022 | 0.044062 | 0.00847 | 91 | 18 | |
| 108006 | MUGER 132.00 | 108011 | DERBA-TAP2 132.00 | 0.022022 | 0.044062 | 0.00847 | 91 | 18 | |
| 108009 | FINCHA-II 132.00 | 115012 | JARDEJARTE 132.00 | 0.1431 | 0.2678 | 0.05245 | 115 | 110 | |
| 109001 | ADIGRAT 132.00 | 109008 | WUKRO-TP 132.00 | 0.072919 | 0.137245 | 0.02659 | 89 | 56.55 | |

| | | | | | | | | |
|--------|-----------------|--------|----------------------|----------|----------|---------|-----|--------|
| 109002 | ADWA 132.00 | 109004 | MEKELE 132.00 | 0.150532 | 0.283324 | 0.05489 | 89 | 116.74 |
| 109004 | MEKELE 132.00 | 109005 | MESOBO 132.00 | 0.006525 | 0.012281 | 0.00238 | 89 | 5.06 |
| 109004 | MEKELE 132.00 | 109005 | MESOBO 132.00 | 0.0066 | 0.0123 | 0.00241 | 115 | 5.06 |
| 109004 | MEKELE 132.00 | 109006 | WIND-P 132.00 | 0.0195 | 0.0367 | 0.00706 | 115 | 15 |
| 109004 | MEKELE 132.00 | 109008 | WUKRO-TP 132.00 | 0.040025 | 0.075333 | 0.0146 | 89 | 31.04 |
| 109007 | WUKRO 132.00 | 109008 | WUKRO-TP 132.00 | 0.001506 | 0.002835 | 0.00055 | 89 | 1.17 |
| 109010 | MEKELEII 132.00 | 109011 | ABIADI 132.00 | 0.1236 | 0.2313 | 0.0453 | 115 | 95 |
| 110001 | AWSH-7KL 132.00 | 110002 | AMIBARA 132.00 | 0.0553 | 0.1043 | 0.02005 | 115 | 42.6 |
| 110001 | AWSH-7KL 132.00 | 110003 | DK290 TS 132.00 | 0.037677 | 0.07099 | 0.01365 | 115 | 29 |
| 110001 | AWSH-7KL 132.00 | 111016 | METE HAR A-TS 132.00 | 0.040795 | 0.076865 | 0.01478 | 115 | 31.4 |
| 111001 | A.TULU 132.00 | 111002 | ASSELA 132.00 | 0.076217 | 0.124114 | 0.0238 | 82 | 50.96 |
| 111001 | A.TULU 132.00 | 111019 | ALUTO-II 132.00 | 0.039 | 0.0734 | 0.01412 | 115 | 30 |
| 111001 | A.TULU 132.00 | 113009 | S.SHEMEN 132.00 | 0.114899 | 0.187107 | 0.03588 | 82 | 76.83 |
| 111001 | A.TULU 132.00 | 114001 | BUTAJIRA 132.00 | 0.057234 | 0.114514 | 0.02202 | 91 | 46.78 |
| 111002 | ASSELA 132.00 | 111003 | AWASH2 132.00 | 0.07657 | 0.124689 | 0.02391 | 82 | 51.2 |
| 111003 | AWASH2 132.00 | 111004 | AWASH-3 132.00 | 0.002171 | 0.003512 | 0.00069 | 82 | 1.45 |
| 111003 | AWASH2 132.00 | 111004 | AWASH-3 132.00 | 0.002171 | 0.003512 | 0.00069 | 82 | 1.45 |
| 111003 | AWASH2 132.00 | 111007 | KOKA 132.00 | 0.037911 | 0.061736 | 0.01184 | 82 | 25.35 |
| 111003 | AWASH2 132.00 | 111014 | WONJPULP 132.00 | 0.026904 | 0.043812 | 0.0084 | 82 | 17.99 |
| 111005 | ELALA-GD 132.00 | 111006 | ELALA-TP 132.00 | 0.007328 | 0.011933 | 0.00229 | 82 | 4.9 |
| 111006 | ELALA-TP 132.00 | 111007 | KOKA 132.00 | 0.035578 | 0.057937 | 0.01111 | 82 | 23.79 |
| 111006 | ELALA-TP 132.00 | 112013 | INDODE 132.00 | 0.052 | 0.0979 | 0.01883 | 115 | 40 |
| 111007 | KOKA 132.00 | 111011 | NAZRETH2 132.00 | 0.017176 | 0.02797 | 0.00536 | 82 | 11.48 |
| 111007 | KOKA 132.00 | 111014 | WONJPULP 132.00 | 0.011007 | 0.017924 | 0.00344 | 82 | 7.36 |

| | | | | | | | | |
|--------|-------------------|--------|--------------------|----------|----------|----------|-----|--------|
| 111007 | KOKA 132.00 | 111018 | ABYSSINIAN 132.00 | 0.0193 | 0.0364 | 0.007 | 115 | 14.868 |
| 111007 | KOKA 132.00 | 112004 | DBZT2-TP 132.00 | 0.057652 | 0.093882 | 0.018 | 82 | 38.55 |
| 111008 | M.WAKNA 132.00 | 111013 | M.WK-YUG 132.00 | 0.006447 | 0.012135 | 0.00235 | 89 | 5 |
| 111008 | M.WAKNA 132.00 | 111013 | M.WK-YUG 132.00 | 0.006447 | 0.012135 | 0.00235 | 89 | 5 |
| 111008 | M.WAKNA 132.00 | 113013 | YADOT 132.00 | 0.122346 | 0.244792 | 0.04707 | 91 | 100 |
| 111009 | METAHARA 132.00 | 111010 | METEHRATAP 132.00 | 0 | 0.0001 | 0 | 82 | 0 |
| 111010 | METEHRATAP 132.00 | 111011 | NAZRETH2 132.00 | 0.13196 | 0.214889 | 0.0412 | 82 | 88.24 |
| 111010 | METEHRATAP 132.00 | 111016 | METEHARA-TS 132.00 | 0.001299 | 0.002448 | 0.000471 | 115 | 1 |
| 111012 | WONJI-TP 132.00 | 111014 | WONJPULP 132.00 | 0.000852 | 0.001388 | 0.00027 | 82 | 0.57 |
| 111013 | M.WK-YUG 132.00 | 111020 | GOBESA 132.00 | 0.0964 | 0.1816 | 0.03493 | 115 | 74.2 |
| 111013 | M.WK-YUG 132.00 | 113009 | S.SHEMEN 132.00 | 0.153691 | 0.28927 | 0.05604 | 89 | 119.19 |
| 111018 | ABYSSINIAN 132.00 | 112011 | AKAKI 2 132.00 | 0.0629 | 0.1184 | 0.02277 | 115 | 48.381 |
| 111020 | GOBESA 132.00 | 111021 | BALEROBE 132.00 | 0.0416 | 0.0783 | 0.01506 | 115 | 32 |
| 112001 | A.CENTER 132.00 | 112005 | KALITI1 132.00 | 0.02146 | 0.034947 | 0.0067 | 82 | 14.35 |
| 112002 | ADS-II 132.00 | 112009 | MEKANISA 132.00 | 0.002447 | 0.004896 | 0.00094 | 91 | 2 |
| 112002 | ADS-II 132.00 | 112009 | MEKANISA 132.00 | 0.0026 | 0.0049 | 0.00095 | 115 | 2 |
| 112003 | DB-ZEIT2 132.00 | 112004 | DBZT2-TP 132.00 | 0.000075 | 0.000122 | 0.00002 | 82 | 0.05 |
| 112004 | DBZT2-TP 132.00 | 112011 | AKAKI 2 132.00 | 0.0351 | 0.0661 | 0.01271 | 115 | 27 |
| 112005 | KALITI1 132.00 | 112006 | KALTI-N 132.00 | 0.012941 | 0.019726 | 0.003782 | 103 | 8.1 |
| 112005 | KALITI1 132.00 | 112008 | KLT.N-TP 132.00 | 0.002243 | 0.003653 | 0.0007 | 82 | 1.5 |
| 112005 | KALITI1 132.00 | 112009 | MEKANISA 132.00 | 0.024167 | 0.039355 | 0.00755 | 82 | 16.16 |
| 112005 | KALITI1 132.00 | 112010 | YESU 132.00 | 0.0104 | 0.0196 | 0.00377 | 115 | 8 |
| 112005 | KALITI1 132.00 | 112011 | AKAKI 2 132.00 | 0.0105 | 0.0161 | 0.00308 | 115 | 1 |
| 112005 | KALITI1 132.00 | 112011 | AKAKI 2 132.00 | 0.0105 | 0.0161 | 0.00308 | 115 | 1 |
| 112005 | KALITI1 132.00 | 112017 | KALITI TS 132.00 | 0.001104 | 0.006906 | 0.055942 | 100 | 5.81 |
| 112006 | KALTI-N | 112008 | KLT.N-TP 132.00 | 0.000658 | 0.001072 | 0.00021 | 82 | 0.44 |

| | | | | | | | | | |
|--------|-----------------------|--------|--------------------|----------|----------|----------|-----|--------|--|
| | 132.00 | | | | | | | | |
| 112007 | KALTWO 132.00 | 112014 | NEFASILK 132.00 | 0.00057 | 0.00356 | 0.02889 | 100 | 3 | |
| 112007 | KALTWO 132.00 | 112014 | NEFASILK 132.00 | 0.00057 | 0.00356 | 0.02889 | 100 | 3 | |
| 112007 | KALTWO 132.00 | 112017 | KALITI TS 132.00 | 0.00057 | 0.00356 | 0.02889 | 100 | 3 | |
| 112008 | KLT.N-TP 132.00 | 112016 | KILINTO 132.00 | 0.0105 | 0.0161 | 0.00308 | 103 | 6.6 | |
| 112009 | MEKANISA 132.00 | 114003 | SEBTA-TP 132.00 | 0.01168 | 0.01902 | 0.00365 | 82 | 7.81 | |
| 112009 | MEKANISA 132.00 | 114007 | ADDIS-EFW 132.00 | 0.0091 | 0.0171 | 0.00329 | 115 | 7 | |
| 112010 | YESU 132.00 | 112011 | AKAKI 2 132.00 | 0.0013 | 0.0024 | 0.00047 | 115 | 1 | |
| 112011 | AKAKI 2 132.00 | 112013 | INDODE 132.00 | 0.0052 | 0.0098 | 0.00188 | 115 | 4 | |
| 113001 | A.MINCH 132.00 | 113012 | W.SODO 132.00 | 0.140719 | 0.264855 | 0.05131 | 89 | 109.13 | |
| 113002 | ALABA 132.00 | 113008 | HOSAINA 132.00 | 0.051063 | 0.096108 | 0.01862 | 89 | 39.6 | |
| 113002 | ALABA 132.00 | 113009 | S.SHEMEN 132.00 | 0.081533 | 0.153457 | 0.02973 | 89 | 63.23 | |
| 113002 | ALABA 132.00 | 113012 | W.SODO 132.00 | 0.079702 | 0.150011 | 0.02906 | 89 | 61.81 | |
| 113003 | AWASA 132.00 | 113009 | S.SHEMEN 132.00 | 0.032303 | 0.052603 | 0.01009 | 82 | 21.6 | |
| 113003 | AWASA 132.00 | 113014 | YIRGALEM 132.00 | 0.052477 | 0.085456 | 0.01639 | 82 | 35.09 | |
| 113003 | AWASA 132.00 | 113027 | AWASA II 132.00 | 0.004487 | 0.007306 | 0.001401 | 82 | 3 | |
| 113004 | BOCU LUGUMA 132.00 | 113016 | YABELO 132.00 | 0.13252 | 0.249688 | 0.048012 | 115 | 102 | |
| 113005 | DILLA 132.00 | 113007 | HAGER MARIAY132.00 | 0.110112 | 0.220313 | 0.04236 | 91 | 90 | |
| 113005 | DILLA 132.00 | 113014 | YIRGALEM 132.00 | 0.048939 | 0.097917 | 0.01883 | 91 | 40 | |
| 113005 | DILLA 132.00 | 113026 | YIRGALEM II 132.00 | 0.04369 | 0.087415 | 0.01681 | 91 | 35.71 | |
| 113007 | HAGER MARIAY132.00 | 113016 | YABELO 132.00 | 0.126024 | 0.237448 | 0.045658 | 115 | 97 | |
| 113008 | HOSAINA 132.00 | 115005 | G.G OLD 132.00 | 0.091062 | 0.171393 | 0.03321 | 89 | 70.62 | |
| 113009 | S.SHEMEN 132.00 | 113027 | AWASA II 132.00 | 0.028415 | 0.046271 | 0.008875 | 82 | 19 | |
| 113010 | SAWLA 132.00 | 113012 | W.SODO 132.00 | 0.151709 | 0.303542 | 0.05837 | 91 | 124 | |
| 113010 | SAWLA 132.00 | 113017 | KEY AFER 132.00 | 0.144213 | 0.271719 | 0.052248 | 115 | 111 | |

| | | | | | | | | |
|--------|-----------------------|--------|--------------------|----------|----------|----------|-----|--------|
| 113011 | SHAKISO 132.00 | 113014 | YIRGALEM 132.00 | 0.199216 | 0.324411 | 0.0622 | 82 | 133.21 |
| 113011 | SHAKISO 132.00 | 113014 | YIRGALEM 132.00 | 0.199216 | 0.324411 | 0.0622 | 82 | 133.21 |
| 113014 | YIRGALEM 132.00 | 113026 | YIRGALEM II 132.00 | 0.008564 | 0.017135 | 0.003295 | 91 | 7 |
| 113018 | OMA-KURAZF1 132.00 | 113019 | OMA-KURAZF2 132.00 | 0.0755 | 0.1412 | 0.02766 | 115 | 58 |
| 113018 | OMA-KURAZF1 132.00 | 113019 | OMA-KURAZF2 132.00 | 0.0755 | 0.1412 | 0.02766 | 115 | 58 |
| 113019 | OMA-KURAZF2 132.00 | 113020 | OMA-KURAZF3 132.00 | 0.026 | 0.0487 | 0.00954 | 115 | 20 |
| 113019 | OMA-KURAZF2 132.00 | 113020 | OMA-KURAZF3 132.00 | 0.026 | 0.0487 | 0.00954 | 115 | 20 |
| 113020 | OMA-KURAZF3 132.00 | 113021 | OMA-KURAZF4 132.00 | 0.0364 | 0.0682 | 0.01335 | 115 | 28 |
| 113020 | OMA-KURAZF3 132.00 | 113021 | OMA-KURAZF4 132.00 | 0.0364 | 0.0682 | 0.01335 | 115 | 28 |
| 113021 | OMA-KURAZF4 132.00 | 113022 | OMA-KURAZF5 132.00 | 0.0195 | 0.0367 | 0.00706 | 115 | 15 |
| 113022 | OMA-KURAZF5 132.00 | 113023 | OMA-KURAZF6 132.00 | 0.0221 | 0.0416 | 0.008 | 115 | 17 |
| 113024 | BUEE 132.00 | 114001 | BUTAJIRA 132.00 | 0.038977 | 0.073438 | 0.014121 | 115 | 30 |
| 114002 | SEBATA 132.00 | 114003 | SEBTA-TP 132.00 | 0.001496 | 0.002435 | 0.00047 | 82 | 1 |
| 114002 | SEBATA 132.00 | 114004 | ADDIS WEST 132.00 | 0.00133 | 0.00832 | 0.0674 | 100 | 7 |
| 114003 | SEBTA-TP 132.00 | 114007 | ADDIS-EFW 132.00 | 0.0088 | 0.0166 | 0.0032 | 115 | 6.8 |
| 114004 | ADDIS WEST 132.00 | 114006 | BLACK-LION 132.00 | 0.00095 | 0.00594 | 0.04814 | 100 | 5 |
| 114004 | ADDIS WEST 132.00 | 114006 | BLACK-LION 132.00 | 0.00114 | 0.00713 | 0.05777 | 100 | 6 |
| 115001 | ABA 132.00 | 115008 | JIMMA 132.00 | 0.057503 | 0.115052 | 0.02212 | 91 | 47 |
| 115002 | AGARO 132.00 | 115003 | B.BEDELE 132.00 | 0.104962 | 0.197555 | 0.03827 | 89 | 81.4 |
| 115002 | AGARO 132.00 | 115008 | JIMMA 132.00 | 0.044899 | 0.084507 | 0.01637 | 89 | 34.82 |
| 115003 | B.BEDELE 132.00 | 115010 | NEKEMPTE 132.00 | 0.141922 | 0.283958 | 0.0546 | 91 | 116 |
| 115004 | BONGA 132.00 | 115008 | JIMMA 132.00 | 0.125301 | 0.248984 | 0.04876 | 91 | 102.27 |
| 115004 | BONGA 132.00 | 115008 | JIMMA 132.00 | 0.125337 | 0.249057 | 0.04878 | 91 | 102.3 |

| | | | | | | | | | |
|--------|----------------------|--|--------|--------------------|----------|----------|----------|-----|---------|
| 115004 | BONGA 132.00 | | 115009 | MIZAN 132.00 | 0.108032 | 0.216151 | 0.04156 | 91 | 88.3 |
| 115005 | G.G OLD 132.00 | | 115006 | G-GIBE-1 132.00 | 0.003353 | 0.00631 | 0.00122 | 89 | 2.6 |
| 115005 | G.G OLD 132.00 | | 115008 | JIMMA 132.00 | 0.091964 | 0.173091 | 0.03353 | 89 | 71.32 |
| 115007 | GIDA-AYANA 132.00 | | 115010 | NEKEMPTE 132.00 | 0.114503 | 0.229098 | 0.04405 | 91 | 93.59 |
| 115008 | JIMMA 132.00 | | 115013 | ATANGO 132.00 | 0.1366 | 0.2556 | 0.05007 | 115 | 105 |
| 115009 | MIZAN 132.00 | | 115014 | TUM 132.00 | 0.1951 | 0.3652 | 0.07152 | 115 | 150 |
| 202001 | COTOBI-II 230.00 | | 202002 | SULULTA 230.00 | 0.0045 | 0.0126 | 0.04046 | 402 | 21 |
| 202001 | COTOBI-II 230.00 | | 202002 | SULULTA 230.00 | 0.0045 | 0.0126 | 0.04046 | 402 | 21 |
| 202001 | COTOBI-II 230.00 | | 202004 | BOLE-LEMI 230.00 | 0.001824 | 0.0051 | 0.016378 | 402 | 8.5 |
| 202001 | COTOBI-II 230.00 | | 202020 | D.BEHRAN230 230.00 | 0.020245 | 0.061892 | 0.187103 | 318 | 100.412 |
| 202001 | COTOBI-II 230.00 | | 202021 | COTOBI-I 230.00 | 0.0017 | 0.0048 | 0.01542 | 402 | 8 |
| 202001 | COTOBI-II 230.00 | | 202021 | COTOBI-I 230.00 | 0.0017 | 0.0048 | 0.01542 | 402 | 8 |
| 202001 | COTOBI-II 230.00 | | 206001 | COMBOL-II 230.00 | 0.057843 | 0.176833 | 0.53458 | 318 | 286.89 |
| 202001 | COTOBI-II 230.00 | | 212001 | KALITI1 230.00 | 0.007058 | 0.020947 | 0.06727 | 318 | 34.91 |
| 202001 | COTOBI-II 230.00 | | 212001 | KALITI1 230.00 | 0.007058 | 0.020947 | 0.06727 | 318 | 34.91 |
| 202002 | SULULTA 230.00 | | 202003 | CHANCHO230 230.00 | 0.0032 | 0.009 | 0.0289 | 402 | 15 |
| 202002 | SULULTA 230.00 | | 202003 | CHANCHO230 230.00 | 0.0032 | 0.009 | 0.0289 | 402 | 15 |
| 202002 | SULULTA 230.00 | | 202006 | SHEGOLE 230.00 | 0.0017 | 0.0049 | 0.01491 | 402 | 8 |
| 202002 | SULULTA 230.00 | | 202006 | SHEGOLE 230.00 | 0.0017 | 0.0049 | 0.01491 | 402 | 8 |
| 202002 | SULULTA 230.00 | | 208003 | GEFERSA 230.00 | 0.003382 | 0.010038 | 0.03224 | 318 | 16.73 |
| 202002 | SULULTA 230.00 | | 208003 | GEFERSA 230.00 | 0.003382 | 0.010038 | 0.03224 | 318 | 16.73 |
| 202004 | BOLE-LEMI 230.00 | | 212001 | KALITI1 230.00 | 0.006525 | 0.018239 | 0.058577 | 402 | 30.4 |
| 202005 | FITCHE 2 230.00 | | 202008 | GEBRE-GURCHA230.00 | 0.009849 | 0.028353 | 0.085714 | 402 | 46 |

| | | | | | | | | | |
|--------|------------------------|---|--------|--------------------|----------|----------|----------|-----|---------|
| 202005 | FITCHE 230.00 | 2 | 202008 | GEBRE-GURCHA230.00 | 0.009849 | 0.028353 | 0.085714 | 402 | 46 |
| 202006 | SHEGOLE 230.00 | | 208003 | GEFERSA 230.00 | 0.0019 | 0.0054 | 0.01627 | 402 | 8.73 |
| 202006 | SHEGOLE 230.00 | | 208003 | GEFERSA 230.00 | 0.0019 | 0.0054 | 0.01627 | 402 | 8.73 |
| 202020 | D.BEHRAN230 230.00 | | 206001 | COMBOL-II 230.00 | 0.037598 | 0.114941 | 0.347477 | 318 | 186.479 |
| 203001 | ADIGALA 230.00 | | 203004 | HURSO 230.00 | 0.028047 | 0.080746 | 0.2441 | 402 | 131 |
| 203001 | ADIGALA 230.00 | | 203007 | LASARAT 230.00 | 0.007708 | 0.02219 | 0.067081 | 402 | 36 |
| 203001 | ADIGALA 230.00 | | 203013 | ADIGALA-TS 230.00 | 0.0018 | 0.0052 | 0.01657 | 402 | 8.6 |
| 203001 | ADIGALA 230.00 | | 203013 | ADIGALA-TS 230.00 | 0.0018 | 0.0052 | 0.01657 | 402 | 8.6 |
| 203002 | D.DAWA3 230.00 | | 203004 | HURSO 230.00 | 0.006117 | 0.017099 | 0.054916 | 402 | 28.5 |
| 203002 | D.DAWA3 230.00 | | 203004 | HURSO 230.00 | 0.006117 | 0.017099 | 0.054916 | 402 | 28.5 |
| 203002 | D.DAWA3 230.00 | | 210001 | AWSH-7KL 230.00 | 0.035593 | 0.158565 | 0.304992 | 353 | 205 |
| 203002 | D.DAWA3 230.00 | | 211001 | KOKA 230.00 | 0.054881 | 0.260666 | 0.50138 | 274 | 337 |
| 203002 | D.DAWA3 230.00 | | 211007 | NURAERA 230.00 | 0.0107 | 0.0308 | 0.09317 | 402 | 50 |
| 203003 | DJIB-PK12 230.00 | | 203007 | LASARAT 230.00 | 0.025692 | 0.073965 | 0.223603 | 402 | 120 |
| 203003 | DJIB-PK12 230.00 | | 203012 | SUBURBAN 230.00 | 0.0186 | 0.0536 | 0.16198 | 402 | 86.93 |
| 203004 | HURSO 230.00 | | 203005 | HARAR IV 230.00 | 0.0105 | 0.0302 | 0.0913 | 402 | 49 |
| 203004 | HURSO 230.00 | | 203005 | HARAR IV 230.00 | 0.0105 | 0.0302 | 0.0913 | 402 | 49 |
| 203004 | HURSO 230.00 | | 203006 | DIRE-IND-230230.00 | 0.0047 | 0.0132 | 0.04239 | 402 | 22 |
| 203004 | HURSO 230.00 | | 203006 | DIRE-IND-230230.00 | 0.0047 | 0.0132 | 0.04239 | 402 | 22 |
| 203004 | HURSO 230.00 | | 203010 | MIESO 230.00 | 0.042071 | 0.117594 | 0.377668 | 402 | 196 |
| 203004 | HURSO 230.00 | | 203012 | SUBURBAN 230.00 | 0.0458 | 0.1319 | 0.39863 | 402 | 213.93 |
| 203004 | HURSO 230.00 | | 211001 | KOKA 230.00 | 0.075556 | 0.211189 | 0.678261 | 402 | 352 |
| 203004 | HURSO 230.00 | | 211005 | NAZERET-ADAM230.00 | 0.062945 | 0.181215 | 0.547828 | 402 | 294 |
| 203006 | DIRE-IND- 230230.00 | | 203008 | LONNIS 230.00 | 0.003434 | 0.009599 | 0.03083 | 402 | 16 |
| 203006 | DIRE-IND- | | 203011 | SHI-KUL-230 230.00 | 0.0118 | 0.033 | 0.10598 | 402 | 55 |

| | | | | | | | | |
|--------|---------------------|--------|--------------------|----------|----------|----------|------|-------|
| | 230230.00 | | | | | | | |
| 203007 | LASARAT 230.00 | 203014 | AYISHAWIND 230.00 | 0.0021 | 0.006 | 0.01927 | 402 | 10 |
| 203007 | LASARAT 230.00 | 203014 | AYISHAWIND 230.00 | 0.0021 | 0.006 | 0.01927 | 402 | 10 |
| 203008 | LONNIS 230.00 | 203011 | SHI-KUL-230 230.00 | 0.009015 | 0.025199 | 0.080929 | 402 | 42 |
| 203010 | MIESO 230.00 | 211001 | KOKA 230.00 | 0.025114 | 0.070196 | 0.225445 | 402 | 117 |
| 204001 | GAMBELA2 230.00 | 204002 | METU 230.00 | 0.029974 | 0.086293 | 0.26087 | 402 | 140 |
| 204002 | METU 230.00 | 215001 | BEDELLE 230.00 | 0.018245 | 0.055777 | 0.16862 | 318 | 90.49 |
| 206001 | COMBOL-II 230.00 | 206002 | TOSAMETAL 230.00 | 0.0021 | 0.006 | 0.01927 | 402 | 10 |
| 206001 | COMBOL-II 230.00 | 206002 | TOSAMETAL 230.00 | 0.0021 | 0.006 | 0.01927 | 402 | 10 |
| 206001 | COMBOL-II 230.00 | 206003 | COMBOLIND 230.00 | 0.003 | 0.0084 | 0.02698 | 402 | 14 |
| 206001 | COMBOL-II 230.00 | 206003 | COMBOLIND 230.00 | 0.003 | 0.0084 | 0.02698 | 402 | 14 |
| 206001 | COMBOL-II 230.00 | 206004 | WOLDIA 230.00 | 0.0193 | 0.054 | 0.17342 | 402 | 90 |
| 206001 | COMBOL-II 230.00 | 206004 | WOLDIA 230.00 | 0.0193 | 0.054 | 0.17342 | 402 | 90 |
| 206001 | COMBOL-II 230.00 | 206007 | DESSIE 230.00 | 0.0047 | 0.0132 | 0.04239 | 402 | 22 |
| 206001 | COMBOL-II 230.00 | 206007 | DESSIE 230.00 | 0.0047 | 0.0132 | 0.04239 | 402 | 22 |
| 206001 | COMBOL-II 230.00 | 209001 | ALAMATA 230.00 | 0.034126 | 0.101275 | 0.32526 | 318 | 168.8 |
| 206001 | COMBOL-II 230.00 | 209001 | ALAMATA 230.00 | 0.034126 | 0.101275 | 0.32526 | 318 | 168.8 |
| 206001 | COMBOL-II 230.00 | 210003 | SEMERA 230.00 | 0.034276 | 0.104784 | 0.31677 | 318 | 170 |
| 206004 | WOLDIA 230.00 | 206005 | SUN-HI-GUL 230.00 | 0.0155 | 0.0432 | 0.13874 | 1973 | 72 |
| 206004 | WOLDIA 230.00 | 206005 | SUN-HI-GUL 230.00 | 0.0155 | 0.0432 | 0.13874 | 1973 | 72 |
| 206004 | WOLDIA 230.00 | 206007 | DESSIE 230.00 | 0.0189 | 0.0528 | 0.16957 | 402 | 88 |
| 206004 | WOLDIA 230.00 | 206007 | DESSIE 230.00 | 0.0189 | 0.0528 | 0.16957 | 402 | 88 |
| 206004 | WOLDIA 230.00 | 209001 | ALAMATA 230.00 | 0.0144 | 0.0402 | 0.1291 | 402 | 67 |
| 206004 | WOLDIA | 209001 | ALAMATA 230.00 | 0.0144 | 0.0402 | 0.1291 | 402 | 67 |

| | | | | | | | | | |
|--------|----------------------|--------|--------------------|----------|----------|----------|------|--------|--|
| | 230.00 | | | | | | | | |
| 206005 | SUN-HI-GUL 230.00 | 206006 | TERU 230.00 | 0.0107 | 0.03 | 0.09634 | 1973 | 50 | |
| 206005 | SUN-HI-GUL 230.00 | 206006 | TERU 230.00 | 0.0107 | 0.03 | 0.09634 | 1973 | 50 | |
| 207001 | B.DAR2 230.00 | 207005 | GONDAR2 230.00 | 0.029325 | 0.084425 | 0.255224 | 402 | 136.97 | |
| 207001 | B.DAR2 230.00 | 207005 | GONDAR2 230.00 | 0.029325 | 0.084425 | 0.255224 | 402 | 136.97 | |
| 207001 | B.DAR2 230.00 | 207007 | MOTA 230.00 | 0.012781 | 0.066429 | 0.12006 | 280 | 83 | |
| 207001 | B.DAR2 230.00 | 207008 | N.MEW TP 230.00 | 0.027501 | 0.084074 | 0.25416 | 318 | 136.4 | |
| 207001 | B.DAR2 230.00 | 207011 | WORETA 230.00 | 0.01199 | 0.034517 | 0.104348 | 402 | 56 | |
| 207002 | DB-MRKOS 230.00 | 207007 | MOTA 230.00 | 0.017209 | 0.089447 | 0.16166 | 280 | 111.76 | |
| 207002 | DB-MRKOS 230.00 | 207010 | DEJEN 230.00 | 0.009206 | 0.026504 | 0.080124 | 402 | 43 | |
| 207002 | DB-MRKOS 230.00 | 208001 | FINCHA 230.00 | 0.014652 | 0.076154 | 0.13763 | 280 | 95.15 | |
| 207003 | GASHENA 230.00 | 207004 | GASHE-TA 230.00 | 0.000202 | 0.000616 | 0.00186 | 318 | 1 | |
| 207004 | GASHE-TA 230.00 | 207008 | N.MEW TP 230.00 | 0.020626 | 0.063056 | 0.19062 | 318 | 102.3 | |
| 207004 | GASHE-TA 230.00 | 209001 | ALAMATA 230.00 | 0.020626 | 0.063056 | 0.19062 | 318 | 102.3 | |
| 207005 | GONDAR2 230.00 | 207006 | METEMA 230.00 | 0.033358 | 0.098995 | 0.31793 | 318 | 165 | |
| 207005 | GONDAR2 230.00 | 207006 | METEMA 230.00 | 0.035326 | 0.101702 | 0.307454 | 402 | 165 | |
| 207005 | GONDAR2 230.00 | 209011 | DANSHA 230.00 | 0.0246 | 0.0709 | 0.21429 | 402 | 115 | |
| 207006 | METEMA 230.00 | 207013 | SUDAN-GADARE230.00 | 0.0343 | 0.096 | 0.3083 | 402 | 160 | |
| 207006 | METEMA 230.00 | 207013 | SUDAN-GADARE230.00 | 0.0343 | 0.096 | 0.3083 | 402 | 160 | |
| 207008 | N.MEW TP 230.00 | 207009 | N.MEWCHA 230.00 | 0.000202 | 0.000616 | 0.00186 | 318 | 1 | |
| 207008 | N.MEW TP 230.00 | 207011 | WORETA 230.00 | 0.017826 | 0.05132 | 0.155143 | 402 | 83.26 | |
| 207013 | SUDAN-GADARE230.00 | 207014 | SUDAN-RABAK 230.00 | 0.050586 | 0.228355 | 0.43378 | 402 | 400 | |
| 207013 | SUDAN-GADARE230.00 | 207014 | SUDAN-RABAK 230.00 | 0.050586 | 0.228355 | 0.43378 | 402 | 400 | |
| 208001 | FINCHA 230.00 | 208002 | FINCHA-II 230.00 | 0.001673 | 0.005116 | 0.01547 | 318 | 8.3 | |
| 208001 | FINCHA 230.00 | 208004 | GHEDO 230.00 | 0.010041 | 0.053852 | 0.09704 | 284 | 67.19 | |

| | | | | | | | | |
|--------|-----------------------|--------|--------------------|----------|----------|----------|-----|--------|
| 208002 | FINCHA-II 230.00 | 208004 | GHEDO 230.00 | 0.014058 | 0.042977 | 0.12992 | 318 | 69.72 |
| 208002 | FINCHA-II 230.00 | 208004 | GHEDO 230.00 | 0.014923 | 0.042962 | 0.129876 | 402 | 69.7 |
| 208002 | FINCHA-II 230.00 | 208005 | NESHE 230.00 | 0.005897 | 0.018027 | 0.0545 | 318 | 29.25 |
| 208003 | GEFERSA 230.00 | 208004 | GHEDO 230.00 | 0.020486 | 0.106479 | 0.19244 | 280 | 133.04 |
| 208003 | GEFERSA 230.00 | 208004 | GHEDO 230.00 | 0.028548 | 0.079796 | 0.256275 | 402 | 133 |
| 208003 | GEFERSA 230.00 | 208004 | GHEDO 230.00 | 0.028548 | 0.079796 | 0.256275 | 402 | 133 |
| 208003 | GEFERSA 230.00 | 208006 | A.ALEM 230.00 | 0.007371 | 0.035277 | 0.066746 | 363 | 45 |
| 208003 | GEFERSA 230.00 | 208007 | GINCHI 230.00 | 0.013523 | 0.037798 | 0.121393 | 402 | 63 |
| 208003 | GEFERSA 230.00 | 208009 | TORHAYILOCH 230.00 | 0.006886 | 0.012974 | 0.002495 | 115 | 5.3 |
| 208004 | GHEDO 230.00 | 208006 | A.ALEM 230.00 | 0.01425 | 0.068203 | 0.129042 | 363 | 87 |
| 208004 | GHEDO 230.00 | 208007 | GINCHI 230.00 | 0.015455 | 0.043198 | 0.138735 | 402 | 72 |
| 208004 | GHEDO 230.00 | 215004 | G-GIBE-OLD 230.00 | 0.021099 | 0.102687 | 0.1886 | 274 | 130 |
| 208006 | A.ALEM 230.00 | 208008 | MUGERII 230.00 | 0.015 | 0.042 | 0.13488 | 402 | 70 |
| 208009 | TORHAYILOCH 230.00 | 214001 | SEBATA-1 230.00 | 0.006886 | 0.012974 | 0.002495 | 115 | 5.3 |
| 209001 | ALAMATA 230.00 | 209004 | MEKELE 230.00 | 0.028534 | 0.084677 | 0.27195 | 318 | 141.14 |
| 209001 | ALAMATA 230.00 | 209007 | MEHONI 230.00 | 0.0077 | 0.0222 | 0.06708 | 402 | 36 |
| 209001 | ALAMATA 230.00 | 209013 | ASHEGODA WF 230.00 | 0.0265 | 0.0762 | 0.23048 | 402 | 123.69 |
| 209002 | ENDASILA 230.00 | 209003 | HUMERA 230.00 | 0.046434 | 0.137799 | 0.44256 | 318 | 229.68 |
| 209002 | ENDASILA 230.00 | 209006 | TEKEZE 230.00 | 0.032245 | 0.09569 | 0.30732 | 318 | 159.49 |
| 209002 | ENDASILA 230.00 | 209006 | TEKEZE 230.00 | 0.032245 | 0.09569 | 0.30732 | 318 | 159.49 |
| 209002 | ENDASILA 230.00 | 209010 | WELKAYT 230.00 | 0.034343 | 0.095995 | 0.308301 | 402 | 160 |
| 209003 | HUMERA 230.00 | 209010 | WELKAYT 230.00 | 0.034129 | 0.095395 | 0.306374 | 402 | 159 |

| | | | | | | | | |
|--------|--------------------|--------|--------------------|----------|----------|----------|-----|--------|
| 209003 | HUMERA 230.00 | 209011 | DANSHA 230.00 | 0.0219 | 0.0631 | 0.19062 | 402 | 102.3 |
| 209004 | MEKELE 230.00 | 209006 | TEKEZE 230.00 | 0.021228 | 0.062997 | 0.20232 | 318 | 105 |
| 209004 | MEKELE 230.00 | 209006 | TEKEZE 230.00 | 0.021228 | 0.062997 | 0.20232 | 318 | 105 |
| 209004 | MEKELE 230.00 | 209007 | MEHONI 230.00 | 0.020982 | 0.060405 | 0.182609 | 402 | 98 |
| 209004 | MEKELE 230.00 | 209008 | DALOL 230.00 | 0.0343 | 0.096 | 0.3083 | 402 | 160 |
| 209004 | MEKELE 230.00 | 209008 | DALOL 230.00 | 0.0343 | 0.096 | 0.3083 | 402 | 160 |
| 209004 | MEKELE 230.00 | 209009 | MEKELEPVC 230.00 | 0.0009 | 0.0024 | 0.00771 | 402 | 4 |
| 209004 | MEKELE 230.00 | 209009 | MEKELEPVC 230.00 | 0.0009 | 0.0024 | 0.00771 | 402 | 4 |
| 209004 | MEKELE 230.00 | 209013 | ASHEGODA WF 230.00 | 0.0041 | 0.0117 | 0.0354 | 402 | 19 |
| 210001 | AWSH-7KL 230.00 | 210006 | MELKASEDI 230.00 | 0.005995 | 0.017259 | 0.052174 | 402 | 28 |
| 210001 | AWSH-7KL 230.00 | 210006 | MELKASEDI 230.00 | 0.005995 | 0.017259 | 0.052174 | 402 | 28 |
| 210001 | AWSH-7KL 230.00 | 211001 | KOKA 230.00 | 0.022453 | 0.100028 | 0.192398 | 353 | 129.32 |
| 210001 | AWSH-7KL 230.00 | 211007 | NURAERA 230.00 | 0.031 | 0.0894 | 0.27019 | 402 | 145 |
| 210002 | DITCHETO 230.00 | 210003 | SEMERA 230.00 | 0.011089 | 0.033901 | 0.10248 | 318 | 55 |
| 210003 | SEMERA 230.00 | 210004 | TENDAHO 230.00 | 0.0043 | 0.0123 | 0.03727 | 402 | 20 |
| 211001 | KOKA 230.00 | 211002 | M-WAKNA 230.00 | 0.029689 | 0.127801 | 0.24166 | 257 | 163.86 |
| 211001 | KOKA 230.00 | 211002 | M-WAKNA 230.00 | 0.029689 | 0.127801 | 0.24166 | 257 | 163.86 |
| 211001 | KOKA 230.00 | 211005 | NAZERET-ADAM230.00 | 0.004496 | 0.012944 | 0.039131 | 402 | 21 |
| 211001 | KOKA 230.00 | 211022 | ADAM-IIWIND 230.00 | 0.0022 | 0.0065 | 0.01957 | 402 | 10.5 |
| 211001 | KOKA 230.00 | 213001 | DUKEM TAP 2 230.00 | 0.005374 | 0.025525 | 0.0491 | 274 | 33 |
| 211001 | KOKA 230.00 | 215002 | DUKEM TAP 1 230.00 | 0.005374 | 0.025525 | 0.0491 | 274 | 33 |
| 211002 | M-WAKNA 230.00 | 213002 | RAMO 230.00 | 0.047736 | 0.133429 | 0.428524 | 402 | 222.39 |
| 211002 | M-WAKNA 230.00 | 213006 | GINIR 230.00 | 0.034042 | 0.098004 | 0.296274 | 402 | 159 |
| 211002 | M-WAKNA 230.00 | 213010 | AWASA-230 230.00 | 0.0225 | 0.063 | 0.20238 | 402 | 105 |

| | | | | | | | | |
|--------|-----------------------|--------|--------------------|----------|----------|----------|-----|--------|
| 211002 | M-WAKNA 230.00 | 213010 | AWASA-230 230.00 | 0.0225 | 0.063 | 0.20238 | 402 | 105 |
| 211003 | MODJO3230 230.00 | 212003 | DB-ZEIT3230 230.00 | 0.0017 | 0.0048 | 0.01542 | 402 | 8 |
| 212001 | KALITI1 230.00 | 212005 | AKAKI2-230 230.00 | 0.000773 | 0.00312 | 0.005899 | 331 | 4 |
| 212001 | KALITI1 230.00 | 212005 | AKAKI2-230 230.00 | 0.000773 | 0.00312 | 0.005899 | 331 | 4 |
| 212001 | KALITI1 230.00 | 214001 | SEBATA-1 230.00 | 0.002314 | 0.011264 | 0.02069 | 274 | 14.26 |
| 212001 | KALITI1 230.00 | 214008 | H.TANNERY 230.00 | 0.0024 | 0.0068 | 0.0205 | 402 | 11 |
| 212002 | DUKEM230 230.00 | 212003 | DB-ZEIT3230 230.00 | 0.0017 | 0.0048 | 0.01542 | 402 | 8 |
| 212002 | DUKEM230 230.00 | 212003 | DB-ZEIT3230 230.00 | 0.0017 | 0.0048 | 0.01542 | 402 | 8 |
| 212005 | AKAKI2-230 230.00 | 213001 | DUKEM TAP 2 230.00 | 0.01237 | 0.049916 | 0.094387 | 331 | 64 |
| 212005 | AKAKI2-230 230.00 | 215002 | DUKEM TAP 1 230.00 | 0.01237 | 0.049916 | 0.094387 | 331 | 64 |
| 213002 | RAMO 230.00 | 213003 | GODE 230.00 | 0.063526 | 0.177565 | 0.570273 | 402 | 295.96 |
| 213002 | RAMO 230.00 | 213003 | GODE 230.00 | 0.063526 | 0.177565 | 0.570273 | 402 | 295.96 |
| 213002 | RAMO 230.00 | 213006 | GINIR 230.00 | 0.016271 | 0.046845 | 0.141615 | 402 | 76 |
| 213004 | ALABA 230.00 | 213005 | HOSAINA 230.00 | 0.008435 | 0.024285 | 0.073416 | 402 | 39.4 |
| 213005 | HOSAINA 230.00 | 214003 | WOLKITE 230.00 | 0.019119 | 0.055043 | 0.166398 | 402 | 89.3 |
| 213008 | OMA-KURAZF1 230.00 | 213009 | W.SODO230 230.00 | 0.0526 | 0.147 | 0.47209 | 402 | 245 |
| 213008 | OMA-KURAZF1 230.00 | 213009 | W.SODO230 230.00 | 0.0526 | 0.147 | 0.47209 | 402 | 245 |
| 213010 | AWASA-230 230.00 | 213011 | YIRGALEM-II 230.00 | 0.008571 | 0.024 | 0.077074 | 318 | 40 |
| 213010 | AWASA-230 230.00 | 213011 | YIRGALEM-II 230.00 | 0.008571 | 0.024 | 0.077074 | 318 | 40 |
| 213010 | AWASA-230 230.00 | 213012 | YIRGALEMI 230.00 | 0.0075 | 0.021 | 0.06744 | 402 | 35 |
| 213011 | YIRGALEM-II 230.00 | 213012 | YIRGALEMI 230.00 | 0.0026 | 0.0072 | 0.02312 | 402 | 12 |
| 213011 | YIRGALEM-II 230.00 | 213012 | YIRGALEMI 230.00 | 0.0026 | 0.0072 | 0.02312 | 402 | 12 |
| 214001 | SEBATA-1 230.00 | 214002 | SEBETA-2 230.00 | 0.002321 | 0.011775 | 0.02228 | 280 | 15.02 |
| 214001 | SEBATA-1 230.00 | 214002 | SEBETA-2 230.00 | 0.002321 | 0.011775 | 0.02228 | 280 | 15.02 |
| 214001 | SEBATA-1 | 214004 | WOLISO 230.00 | 0.02141 | 0.061638 | 0.186336 | 402 | 100 |

| | | | | | | | | |
|--------|-----------------------|--------|--------------------|----------|----------|----------|------|-------|
| | 230.00 | | | | | | | |
| 214001 | SEBATA-1 230.00 | 214006 | ADDIS-EFW 230.00 | 0.0011 | 0.003 | 0.00963 | 402 | 5 |
| 214001 | SEBATA-1 230.00 | 214006 | ADDIS-EFW 230.00 | 0.0011 | 0.003 | 0.00963 | 402 | 5 |
| 214001 | SEBATA-1 230.00 | 214008 | H.TANNERY 230.00 | 0.0016 | 0.0045 | 0.01353 | 402 | 7.26 |
| 214003 | WOLKITE 230.00 | 214004 | WOLISO 230.00 | 0.009035 | 0.026011 | 0.078634 | 402 | 42.2 |
| 214003 | WOLKITE 230.00 | 215004 | G-GIBE-OLD 230.00 | 0.010779 | 0.056025 | 0.10125 | 280 | 70 |
| 215001 | BEDELLE 230.00 | 215006 | AGARO 230.00 | 0.017494 | 0.048897 | 0.157041 | 402 | 81.5 |
| 215001 | BEDELLE 230.00 | 215006 | AGARO 230.00 | 0.017494 | 0.048897 | 0.157041 | 402 | 81.5 |
| 215002 | DUKEM TAP 1 230.00 | 215007 | EAST INDUSTR230.00 | 0 | 0.0001 | 0 | 0 | 0 |
| 215003 | G-GIBE-1 230.00 | 215004 | G-GIBE-OLD 230.00 | 0.000814 | 0.003867 | 0.00744 | 274 | 5 |
| 215003 | G-GIBE-1 230.00 | 215004 | G-GIBE-OLD 230.00 | 0.000814 | 0.003867 | 0.00744 | 274 | 5 |
| 215003 | G-GIBE-1 230.00 | 215005 | JIMMA 230.00 | 0.014081 | 0.039358 | 0.126403 | 402 | 65.6 |
| 215003 | G-GIBE-1 230.00 | 215005 | JIMMA 230.00 | 0.014081 | 0.039358 | 0.126403 | 402 | 65.6 |
| 215005 | JIMMA 230.00 | 215006 | AGARO 230.00 | 0.008307 | 0.023219 | 0.07457 | 402 | 38.7 |
| 215005 | JIMMA 230.00 | 215006 | AGARO 230.00 | 0.008307 | 0.023219 | 0.07457 | 402 | 38.7 |
| 402001 | SULULTA 400.00 | 402003 | GEBRE-GURCHA400.00 | 0.002 | 0.0271 | 0.7483 | 1341 | 131.5 |
| 402001 | SULULTA 400.00 | 402003 | GEBRE-GURCHA400.00 | 0.0027 | 0.0213 | 0.9377 | 1973 | 131.5 |
| 402001 | SULULTA 400.00 | 407003 | D-MARKOS 400.00 | 0.003335 | 0.04436 | 1.22684 | 1341 | 215.6 |
| 402001 | SULULTA 400.00 | 407003 | D-MARKOS 400.00 | 0.0045 | 0.035 | 1.54022 | 1973 | 216 |
| 402001 | SULULTA 400.00 | 414002 | HOLETA-400 400.00 | 0.0006 | 0.005 | 0.22105 | 1973 | 31 |
| 402001 | SULULTA 400.00 | 414002 | HOLETA-400 400.00 | 0.0006 | 0.005 | 0.22105 | 1973 | 31 |
| 402002 | AKAKI2400 400.00 | 412001 | DB-ZEIT2400 400.00 | 0.0006 | 0.0049 | 0.21392 | 1973 | 30 |
| 402002 | AKAKI2400 400.00 | 412001 | DB-ZEIT2400 400.00 | 0.0006 | 0.0049 | 0.21392 | 1973 | 30 |
| 402002 | AKAKI2400 400.00 | 413001 | W.SODO400 400.00 | 0.0055 | 0.0432 | 1.90389 | 1342 | 267 |
| 402002 | AKAKI2400 | 413001 | W.SODO400 400.00 | 0.0055 | 0.0432 | 1.90389 | 1342 | 267 |

| | | | | | | | | |
|--------|------------------------|--------|---------------------|----------|----------|----------|------|--------|
| | 400.00 | | | | | | | |
| 402002 | AKAKI2400 400.00 | 414001 | SEBETA-2 400.00 | 0.0007 | 0.0057 | 0.22078 | 1973 | 33 |
| 402002 | AKAKI2400 400.00 | 414002 | HOLETA-400 400.00 | 0.001 | 0.0079 | 0.349 | 1973 | 49 |
| 402002 | AKAKI2400 400.00 | 414002 | HOLETA-400 400.00 | 0.001 | 0.0079 | 0.349 | 1973 | 49 |
| 402003 | GEBRE- GURCHA400.00 | 407003 | D-MARKOS 400.00 | 0.0014 | 0.018 | 0.4979 | 1341 | 87.5 |
| 402003 | GEBRE- GURCHA400.00 | 407003 | D-MARKOS 400.00 | 0.0018 | 0.0142 | 0.6239 | 1973 | 87.5 |
| 403001 | HURSO400 400.00 | 411001 | AWASH7-400 400.00 | 0.0039 | 0.0302 | 1.32987 | 1973 | 186.5 |
| 403001 | HURSO400 400.00 | 411001 | AWASH7-400 400.00 | 0.0039 | 0.0302 | 1.32987 | 1973 | 186.5 |
| 406001 | WOLDIA 400.00 | 407001 | BAHIRDAR-II 400.00 | 0.0056 | 0.0435 | 1.91815 | 1973 | 269 |
| 406001 | WOLDIA 400.00 | 407001 | BAHIRDAR-II 400.00 | 0.0056 | 0.0435 | 1.91815 | 1973 | 269 |
| 407001 | BAHIRDAR-II 400.00 | 407002 | BELES 400.00 | 0.000958 | 0.012159 | 0.37713 | 1341 | 62.84 |
| 407001 | BAHIRDAR-II 400.00 | 407002 | BELES 400.00 | 0.000958 | 0.012159 | 0.37713 | 1341 | 62.84 |
| 407001 | BAHIRDAR-II 400.00 | 407003 | D-MARKOS 400.00 | 0.002997 | 0.03986 | 1.10239 | 1341 | 193.73 |
| 407001 | BAHIRDAR-II 400.00 | 407004 | GRAN RENAIIS 400.00 | 0.005033 | 0.041797 | 1.605239 | 1973 | 240 |
| 407002 | BELES 400.00 | 407004 | GRAN RENAIIS 400.00 | 0.0044 | 0.0366 | 1.40458 | 1973 | 210 |
| 411001 | AWASH7-400 400.00 | 412001 | DB-ZEIT2400 400.00 | 0.0035 | 0.027 | 1.18726 | 1973 | 166.5 |
| 411001 | AWASH7-400 400.00 | 412001 | DB-ZEIT2400 400.00 | 0.0035 | 0.027 | 1.18726 | 1973 | 166.5 |
| 413001 | W.SODO400 400.00 | 413002 | YIRGALEMII 400.00 | 0.00179 | 0.014697 | 0.56384 | 1973 | 84.3 |
| 413001 | W.SODO400 400.00 | 413002 | YIRGALEMII 400.00 | 0.00179 | 0.014697 | 0.56384 | 1973 | 84.3 |
| 413001 | W.SODO400 400.00 | 415001 | G-GIBE-2 400.00 | 0.0025 | 0.0207 | 0.79593 | 1341 | 119 |
| 413001 | W.SODO400 400.00 | 415003 | GIBE-III 400.00 | 0.001 | 0.0081 | 0.35653 | 1973 | 50 |
| 413001 | W.SODO400 400.00 | 415003 | GIBE-III 400.00 | 0.001 | 0.0081 | 0.35653 | 1973 | 50 |
| 413001 | W.SODO400 400.00 | 415004 | G-GIBE3 400.00 | 0.001 | 0.0081 | 0.35653 | 1342 | 50 |

| | | | | | | | | |
|--------|----------------------|--------|-------------------|----------|----------|----------|------|-------|
| 413001 | W.SODO400 400.00 | 415004 | G-GIBE3 400.00 | 0.001 | 0.0081 | 0.35653 | 1342 | 50 |
| 413001 | W.SODO400 400.00 | 415004 | G-GIBE3 400.00 | 0.0011 | 0.0083 | 0.36366 | 1342 | 51 |
| 413002 | YIRGALEMII 400.00 | 413003 | GENDAWAIII 400.00 | 0.005638 | 0.043914 | 1.932408 | 1973 | 271 |
| 413002 | YIRGALEMII 400.00 | 413003 | GENDAWAIII 400.00 | 0.005638 | 0.043914 | 1.932408 | 1973 | 271 |
| 414001 | SEBETA-2 400.00 | 414002 | HOLETA-400 400.00 | 0.0004 | 0.0029 | 0.12835 | 1973 | 18 |
| 414001 | SEBETA-2 400.00 | 414002 | HOLETA-400 400.00 | 0.0004 | 0.0029 | 0.12835 | 1973 | 18 |
| 414001 | SEBETA-2 400.00 | 415001 | G-GIBE-2 400.00 | 0.002839 | 0.037756 | 1.04419 | 1341 | 183.5 |
| 415001 | G-GIBE-2 400.00 | 415002 | GIGIBE-OLD 400.00 | 0.000431 | 0.005737 | 0.15868 | 1341 | 27.89 |

APPENDIX C: Load Flow Analysis

Table C-1 Peak load flow

| X-- AREA -- X | GENE- RATION | FROM IND GENERATION | TO IND MOTORS | TO LOAD | TO BUS SHUNT | GNE BUS DEVICES | TO LINE SHUNT | FROM CHARGING | TO LOSSES | TO TIE LINES | TO TIES LOADS |
|------------------|-----------------|------------------------|------------------|------------|--------------------|-----------------------|---------------------|------------------|--------------|-----------------|------------------|
| 1 | 0 | 0 | 0 | 12.2 | 0 | 0 | 0.1 | 0 | 0.2 | -12.6 | -120.6 |
| ASOSA | 0 | 0 | 0 | 1.6 | 7.8 | 0 | 0 | 14 | 0.9 | 3.5 | -34.2 |
| 2 | 0 | 0 | 0 | 256.2 | 0 | 0 | 0.8 | 0 | 8 | -265 | -218.7 |
| EASTERN A.A. | 0 | 0 | 0 | 82.1 | 0 | 0 | 2.3 | 345.2 | 62.3 | 198.5 | 202.6 |
| 3 | 0 | 0 | 0 | 145.3 | 0.2 | 0 | 0.6 | 0 | 9.6 | -155.8 | -86.4 |

| | | | | | | | | | | | |
|---------|---|---|---|------|----|---|------|-------|----|-------|-------|
| EASTERN | 0 | 0 | 0 | 66.5 | 55 | 0 | 51.5 | 322.6 | 36 | 113.7 | 150.5 |
|---------|---|---|---|------|----|---|------|-------|----|-------|-------|

| | | | | | | | | | | | |
|---------|---|---|---|-----|------|---|-----|------|-----|-------|-------|
| 4 | 0 | 0 | 0 | 16 | 0.1 | 0 | 0.1 | 0 | 0.9 | -17.1 | -17 |
| GAMBELA | 0 | 0 | 0 | 7.7 | 50.5 | 0 | 0.1 | 44.1 | 3.2 | -17.4 | -17.4 |

| | | | | | | | | | | | |
|--------|---|---|---|------|---|---|---|-----|-----|-------|-------|
| 5 | 0 | 0 | 0 | 12.4 | 0 | 0 | 0 | 0 | 0.3 | -12.8 | -12.8 |
| JIJIGA | 0 | 0 | 0 | 6.8 | 0 | 0 | 0 | 3.9 | 1.9 | -4.8 | -4.8 |

| | | | | | | | | | | | |
|-----------------|---|---|---|------|------|---|-----|------|------|-------|-------|
| 6 | 0 | 0 | 0 | 71.3 | 0.1 | 0 | 0.2 | 0 | 3.4 | -75 | -75 |
| NORTH EASTER | 0 | 0 | 0 | 27.1 | 14.8 | 0 | 0.5 | 42.4 | 13.5 | -13.4 | -13.4 |

| | | | | | | | | | | | |
|-----------------|------|---|---|--------|-----|---|------|-------|-------|-------|-------|
| 7 | 3434 | 0 | 0 | 3279.1 | 0.7 | 0 | 1.1 | 0 | 33.7 | 119.4 | 104.4 |
| NORTH WESTER | 1477 | 0 | 0 | 1568.8 | 271 | 0 | 62.8 | 589.3 | 170.7 | -7.1 | -14.4 |

| | | | | | | | | | | | |
|-----------------|-------|---|---|-------|---|---|-----|-------|------|-------|-------|
| 8 | 189.9 | 0 | 0 | 205.6 | 0 | 0 | 0.9 | 0 | 12 | -28.6 | -29.8 |
| NORTHERN A.A | 23.5 | 0 | 0 | 82.6 | 0 | 0 | 2.4 | 112.8 | 72.1 | -20.7 | -21.7 |

| | | | | | | | | | | | |
|----------|-------|---|---|-------|------|---|------|-------|------|-------|-------|
| 9 | 183.3 | 0 | 0 | 203.8 | 0.2 | 0 | 0.8 | 0 | 7.7 | -29.2 | -29.2 |
| NORTHERN | 43.8 | 0 | 0 | 96.4 | 65.9 | 0 | 14.3 | 183.9 | 64.8 | -13.7 | -13.7 |

| | | | | | | | | | | | |
|--------|---|---|---|------|---|---|------|------|-----|-------|-------|
| 10 | 0 | 0 | 0 | 13.9 | 0 | 0 | 0.2 | 0 | 1.8 | -15.9 | -15.9 |
| SEMERA | 0 | 0 | 0 | 6.7 | 0 | 0 | 15.5 | 74.1 | 7.7 | 44.1 | 44.1 |

| | | | | | | | | | | | |
|-----------------|-------|---|---|-------|------|---|-----|------|------|------|------|
| 11 | 181.8 | 0 | 0 | 153.5 | 0.1 | 0 | 1 | 0 | 8.3 | 18.9 | 18.8 |
| SOUTH EASTER | 89.5 | 0 | 0 | 79.6 | 17.9 | 0 | 4.8 | 90.1 | 49.7 | 27.6 | 27.6 |

| | | | | | | | | | | | |
|----------|-----|---|---|-------|------|---|-----|-------|-------|--------|--------|
| 12 | 3.3 | 0 | 0 | 449 | 0.2 | 0 | 0.8 | 0 | 27 | -473.7 | -458.5 |
| SOUTHERN | 0.4 | 0 | 0 | 188.6 | 87.7 | 0 | 3.2 | 211.2 | 269.7 | -337.6 | -330.2 |

| | | | | | | | | | | | | |
|-----------------|--------|---|---|--------|--------|---|-------|--------|--------|--------|--------|--|
| A.A | | | | | | | | | | | | |
| 13 | 0 | 0 | 0 | 158.8 | 0.5 | 0 | 0.6 | 0 | 34.5 | -194.4 | -209 | |
| SOUTHERN | 0 | 0 | 0 | 72.2 | 173 | 0 | 1.3 | 233.7 | 113.5 | -126.2 | -133.3 | |
| 14 | 0 | 0 | 0 | 218.9 | 0 | 0 | 1 | 0 | 15.1 | -235 | -220 | |
| WESTERN A.A. | 0 | 0 | 0 | 84.3 | -256.2 | 0 | 3.5 | 209.6 | 164.3 | 213.8 | 221 | |
| 15 | 1478.6 | 0 | 0 | 84 | 0.1 | 0 | 1.1 | 0 | 16.5 | 1376.9 | 1376.5 | |
| WESTERN | 444.8 | 0 | 0 | 40.3 | 45.4 | 0 | 3.4 | 215.3 | 631.5 | -60.3 | -60.5 | |
| 20 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | -6.7 | |
| | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | -2.3 | |
| COLUMN | 5470.9 | 0 | 0 | 5280.3 | 2.2 | 0 | 9.4 | 0 | 179 | 0 | 0 | |
| TOTALS | 2078.9 | 0 | 0 | 2411.3 | 532.8 | 0 | 165.5 | 2692.4 | 1661.7 | 0 | 0 | |

Table C-2 Generator VAR limits

| X-- NAME --X | BAS KV | MW | MVAR | QMAX | QMIN | VSCHED | V ACTUAL | X-- NAME --X | BAS KV | MVA BASE | AREA SWING |
|--------------|--------|-----|------|------|------|--------|----------|--------------|--------|----------|------------|
| ABA SAMUEL | 6.3 | 3.3 | 0.4 | 0.4 | -0.2 | 1 | 0.9815 | ABA SAMUEL | 45 | 5.4 | 1 |
| AWASH2-1 | 10.5 | 6.4 | 12.9 | 12.9 | -16 | 1 | 0.9475 | AWASH2 | 132 | 20 | 2 |
| AWASH3-1 | 10.5 | 6.4 | 12.9 | 12.9 | -16 | 1 | 0.9483 | AWASH-3 | 132 | 20 | 2 |
| KOKA1 | 10.5 | 6.1 | 13.1 | 13.1 | -12 | 1 | 0.9547 | KOKA | 132 | 18 | 2 |
| AWASH2-2 | 10.5 | 6.4 | 12.9 | 12.9 | -16 | 1 | 0.9475 | AWASH2 | 132 | 20 | 2 |
| AWASH3-2 | 10.5 | 6.4 | 12.9 | 12.9 | -16 | 1 | 0.9483 | AWASH-3 | 132 | 20 | 2 |

| | | | | | | | | | | | |
|-------------|------|------|-------|------|-------|------|--------|-----------------|-----|-------|---|
| KOKA2 | 10.5 | 6.1 | 13.1 | 13.1 | -12 | 1 | 0.9547 | KOKA | 132 | 18 | 2 |
| ADAMA WF-I | 33 | 26.7 | 17 | 17 | -17 | 1 | 0.9594 | ADAMA-I WIND | 132 | 53.7 | 2 |
| ADAMA WF-II | 33 | 87.5 | 0 | 49.7 | 0 | 1 | 1.0039 | ADAMA II WF | 230 | 161.2 | 2 |
| NESHE-1 | 13.8 | 44.6 | -13.7 | 18.1 | -13.7 | 1 | 1.0271 | NESHE | 230 | 53 | 4 |
| NESHE-2 | 13.8 | 44.6 | -13.7 | 18.1 | -13.7 | 1 | 1.0271 | NESHE | 230 | 53 | 4 |
| G-GIBE1-1 | 13.8 | 57.1 | 18.7 | 18.7 | -18.7 | 1.02 | 1.0094 | GI GIBE-1 | 230 | 73 | 8 |
| G-GIBE1-2 | 13.8 | 14.3 | 38.4 | 38.4 | -50.9 | 1.02 | 1.0094 | GI GIBE-1 | 230 | 73 | 8 |
| G-GIBE1-3 | 13.8 | 57.1 | 18.7 | 18.7 | -18.7 | 1.02 | 1.0094 | GI GIBE-1 | 230 | 73 | 8 |
| ASHEGODA-WF | 33 | 8.3 | 58.4 | 58.4 | 0 | 1 | 0.998 | ASHEGODA WF | 230 | 188.5 | 9 |




Figure C-1 PSS/E single line model peak load of 2017 Ethiopian Transmission Grid

APPENDIX D: General Network Diagram of EEP

Table D-1 Buses with voltage less than their normal low limit

| BUS# | X-- NAME --X | BASKV | V(PU) | VLIMIT | BUS# | X-- NAME --X | BASKV | V(PU) | VLIMIT |
|--------|--------------|-------|--------|--------|--------|--------------|-------|--------|--------|
| 102001 | ADD EAST-II | 132 | 0.944 | 0.95 | 102002 | B.WGN-TP | 132 | 0.9468 | 0.95 |
| 102003 | COTEBEI-I | 132 | 0.9497 | 0.95 | 102004 | DEBRE BERHAN | 132 | 0.9413 | 0.95 |
| 102006 | WERGENU | 132 | 0.9391 | 0.95 | 102010 | ADDIS-E1 | 132 | 0.9492 | 0.95 |
| 105001 | JIJIGA I | 132 | 0.9198 | 0.95 | 106004 | SHOWA-ROBIT | 132 | 0.9449 | 0.95 |
| 108001 | ADDIS-NORTH | 132 | 0.9407 | 0.95 | 108002 | DERBA-CEMENT | 132 | 0.6832 | 0.95 |
| 108006 | MUGER | 132 | 0.789 | 0.95 | 108007 | DERBA-TAP | 132 | 0.7944 | 0.95 |
| 108015 | MINILIK TS | 132 | 0.9451 | 0.95 | 108016 | HABESHA CEM | 132 | 0.886 | 0.95 |
| 108017 | HABESHA TP | 132 | 0.886 | 0.9 | 109001 | ADIGRAT | 132 | 0.9133 | 0.95 |
| 109002 | ADWA | 132 | 0.8713 | 0.95 | 109005 | MESOBO | 132 | 0.9494 | 0.95 |
| 109007 | WUKRO | 132 | 0.9371 | 0.95 | 109008 | WUKRO-TP | 132 | 0.9373 | 0.95 |
| 109020 | ABIADI MB TP | 132 | 0.8948 | 0.95 | 109021 | ABIADI MB | 132 | 0.8932 | 0.95 |
| 111001 | ADAMI TULU | 132 | 0.9024 | 0.95 | 111002 | ASSELA | 132 | 0.9266 | 0.95 |
| 111027 | WON SUG TP | 132 | 0.9474 | 0.95 | 111028 | WON SUG | 132 | 0.9473 | 0.95 |
| 112001 | ADDIS CENTER | 132 | 0.9253 | 0.95 | 112002 | GOFA | 132 | 0.9456 | 0.95 |
| 112007 | KALITI TWO | 132 | 0.9493 | 0.95 | 112009 | MEKANISA | 132 | 0.9472 | 0.95 |
| 112014 | NEFASILK | 132 | 0.9487 | 0.95 | 112019 | DANGOTE TP | 132 | 0.791 | 0.95 |
| 113003 | AWASA | 132 | 0.8537 | 0.95 | 113004 | BOCULUGUMA | 132 | 0.7851 | 0.95 |
| 113005 | DILLA | 132 | 0.8036 | 0.95 | 113007 | HAGER MARIAM | 132 | 0.7929 | 0.95 |
| 113009 | SHASHEMENE | 132 | 0.8962 | 0.95 | 113011 | SHAKISO | 132 | 0.7711 | 0.95 |
| 113014 | YIRGALEM | 132 | 0.819 | 0.95 | 113029 | AWASA MOBILE | 132 | 0.9353 | 0.95 |




Figure D-1 General Network Diagram

